

BASSANO AGCM, AB, CanadaWMO: **710080**Lat: **50.8925N**Lon: **112.4650W**Elev: **2648**StdP: **13.34**Time Zone: **-7.00 (NAM)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-24.2	-18.2	-30.5	1.1	-24.1	-24.0	1.6	-17.9	34.9	19.2	28.9	27.2	4.9	280	0.720

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.4	87.6	61.6	83.9	60.5	80.4	59.9	64.9	78.9	63.4	78.0	61.9	76.4	10.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.1	85.7	70.5	58.1	79.5	68.7	56.3	74.4	66.7	31.3	79.0	30.1	78.6	29.0	76.3	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.7	25.4	21.8	DB	-33.2	94.2	5.1	3.8	-36.9	96.9	-39.9	99.2	-42.8	101.3	-46.6	104.1	(4)
(5)			WB	-33.4	69.7	5.1	2.2	-37.1	71.3	-40.1	72.6	-42.9	73.9	-46.6	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.7	15.3	13.3	26.2	39.3	51.3	58.6	63.9	62.6	53.8	40.6	25.7	12.6
	DBStd	21.69	15.30	15.23	14.78	9.13	7.71	5.34	4.79	5.59	8.38	9.12	13.77	14.66
	HDD50	5513	1076	1026	738	332	79	4	0	1	54	311	732	1160
	HDD65	9688	1541	1446	1203	772	426	202	79	113	344	757	1180	1625
	CDD50	1403	0	0	0	10	119	262	430	392	168	20	2	0
	CDD65	102	0	0	0	0	2	9	44	39	8	0	0	0
	CDH74	2747	0	0	0	13	176	290	975	930	351	12	0	0
	CDH80	830	0	0	0	2	31	60	309	317	110	1	0	0
Wind	WSAvg	9.3	9.9	8.6	9.5	10.5	10.5	9.8	8.5	8.2	8.7	9.2	9.2	8.8
Precipitation	PrecAvg	13.8	0.5	0.4	0.7	1.2	2.1	2.8	1.7	1.5	1.1	0.7	0.6	0.5
	PrecMax	21.0	1.0	0.9	2.2	2.7	3.6	7.9	4.0	3.7	4.3	1.9	1.5	1.1
	PrecMin	6.3	0.0	0.0	0.0	0.3	0.5	0.9	0.3	0.0	0.1	0.1	0.0	0.0
	PrecStd	2.6	0.2	0.2	0.4	0.6	0.9	1.5	1.0	0.9	0.9	0.4	0.4	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.0	48.7	62.4	74.2	83.7	85.8	92.0	92.6	88.4	75.1	64.2	49.4
		MCWB	39.1	39.5	46.6	51.7	56.2	63.7	64.4	61.3	59.3	54.4	48.4	40.2
	2%	DB	43.1	42.8	57.0	68.0	79.0	80.9	87.4	87.5	83.5	67.6	55.8	41.9
		MCWB	36.8	36.0	42.9	48.9	55.1	59.5	62.8	61.3	57.9	50.7	43.6	36.0
	5%	DB	39.8	38.2	51.3	62.2	74.3	77.1	83.2	83.4	77.6	62.7	49.3	37.9
		MCWB	35.0	33.7	40.4	45.3	53.2	58.1	62.3	60.8	56.2	48.4	40.1	33.5
	10%	DB	36.5	34.1	45.4	56.9	69.4	73.4	79.6	79.2	72.4	57.5	43.7	33.3
		MCWB	32.8	31.1	37.4	42.5	51.0	56.4	61.4	59.8	54.5	45.4	36.3	29.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	41.3	47.7	52.4	58.0	65.3	69.0	66.2	61.5	55.1	48.6	41.3
		MCDB	46.7	48.3	60.6	72.1	79.9	79.3	81.9	80.0	81.2	71.3	64.0	48.7
	2%	WB	37.1	36.3	44.0	49.0	55.9	62.5	65.8	64.1	59.1	51.8	44.1	36.3
		MCDB	42.3	41.6	55.1	66.4	75.7	75.7	78.8	79.6	78.3	64.9	54.4	41.6
	5%	WB	35.1	33.9	40.9	45.9	54.2	60.1	64.0	62.7	57.0	48.7	40.6	33.5
		MCDB	39.5	38.3	50.3	60.1	71.3	72.9	78.0	78.9	75.2	61.1	48.6	37.9
	10%	WB	32.8	31.1	37.6	43.3	52.2	58.2	62.7	61.0	54.9	46.1	37.0	30.1
		MCDB	36.6	34.0	44.7	55.2	66.5	70.5	76.8	75.6	71.1	56.4	42.6	33.3
Mean Daily Temperature Range	5% DB	MDBR	19.4	20.9	21.7	25.0	26.4	24.4	27.4	28.1	28.1	25.8	21.5	19.5
		MCDBR	20.6	24.4	29.9	36.6	35.5	31.7	35.6	37.9	39.1	34.2	28.5	23.1
		MCWBR	15.7	18.5	17.8	19.0	15.5	14.0	14.8	14.7	17.1	18.6	17.8	18.0
	5% WB	MCDBR	19.9	23.8	28.2	35.1	30.9	28.5	30.0	31.4	35.5	32.8	28.3	23.4
MCWBR		15.3	18.2	17.7	18.8	14.0	13.9	14.1	13.8	16.2	18.3	18.2	18.6	
Clear-Sky Solar Irradiance	taub	0.267	0.274	0.292	0.345	0.370	0.360	0.359	0.377	0.330	0.288	0.259	0.246	
	taud	2.388	2.445	2.458	2.309	2.291	2.368	2.399	2.324	2.432	2.527	2.490	2.414	
	Ebn at Noon	247	278	292	284	281	284	282	270	274	270	252	239	
	Edh at Noon	19	23	28	37	39	37	35	36	29	22	17	16	
All-Sky Solar Radiation	RadAvg	371	689	1115	1523	1827	1981	2141	1720	1216	743	402	283	
	RadStd	28	62	87	111	126	122	105	115	117	85	36	26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (83 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page