

CRAIGMYLE AGCM, AB, Canada

WMO: 710130

Lat: 51.775N

Lon: 112.252W

Elev: 2772

StdP: 13.28

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-22.9	-17.7	-28.4	1.2	-22.7	-23.3	1.7	-17.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.9	85.3	61.8	81.6	61.3	78.2	60.0	65.6	77.8	63.7	76.5	62.1	74.4	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.6	90.8	70.1	59.3	83.6	68.3	57.4	77.9	66.5	32.0	77.5	30.4	76.8	29.2	74.8	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-30.7	91.1	5.1	4.4	-34.4	94.3	-37.3	96.9	-40.2	99.4	-43.9	102.6
			-30.9	70.2	5.0	2.5	-34.6	72.0	-37.5	73.5	-40.3	74.9	-44.0	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	14.2	12.1	24.4	37.9	50.7	57.7	62.7	61.4	52.7	39.9	24.8	12.2		
	DBStd	21.57	14.96	14.42	14.29	9.52	7.93	5.67	5.21	5.97	8.48	9.14	13.12	14.20		
	HDD50	5759	1108	1060	793	373	90	8	0	2	66	330	756	1173		
	HDD65	10043	1573	1480	1258	814	446	227	107	142	375	778	1205	1638		
	CDD50	1276	0	0	0	10	111	239	393	356	148	18	1	0		
	CDD65	84	0	0	0	0	2	9	35	31	7	0	0	0		
	CDH74	1831	0	0	0	8	98	177	684	624	233	7	0	0		
	CDH80	481	0	0	0	0	11	31	195	184	60	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	15.1	0.6	0.4	0.6	1.0	1.9	3.0	2.6	2.1	1.3	0.6	0.6	0.5		
(15) Precipitation	PrecMax	19.3	1.3	0.9	2.1	2.4	3.7	6.0	5.9	4.3	3.2	1.4	1.9	1.1		
	PrecMin	9.0	0.0	0.0	0.1	0.1	0.2	1.3	0.9	0.1	0.2	0.2	0.1	0.0		
	PrecStd	2.6	0.3	0.2	0.4	0.6	0.9	1.2	1.2	1.1	0.7	0.4	0.4	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.4	44.1	58.9	72.0	81.2	83.8	90.1	90.3	86.3	73.4	60.1	46.1		
		MCWB	38.2	37.1	46.0	50.3	56.2	61.3	64.0	61.9	58.9	52.6	47.0	39.2		
	2%	DB	40.7	38.6	52.9	66.1	76.6	78.7	85.3	84.8	80.5	65.5	51.8	40.0		
		MCWB	36.0	33.9	41.8	48.1	54.3	59.8	63.6	61.7	58.4	50.1	42.2	34.8		
	5%	DB	38.1	35.5	47.4	60.2	72.4	75.1	81.2	80.9	75.6	60.3	45.7	35.8		
		MCWB	34.3	32.4	38.8	44.3	53.0	58.6	63.0	61.3	56.6	47.4	38.1	31.6		
	10%	DB	34.5	32.0	41.8	54.6	67.5	71.6	77.4	76.8	69.9	55.0	41.0	31.4		
		MCWB	31.2	29.6	35.7	41.8	50.8	57.0	61.8	60.5	54.6	44.7	35.5	28.4		
	0.4%	WB	38.8	38.4	46.7	51.8	58.1	65.2	70.5	67.5	61.9	55.1	47.1	39.9		
		MCDB	44.0	44.0	58.1	69.6	76.3	77.4	82.0	77.7	79.6	69.8	58.7	45.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.2	34.4	42.5	48.2	55.9	62.2	66.6	64.9	59.5	51.5	42.6	34.8		
		MCDB	40.2	38.0	51.3	64.7	72.4	74.8	78.9	77.7	76.3	62.9	51.0	39.6		
	5%	WB	34.4	32.2	39.3	45.3	54.0	60.3	64.4	63.2	57.2	48.2	39.2	31.7		
		MCDB	38.0	35.4	47.0	58.0	68.9	71.2	76.8	76.6	71.3	58.8	44.9	35.4		
	10%	WB	31.3	29.7	36.0	42.6	52.2	58.3	62.8	61.5	55.2	45.4	36.0	28.4		
		MCDB	34.3	32.0	41.2	53.4	65.5	68.7	74.8	73.8	69.9	54.3	40.0	31.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.7	18.3	19.2	22.2	24.1	22.5	24.9	25.1	25.1	22.3	18.2	17.0		
		MCDBR	18.5	19.1	25.5	32.4	31.3	28.7	32.2	33.4	34.8	30.0	24.5	19.9		
		MCWBR	14.6	15.5	15.3	16.7	14.0	13.1	14.0	14.0	15.4	16.4	15.7	15.5		
		MCDBR	18.2	18.7	24.6	30.2	27.4	25.1	27.7	28.8	31.7	28.1	22.7	19.8		
	5% WB	MCWBR	14.6	15.6	15.6	16.1	12.9	12.6	13.7	13.8	14.8	15.8	15.2	15.6		
(40) Clear-Sky Solar Irradiance	taub		0.268	0.281	0.283	0.333	0.361	0.359	0.354	0.369	0.319	0.284	0.255	0.246		
	taud		2.313	2.361	2.466	2.348	2.316	2.365	2.414	2.349	2.458	2.537	2.483	2.357		
	Ebn at Noon		238	270	294	287	283	284	283	272	276	269	249	230		
	Edh at Noon		20	25	28	35	38	37	35	35	28	21	16	16		
(44) All-Sky Solar Radiation	RadAvg		351	681	1121	1509	1829	1937	2060	1673	1179	710	374	270		
	RadStd		29	56	90	126	120	119	100	120	121	85	32	26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (78 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page