

YOHIN, NT, Canada

WMO: 710200

Lat: 61.242N

Lon: 123.742W

Elev: 669

StdP: 14.34

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.1	-29.4	-41.2	0.5	-34.0	-36.1	0.7	-29.4	10.2	33.1	9.4	31.0	0.7	340	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.6	84.2	63.2	80.6	61.4	77.3	60.1	65.6	78.4	63.8	76.0	62.1	73.6	4.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.3	83.0	68.8	59.3	77.3	67.1	57.6	72.7	65.6	30.8	78.6	29.4	75.7	28.2	74.1	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.3	7.3	DB	-42.6	91.6	4.4	4.2	-45.7	94.6	-48.3	97.1	-50.7	99.4	-53.9	102.5	(4)
			WB	-42.8	70.1	4.4	2.1	-45.9	71.6	-48.5	72.8	-50.9	74.0	-54.1	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.1	-3.8	1.9	12.3	33.4	49.5	58.6	63.2	58.6	47.6	32.1	8.7	-2.8
	DBStd	27.09	16.24	13.93	15.22	10.55	8.37	6.59	5.34	7.02	7.47	9.60	13.97	15.87
	HDD50	8383	1667	1347	1168	498	114	11	0	13	130	560	1240	1635
	HDD65	12818	2132	1767	1632	947	484	208	98	218	522	1020	1690	2100
	CDD50	1120	0	0	1	1	97	269	409	280	58	5	0	0
	CDD65	81	0	0	0	0	2	17	41	20	1	0	0	0
	CDH74	1510	0	0	0	0	107	350	682	350	18	3	0	0
	CDH80	367	0	0	0	0	17	88	180	79	3	0	0	0
Wind	WSAvg	2.6	2.1	2.3	3.0	3.6	3.4	2.7	2.6	2.4	2.6	2.7	2.2	1.8
Precipitation	PrecAvg	16.3	0.9	0.7	0.7	0.6	1.3	2.5	2.8	2.2	1.7	1.2	1.0	0.9
	PrecMax	22.9	1.7	1.8	1.7	1.2	2.4	5.1	7.3	4.3	4.0	2.1	2.2	2.0
	PrecMin	10.1	0.1	0.1	0.0	0.1	0.3	0.7	0.4	0.4	0.5	0.6	0.2	0.2
	PrecStd	2.8	0.4	0.4	0.4	0.3	0.6	1.3	1.3	0.8	0.8	0.5	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.6	48.6	56.7	67.7	81.8	87.6	90.0	86.3	75.6	65.5	52.3	50.7
		MCWB	40.4	38.6	42.0	48.7	57.9	63.8	64.7	64.7	57.0	50.6	41.1	39.9
	2%	DB	43.1	43.1	49.5	61.2	76.7	82.3	84.6	82.0	70.7	57.9	45.7	41.7
		MCWB	35.0	34.6	37.8	45.1	55.0	60.4	64.2	62.7	54.4	45.5	37.0	33.3
	5%	DB	34.1	34.0	44.0	56.7	72.6	77.8	81.0	77.8	66.8	53.2	38.1	31.4
		MCWB	28.8	28.2	34.5	42.6	53.2	59.1	62.7	61.0	52.9	43.0	31.4	26.9
	10%	DB	20.0	22.4	37.5	52.4	68.2	73.9	77.6	73.9	63.0	47.4	28.0	20.2
		MCWB	18.5	19.9	30.4	40.0	51.2	57.7	61.7	59.4	51.0	40.1	25.9	18.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.2	38.9	42.7	49.5	59.5	65.7	68.8	67.8	59.7	51.5	41.3	40.1
		MCDB	49.5	48.4	55.7	65.6	77.6	78.2	81.5	79.5	72.6	63.8	51.8	49.9
	2%	WB	35.1	34.6	38.3	45.7	56.6	63.5	66.3	64.6	56.0	46.3	37.3	33.7
		MCDB	43.1	43.3	48.4	60.0	73.9	75.7	79.2	77.8	66.6	56.1	45.5	41.6
	5%	WB	28.9	28.6	35.0	43.0	54.3	61.4	64.6	62.6	54.1	43.5	31.7	27.5
		MCDB	34.2	33.6	43.4	55.7	69.3	73.7	77.0	75.0	63.8	52.0	37.4	31.4
	10%	WB	18.5	20.1	30.8	40.5	52.1	59.4	63.0	60.5	52.2	40.6	25.8	18.8
		MCDB	20.1	22.2	37.4	51.2	66.1	70.7	74.4	71.2	61.2	47.0	28.4	20.0
Mean Daily Temperature Range	5% DB	MDBR	17.7	23.1	28.3	25.3	27.2	24.6	24.6	24.3	22.9	17.0	17.3	16.8
		MCDBR	32.2	35.0	32.6	33.3	35.6	33.0	32.4	31.9	31.0	27.8	26.2	31.4
		MCWBR	25.1	27.1	21.8	18.4	16.1	14.1	14.2	14.7	16.4	16.3	19.5	24.7
	5% WB	MCDBR	31.3	33.5	30.8	32.0	33.5	27.6	29.3	29.9	28.0	25.5	25.0	30.6
		MCWBR	24.3	26.0	20.6	18.0	15.7	12.9	14.1	15.1	16.0	15.5	18.6	24.1
Clear-Sky Solar Irradiance	taub	0.207	0.247	0.274	0.343	0.365	0.377	0.392	0.370	0.316	0.285	0.213	0.170	
	taud	2.119	2.285	2.255	2.166	2.333	2.375	2.359	2.425	2.556	2.448	2.136	1.972	
	Ebn at Noon	176	242	271	267	272	270	261	259	258	225	167	132	
	Edh at Noon	11	19	28	38	35	34	34	30	22	17	11	7	
All-Sky Solar Radiation	RadAvg	108	373	921	1486	1736	1772	1666	1339	849	392	138	55	
	RadStd	8	28	56	74	109	142	134	97	89	32	14	3	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (6 neighbors)	N/A	+3.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page