

YOHIN, NT, Canada

WMO: 710200

Lat: 61.242N

Lon: 123.742W

Elev: 204

StdP: 98.90

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.7	-34.1	-40.7	0.1	-36.7	-37.8	0.1	-34.1	4.6	0.6	4.2	-0.5	0.3	340	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	29.0	17.3	27.0	16.3	25.2	15.6	18.7	25.8	17.7	24.5	16.7	23.1	1.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.3	11.9	20.4	15.2	11.0	19.5	14.2	10.4	18.6	53.8	25.9	50.6	24.3	47.8	23.4	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.3	3.7	3.3	-41.4	33.1	2.4	2.3	-43.2	34.8	-44.6	36.2	-46.0	37.5	-47.7	39.2		
(5)			-41.5	21.1	2.4	1.2	-43.3	22.0	-44.7	22.7	-46.1	23.3	-47.8	24.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.1	-19.9	-16.7	-10.9	0.8	9.7	14.8	17.3	14.8	8.7	0.1	-13.0	-19.3	(6)	
	DBStd	15.05	9.02	7.74	8.45	5.86	4.65	3.66	2.97	3.90	4.15	5.34	7.76	8.82	(7)	
	HDD10.0	4657	926	748	649	277	63	6	0	7	72	311	689	908	(8)	
	HDD18.3	7121	1184	982	907	526	269	116	54	121	290	567	939	1167	(9)	
	CDD10.0	622	0	0	1	1	54	149	227	156	32	3	0	0	(10)	
	CDD18.3	45	0	0	0	0	1	9	23	11	1	0	0	0	(11)	
	CDH23.3	839	0	0	0	0	59	194	379	194	10	2	0	0	(12)	
	CDH26.7	204	0	0	0	0	9	49	100	44	2	0	0	0	(13)	
(14) Wind	WSAvg	1.2	0.9	1.0	1.3	1.6	1.5	1.2	1.1	1.1	1.2	1.2	1.0	0.8	(14)	
(15) Precipitation	PrecAvg	413	22	17	17	15	32	64	71	55	42	30	26	22	(15)	
	PrecMax	582	42	45	42	31	62	129	186	110	101	53	55	52	(16)	
	PrecMin	256	2	3	1	2	7	17	11	10	12	14	4	6	(17)	
	PrecStd	72	9	10	10	8	14	32	33	21	20	12	10	10	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	9.2	13.7	19.9	27.7	30.9	32.2	30.2	24.2	18.6	11.3	10.4	(19)	
		MCWB	4.7	3.6	5.6	9.3	14.4	17.7	18.2	18.2	13.9	10.3	5.1	4.4	(20)	
	2%	DB	6.2	6.2	9.7	16.2	24.8	28.0	29.2	27.8	21.5	14.4	7.6	5.4	(21)	
		MCWB	1.6	1.4	3.2	7.3	12.8	15.8	17.9	17.1	12.4	7.5	2.8	0.7	(22)	
	5%	DB	1.2	1.1	6.7	13.7	22.5	25.4	27.2	25.5	19.4	11.8	3.4	-0.3	(23)	
		MCWB	-1.8	-2.1	1.4	5.9	11.8	15.1	17.1	16.1	11.6	6.1	-0.3	-2.9	(24)	
	10%	DB	-6.7	-5.3	3.1	11.3	20.1	23.3	25.3	23.3	17.2	8.6	-2.2	-6.6	(25)	
		MCWB	-7.5	-6.7	-0.9	4.5	10.7	14.3	16.5	15.2	10.6	4.5	-3.4	-7.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	3.9	6.0	9.7	15.3	18.7	20.4	19.9	15.4	10.9	5.2	4.5	(27)	
		MCDB	9.7	9.1	13.2	18.7	25.3	25.7	27.5	26.4	22.5	17.7	11.0	9.9	(28)	
	2%	WB	1.7	1.5	3.5	7.6	13.7	17.5	19.0	18.1	13.3	8.0	2.9	1.0	(29)	
		MCDB	6.1	6.3	9.1	15.6	23.3	24.3	26.2	25.4	19.2	13.4	7.5	5.3	(30)	
	5%	WB	-1.7	-1.9	1.7	6.1	12.4	16.4	18.1	17.0	12.3	6.4	-0.2	-2.5	(31)	
		MCDB	1.2	0.9	6.3	13.1	20.7	23.2	25.0	23.9	17.6	11.1	3.0	-0.3	(32)	
	10%	WB	-7.5	-6.6	-0.7	4.7	11.2	15.2	17.2	15.8	11.2	4.8	-3.5	-7.3	(33)	
		MCDB	-6.6	-5.5	3.0	10.7	18.9	21.5	23.5	21.8	16.2	8.3	-2.0	-6.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	12.8	15.7	14.1	15.1	13.7	13.7	13.5	12.7	9.4	9.6	9.3	(35)	
		MCDBR	17.9	19.4	18.1	18.5	19.8	18.4	18.0	17.7	17.2	15.4	14.6	17.4	(36)	
		MCWBR	13.9	15.0	12.1	10.2	9.0	7.9	7.9	8.2	9.1	9.0	10.8	13.7	(37)	
	5% WB	MCDBR	17.4	18.6	17.1	17.8	18.6	15.3	16.3	16.6	15.5	14.2	13.9	17.0	(38)	
		MCWBR	13.5	14.4	11.4	10.0	8.7	7.2	7.8	8.4	8.9	8.6	10.3	13.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.207	0.247	0.274	0.343	0.365	0.377	0.392	0.370	0.316	0.285	0.213	0.170	(40)	
	taud		2.119	2.285	2.255	2.166	2.333	2.375	2.359	2.425	2.556	2.448	2.136	1.972	(41)	
	Ebn at Noon		554	762	854	842	856	850	824	815	813	709	528	416	(42)	
	Edh at Noon		36	60	89	120	110	108	108	93	68	53	34	23	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.34	1.18	2.90	4.69	5.47	5.58	5.25	4.22	2.67	1.24	0.44	0.17	(44)	
	RadStd		0.03	0.09	0.17	0.23	0.34	0.45	0.42	0.30	0.28	0.10	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		N/A	+1.84	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page