

JIMMY LAKE, SK, Canada

WMO: 710230

Lat: 54.908N

Lon: 109.962W

Elev: 637

StdP: 93.90

Time Zone: -6.00 (W06)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.9	-29.2	-36.6	0.1	-31.6	-34.1	0.2	-28.9	10.4	0.4	9.1	-2.4	2.1	320	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	26.6	17.2	24.9	16.5	23.4	15.6	18.5	24.2	17.4	22.9	16.6	21.7	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.5	12.6	21.0	15.4	11.8	19.7	14.5	11.1	18.7	55.1	24.0	51.6	23.0	48.9	21.8	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.3	6.4	-35.4	29.7	3.2	1.1	-37.8	30.4	-39.7	31.0	-41.5	31.6	-43.9	32.4		
(5)			-35.2	20.7	2.8	0.9	-37.1	21.3	-38.8	21.9	-40.3	22.4	-42.3	23.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.6	-14.3	-13.3	-6.0	2.1	9.5	14.2	16.9	15.3	10.3	2.9	-6.2	-13.8	(6)
(7)		DBStd	12.88	9.02	7.77	8.03	5.67	4.90	3.33	2.71	3.36	4.42	5.03	6.65	7.81	(7)
(8)		HDD10.0	3718	753	652	498	241	68	6	0	3	49	226	486	737	(8)
(9)		HDD18.3	6156	1011	886	756	486	274	129	60	103	242	478	736	996	(9)
(10)		CDD10.0	636	0	0	0	4	54	132	215	167	58	6	0	0	(10)
(11)		CDD18.3	32	0	0	0	0	1	5	16	9	1	0	0	0	(11)
(12)		CDH23.3	346	0	0	0	1	25	59	146	90	23	1	0	0	(12)
(13)		CDH26.7	39	0	0	0	0	3	7	19	8	2	0	0	0	(13)
(14)	Wind	WSAvg	3.0	2.9	2.9	3.3	3.5	3.4	3.0	2.9	2.8	3.0	3.1	3.0	2.6	(14)
(15)	Precipitation	PrecAvg	428	20	16	17	31	36	69	80	58	43	23	18	22	(15)
(16)		PrecMax	535	37	28	34	76	64	152	116	142	92	46	40	50	(16)
(17)		PrecMin	308	8	6	1	6	6	33	33	21	13	7	5	8	(17)
(18)		PrecStd	59	9	7	9	16	18	29	25	31	23	11	10	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	6.5	11.7	21.2	26.6	27.6	28.5	27.7	26.3	20.4	9.8	4.3	(19)
(20)			MCWB	2.2	1.9	5.0	10.3	14.1	16.1	18.9	18.5	16.8	12.1	4.8	1.1	(20)
(21)		2%	DB	3.6	3.1	8.5	16.8	22.9	25.0	26.7	25.8	23.0	15.5	6.6	1.7	(21)
(22)			MCWB	0.8	-0.4	3.1	7.8	12.3	15.4	18.1	17.5	14.9	9.3	3.2	-0.2	(22)
(23)		5%	DB	1.2	0.5	6.2	13.8	20.7	23.1	24.9	24.0	20.2	12.5	4.1	-0.8	(23)
(24)			MCWB	-0.5	-1.8	1.6	5.9	11.2	14.5	17.1	16.6	13.8	7.3	1.5	-2.2	(24)
(25)		10%	DB	-1.4	-1.9	4.3	11.2	18.6	21.1	23.3	22.3	17.7	10.1	1.9	-3.0	(25)
(26)			MCWB	-2.8	-3.6	0.6	4.7	10.0	13.3	16.3	15.9	12.2	5.9	0.0	-4.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	2.3	5.3	10.5	14.8	17.5	20.5	19.8	17.6	12.4	5.5	1.7	(27)
(28)			MCD B	6.3	6.4	10.7	20.3	24.4	24.2	25.9	25.8	24.5	19.4	8.7	3.4	(28)
(29)		2%	WB	1.1	0.0	3.4	8.1	13.4	16.3	18.9	18.3	15.8	9.8	3.7	-0.2	(29)
(30)			MCD B	3.5	2.5	8.1	16.2	21.0	22.6	24.4	24.0	21.5	14.9	6.4	1.9	(30)
(31)		5%	WB	-0.4	-1.6	2.0	6.3	12.1	15.4	17.8	17.3	14.3	7.9	2.0	-2.1	(31)
(32)			MCD B	1.6	0.8	5.9	13.2	19.1	21.0	23.0	22.8	19.5	11.8	4.2	-0.6	(32)
(33)		10%	WB	-2.4	-3.3	0.6	4.8	10.9	14.5	16.8	16.4	12.8	6.3	0.2	-4.1	(33)
(34)			MCD B	-1.0	-1.5	3.9	10.7	17.1	19.2	21.6	21.3	16.8	9.8	1.8	-3.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	10.1	10.2	10.4	11.6	10.3	10.4	10.3	9.9	8.0	7.2	8.0	(35)
(36)			MCDBR	10.4	11.8	11.8	15.0	14.7	13.4	12.9	13.1	14.1	12.4	9.2	10.7	(36)
(37)			MCWBR	8.4	8.9	7.8	8.8	7.4	6.1	6.1	6.2	7.3	7.2	6.4	8.8	(37)
(38)		5% WB	MCDBR	10.3	12.0	11.4	14.7	13.2	11.2	11.5	12.1	13.6	11.9	9.2	10.5	(38)
(39)			MCWBR	8.3	9.4	7.7	8.7	6.9	5.7	5.9	6.1	7.3	7.3	6.7	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.239	0.268	0.273	0.314	0.333	0.352	0.355	0.350	0.306	0.276	0.244	0.214	(40)	
(41)		taud	2.333	2.307	2.434	2.462	2.452	2.410	2.448	2.421	2.551	2.601	2.466	2.352	(41)	
(42)		Ebn at Noon	738	829	919	917	912	894	884	866	872	832	740	703	(42)	
(43)		Edh at Noon	51	76	85	96	103	109	103	100	76	57	45	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.81	1.84	3.38	4.65	5.60	5.64	5.69	4.68	3.26	1.80	0.81	0.56	(44)	
(45)		RadStd	0.08	0.13	0.23	0.36	0.53	0.42	0.35	0.38	0.36	0.30	0.11	0.05	(45)	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page