

MAPLE PLAINS, PE, Canada

WMO: 710267

Lat: 46.300N

Lon: 63.580W

Elev: 46

StdP: 100.78

Time Zone: -4.00 (NAA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.5	-18.6	-25.1	0.4	-20.5	-22.3	0.5	-17.6	11.8	-1.3	10.5	-3.8	2.8	290	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	27.0	20.6	25.5	19.6	24.1	18.8	21.7	25.4	20.8	24.1	19.9	22.8	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.2	23.9	19.6	14.4	22.8	18.7	13.6	21.8	63.5	25.3	60.3	24.2	57.3	22.9	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.5	7.5	-26.3	29.6	2.7	1.3	-28.3	30.5	-29.9	31.3	-31.4	32.0	-33.4	33.0		
(5)			-26.3	23.3	2.8	0.8	-28.3	23.9	-29.9	24.4	-31.5	24.8	-33.5	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-7.5	-7.4	-3.4	3.1	9.0	14.1	18.6	18.1	14.0	8.5	3.1	-2.9	(6)
(7)		DBStd	10.10	6.17	5.68	4.79	4.01	3.77	3.65	2.79	3.02	3.96	4.16	4.53	5.26	(7)
(8)		HDD10.0	2427	542	488	415	211	66	6	0	0	9	81	211	399	(8)
(9)		HDD18.3	4704	800	721	673	458	289	134	31	42	138	306	456	657	(9)
(10)		CDD10.0	852	0	0	0	3	34	128	267	251	129	33	5	0	(10)
(11)		CDD18.3	89	0	0	0	0	0	6	40	34	8	1	0	0	(11)
(12)		CDH23.3	476	0	0	0	0	6	38	214	188	30	1	0	0	(12)
(13)		CDH26.7	57	0	0	0	0	0	3	27	23	4	0	0	0	(13)
(14)	Wind	WSAvg	3.5	3.9	3.9	4.0	3.8	3.5	3.2	2.9	2.7	3.0	3.4	3.8	4.1	(14)
(15)	Precipitation	PrecAvg	1055	77	69	77	77	80	90	75	87	100	112	98	105	(15)
(16)		PrecMax	1411	128	140	140	141	195	149	142	160	205	204	169	230	(16)
(17)		PrecMin	790	12	8	24	36	24	30	17	21	17	28	39	45	(17)
(18)		PrecStd	146	29	29	30	27	37	30	31	40	51	51	33	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	7.8	10.9	17.6	24.1	26.6	29.3	29.0	26.3	21.6	16.9	11.8	(19)
(20)			MCWB	9.5	7.0	6.8	12.7	15.7	18.8	21.9	21.2	20.6	17.1	14.9	11.0	(20)
(21)		2%	DB	5.7	5.0	7.2	14.5	20.8	24.3	27.1	27.0	23.7	18.7	14.7	8.7	(21)
(22)			MCWB	5.1	4.2	5.4	11.1	14.3	18.1	21.0	20.4	19.0	15.4	13.4	8.0	(22)
(23)		5%	DB	3.3	2.6	4.9	11.9	18.0	22.5	25.7	25.4	21.9	16.9	12.7	6.4	(23)
(24)			MCWB	2.5	1.5	3.2	9.2	12.3	17.0	20.0	19.6	17.9	14.3	11.3	5.7	(24)
(25)		10%	DB	1.0	0.7	3.0	9.7	15.8	20.7	24.2	24.0	20.3	15.3	10.3	4.2	(25)
(26)			MCWB	0.5	-0.2	1.5	6.9	11.5	16.1	19.0	18.8	17.1	13.1	8.9	3.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	7.1	8.2	14.5	17.8	21.2	23.2	22.7	21.7	18.5	15.2	11.1	(27)
(28)			MCDWB	10.4	7.6	9.2	16.2	21.8	25.1	27.5	27.0	24.9	20.5	16.3	11.7	(28)
(29)		2%	WB	5.4	4.4	5.9	11.7	15.4	19.5	22.0	21.6	20.1	16.3	13.5	8.1	(29)
(30)			MCDWB	5.7	5.1	7.1	13.7	18.7	22.6	26.0	25.1	22.4	17.8	14.4	8.7	(30)
(31)		5%	WB	2.8	1.8	3.5	9.7	13.8	18.2	21.0	20.7	18.9	14.8	11.4	5.8	(31)
(32)			MCDWB	3.4	2.4	4.7	11.5	16.6	21.1	24.4	24.0	20.9	16.6	12.3	6.3	(32)
(33)		10%	WB	0.6	0.0	1.5	7.4	12.2	16.7	20.0	19.7	17.8	13.2	9.0	3.5	(33)
(34)			MCDWB	1.1	0.7	2.9	9.5	15.5	20.1	22.9	22.9	19.8	14.9	10.3	4.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	9.1	8.2	8.4	10.1	9.9	10.1	10.4	10.3	8.7	7.1	6.8	(35)
(36)			MCDBR	10.8	10.0	9.9	12.0	14.1	12.5	12.2	12.1	11.0	10.2	9.2	8.9	(36)
(37)			MCWBR	11.1	9.5	8.5	8.7	8.5	7.4	6.9	6.7	7.2	7.7	8.4	9.2	(37)
(38)		5% WB	MCDWB	10.7	10.1	9.8	10.2	11.4	10.2	9.8	10.0	8.9	9.0	9.0	9.1	(38)
(39)			MCWBR	11.0	9.9	9.0	8.7	7.8	6.7	6.1	6.0	6.5	7.5	8.7	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.301	0.289	0.319	0.347	0.366	0.381	0.407	0.391	0.356	0.331	0.309	0.289	(40)	
(41)		taud	2.350	2.335	2.347	2.401	2.408	2.382	2.346	2.383	2.479	2.529	2.518	2.474	(41)	
(42)		Ebn at Noon	791	889	908	911	900	885	855	856	861	835	789	776	(42)	
(43)		Edh at Noon	74	91	105	110	113	117	120	111	93	76	64	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.10	1.81	3.16	4.19	5.08	5.52	5.62	4.96	3.81	2.36	1.23	0.84	(44)	
(45)		RadStd	0.08	0.23	0.29	0.38	0.47	0.42	0.38	0.32	0.33	0.24	0.15	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A

Nomenclature: See separate page