

INGONISH BEACH, NS, Canada

WMO: 710270

Lat: 46.663N

Lon: 60.406W

Elev: 10

StdP: 101.20

Time Zone: -4.00 (NAA)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.9	-13.5	-20.2	0.6	-14.6	-18.1	0.8	-12.4	11.0	-4.7	9.4	-6.4	2.6	260	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	29.0	20.3	27.1	19.8	25.3	19.0	22.1	26.7	21.1	25.2	20.2	23.9	3.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.2	24.4	19.6	14.3	23.5	18.7	13.5	22.6	64.7	26.7	61.2	25.3	58.0	24.0	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.1	6.0	DB	-19.2	32.5	2.9	1.8	-21.3	33.8	-23.0	34.8	-24.7	35.8	-26.8	37.1	(4)
(5)			WB	-19.5	23.7	2.9	0.9	-21.6	24.4	-23.3	24.9	-24.9	25.4	-27.0	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.8	-3.9	-4.7	-1.8	3.0	8.1	13.1	18.8	19.2	15.2	9.5	4.6	-0.4
	DBStd	9.10	4.65	4.77	4.43	3.65	3.76	4.10	3.39	2.88	3.67	3.65	4.13	4.01
	HDD10.0	2066	432	411	367	212	86	12	0	0	3	54	168	322
	HDD18.3	4333	690	644	625	459	318	167	36	23	107	273	411	579
	CDD10.0	898	1	0	0	3	26	105	273	285	159	39	8	0
	CDD18.3	124	0	0	0	0	1	9	51	50	13	1	0	0
	CDH23.3	878	0	0	0	0	16	91	372	315	79	5	0	0
	CDH26.7	199	0	0	0	0	1	21	98	66	13	1	0	0
Wind	WSAvg	2.4	2.6	2.7	2.7	2.5	2.3	2.1	2.1	2.2	2.3	2.4	2.4	2.5
Precipitation	PrecAvg	1694	168	141	138	130	101	103	91	118	136	205	164	203
	PrecMax	1991	321	240	304	221	195	235	202	353	345	332	346	475
	PrecMin	1212	53	66	50	65	42	38	35	46	45	82	91	97
	PrecStd	186	56	49	57	46	46	51	36	62	75	70	55	76
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.5	10.9	13.0	19.2	25.5	29.2	31.6	31.4	28.3	23.5	19.3	14.6
		MCWB	12.1	9.3	9.8	14.5	16.6	19.4	21.8	21.2	20.1	16.9	16.1	12.6
	2%	DB	7.9	7.0	9.7	14.9	21.6	25.9	29.3	28.4	25.5	20.4	16.5	10.5
		MCWB	6.0	4.9	6.8	10.7	14.1	18.3	20.7	20.2	19.2	16.1	14.1	8.9
	5%	DB	4.3	3.3	6.5	11.8	18.0	23.2	27.3	26.6	23.5	17.9	14.0	7.2
		MCWB	2.7	1.5	3.7	7.9	12.1	16.7	20.1	19.8	18.3	14.7	12.2	5.9
	10%	DB	2.1	1.4	4.0	9.0	14.9	20.5	25.2	24.9	21.6	15.7	11.0	5.1
		MCWB	0.9	0.1	1.5	5.7	9.8	15.2	19.2	19.2	17.4	12.6	9.5	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	9.6	10.3	14.8	18.2	21.7	23.7	23.1	21.9	19.1	16.6	12.8
		MCDB	14.5	11.0	12.2	18.7	23.8	27.3	28.8	28.3	25.7	21.1	18.8	14.1
	2%	WB	6.6	5.1	7.1	11.3	15.5	19.7	22.3	21.9	20.5	16.8	14.6	9.1
		MCDB	7.7	6.6	9.7	14.0	19.8	23.9	27.1	26.2	24.0	19.4	16.3	10.5
	5%	WB	2.9	1.8	3.9	8.5	12.6	17.5	21.3	20.9	19.3	15.0	12.1	6.1
		MCDB	4.1	3.0	6.4	11.2	17.3	22.1	25.6	24.7	22.5	17.7	13.8	7.0
	10%	WB	1.0	0.3	1.8	5.9	10.3	15.7	20.2	20.1	18.1	13.1	9.7	4.1
		MCDB	1.9	1.1	3.6	8.4	14.2	19.5	24.2	23.6	20.8	15.2	10.8	5.0
Mean Daily Temperature Range	5% DB	MDBR	7.2	8.3	8.5	8.3	9.1	9.1	9.8	9.7	9.9	8.3	7.1	6.1
		MCDBR	10.1	11.3	12.1	13.5	15.4	13.9	13.0	12.3	12.0	11.7	11.3	9.9
		MCWBR	9.7	10.0	9.5	9.8	9.4	7.7	6.3	6.2	7.1	8.3	9.9	9.4
	5% WB	MCDBR	10.0	10.9	12.0	12.4	14.1	11.9	11.0	10.2	10.7	11.0	10.8	9.7
		MCWBR	9.8	10.1	10.0	10.1	9.4	7.8	6.0	6.0	7.4	8.7	9.9	9.4
Clear-Sky Solar Irradiance	taub	0.306	0.299	0.334	0.363	0.374	0.395	0.424	0.400	0.368	0.350	0.326	0.308	
	taud	2.335	2.349	2.288	2.357	2.412	2.374	2.337	2.411	2.474	2.477	2.460	2.370	
	Ebn at Noon	777	874	888	893	891	871	839	847	846	807	756	730	
	Edh at Noon	75	90	111	115	113	118	121	108	93	80	67	65	
All-Sky Solar Radiation	RadAvg	0.94	1.71	3.00	4.20	5.10	5.47	5.49	4.85	3.70	2.26	1.14	0.71	
	RadStd	0.07	0.23	0.32	0.35	0.42	0.50	0.37	0.32	0.30	0.21	0.14	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	-0.86	-0.60	N/A	N/A	N/A	N/A	-29
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A

Nomenclature: See separate page