

TATLAYOKO LAKE, BC, Canada

WMO: 710280

Lat: 51.6747N

Lon: 124.4031W

Elev: 2876

StdP: 13.23

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.0	-5.4	-17.5	2.3	-10.4	-11.2	3.3	-2.8	21.7	40.1	19.5	39.8	4.1	350	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.5	84.1	58.7	80.2	57.5	76.4	56.1	60.6	78.7	58.9	76.3	57.3	73.5	6.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.6	70.6	63.1	52.4	64.9	60.8	50.4	60.4	59.5	28.0	78.9	26.8	76.3	25.7	73.9	70.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.8	13.9	-22.1	89.9	6.0	3.0	-26.4	92.0	-29.9	93.7	-33.3	95.4	-37.7	97.5		
(5)			-22.1	64.0	5.8	2.7	-26.2	65.9	-29.7	67.4	-32.9	68.9	-37.2	70.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.9	23.1	25.4	32.0	39.2	47.0	53.2	58.3	57.8	50.1	40.5	29.8	21.0		
	DBStd	15.24	12.17	10.26	8.91	5.62	5.76	5.28	5.16	4.99	6.03	6.52	9.89	11.22		
	HDD50	4446	835	690	557	325	129	27	3	4	72	300	606	898		
	HDD65	9185	1300	1110	1022	773	559	354	217	226	447	758	1056	1363		
	CDD50	748	0	0	0	1	34	124	259	247	76	7	0	0		
	CDD65	13	0	0	0	0	0	1	8	4	0	0	0	0		
	CDH74	1327	0	0	0	1	29	163	545	492	96	1	0	0		
	CDH80	346	0	0	0	0	2	35	161	133	15	0	0	0		
	WSAvg	5.3	5.0	4.9	6.3	6.2	5.5	5.3	5.0	4.6	4.8	5.4	5.4	4.8		
	PrecAvg	17.4	1.8	1.1	0.8	0.7	1.0	1.1	1.5	1.2	1.2	2.4	2.3	2.0		
(15) Precipitation	PrecMax	24.5	4.7	3.9	2.3	2.7	2.5	4.7	3.8	3.2	3.4	4.7	10.1	4.7		
	PrecMin	11.4	0.2	0.1	0.0	0.1	0.2	0.0	0.0	0.0	0.0	0.4	0.2	0.3		
	PrecStd	3.5	1.2	0.8	0.6	0.6	0.7	1.0	1.1	0.9	0.8	1.4	2.0	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	51.0	59.5	69.7	77.7	84.9	90.0	88.0	82.1	68.4	54.9	47.2		
		MCWB	40.1	40.3	43.7	50.0	54.2	57.2	61.0	60.5	56.9	52.3	44.2	38.4		
	2%	DB	44.8	45.6	52.0	61.8	72.5	78.5	84.4	84.0	76.6	61.6	48.9	42.1		
		MCWB	38.2	37.3	41.0	45.8	52.6	55.5	59.0	59.2	56.3	48.8	42.4	36.5		
	5%	DB	41.7	42.3	47.8	56.3	67.2	73.7	80.1	79.8	70.8	57.1	45.4	38.9		
		MCWB	36.8	35.8	38.6	43.0	50.4	54.1	57.6	57.8	54.6	46.9	40.1	35.0		
	10%	DB	38.6	39.2	44.6	52.3	62.7	68.6	75.8	75.3	65.3	53.0	42.4	36.3		
		MCWB	35.2	34.1	36.8	40.8	48.4	52.7	56.2	56.2	52.1	44.8	38.3	33.5		
	0.4%	WB	41.5	41.7	45.6	51.2	56.2	60.0	63.8	64.0	60.9	53.7	46.6	40.5		
		MCDB	46.9	47.8	56.5	67.1	72.8	76.5	81.1	79.0	73.5	65.1	51.4	44.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.0	38.7	42.0	47.5	53.3	57.2	60.8	60.3	57.5	50.6	43.0	37.5		
		MCDB	43.3	43.8	50.7	60.5	69.8	73.9	79.9	78.9	73.7	59.3	47.4	40.8		
	5%	WB	37.3	36.3	39.5	44.2	51.3	55.2	59.0	58.7	55.1	48.0	40.8	35.4		
		MCDB	41.1	41.6	46.5	55.0	65.0	70.5	76.7	76.4	68.5	55.3	44.6	38.1		
	10%	WB	35.4	34.3	37.6	41.6	49.4	53.5	57.1	57.2	53.0	45.4	38.7	33.5		
		MCDB	38.6	38.9	43.5	51.0	60.6	66.8	73.3	73.3	64.1	52.1	42.1	36.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.3	21.2	21.1	24.6	27.8	28.0	31.5	32.7	29.4	23.1	16.6	16.1		
		MCDBR	18.2	23.5	25.3	34.0	38.6	40.4	42.1	43.1	41.6	31.0	19.1	17.0		
		MCWBR	12.9	15.9	15.2	19.6	20.3	18.6	18.5	20.1	22.3	19.2	12.6	12.5		
		MCDBR	17.1	21.8	23.4	31.3	32.6	33.3	36.3	38.3	37.3	28.4	17.7	15.7		
	5% WB	MCWBR	12.5	15.1	15.0	18.7	17.8	16.4	18.2	19.0	21.4	19.0	12.3	12.0		
(40) Clear-Sky Solar Irradiance	taub		0.283	0.286	0.310	0.340	0.368	0.369	0.351	0.352	0.314	0.305	0.298	0.275		
	taud		2.248	2.344	2.311	2.291	2.288	2.335	2.432	2.437	2.544	2.515	2.317	2.246		
	Ebn at Noon		228	268	281	285	280	280	284	278	279	259	221	209		
	Edh at Noon		21	26	32	37	39	38	34	32	26	22	20	18		
(44) All-Sky Solar Radiation	RadAvg		268	547	856	1328	1693	1706	1832	1584	1084	614	297	213		
	RadStd		30	65	107	131	138	162	188	94	97	85	44	25		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+121	N/A	

Nomenclature: See separate page