

TATLAYOKO LAKE, BC, Canada

WMO: 710280

Lat: 51.6747N

Lon: 124.4031W

Elev: 877

StdP: 91.23

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-24.4	-20.8	-27.5	0.3	-23.5	-24.0	0.5	-19.4	9.7	4.5	8.7	4.3	1.8	350	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	29.0	14.9	26.8	14.1	24.7	13.4	15.9	25.9	14.9	24.6	14.0	23.1	3.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	10.1	17.3	11.3	9.3	16.0	10.2	8.6	15.3	47.3	26.1	44.5	24.6	41.9	23.3	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.1	6.2	-30.1	32.2	3.3	1.6	-32.5	33.3	-34.4	34.3	-36.3	35.2	-38.7	36.4		
(5)			-30.0	17.8	3.2	1.5	-32.4	18.8	-34.3	19.7	-36.1	20.5	-38.4	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	-5.0	-3.7	0.0	4.0	8.3	11.8	14.6	14.4	10.1	4.7	-1.2	-6.1	(6)
(7)		DBStd	8.47	6.76	5.70	4.95	3.12	3.20	2.93	2.86	2.77	3.35	3.62	5.49	6.23	(7)
(8)		HDD10.0	2470	464	383	309	181	72	15	2	2	40	167	337	499	(8)
(9)		HDD18.3	5103	722	617	568	429	311	197	121	126	248	421	587	757	(9)
(10)		CDD10.0	416	0	0	0	1	19	69	144	137	42	4	0	0	(10)
(11)		CDD18.3	7	0	0	0	0	0	1	4	2	0	0	0	0	(11)
(12)		CDH23.3	737	0	0	0	1	16	91	303	273	53	1	0	0	(12)
(13)		CDH26.7	192	0	0	0	0	1	19	89	74	8	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.3	2.2	2.8	2.8	2.4	2.4	2.2	2.1	2.1	2.4	2.4	2.2	(14)
(15)	Precipitation	PrecAvg	443	45	29	21	19	26	28	37	31	30	60	58	51	(15)
(16)		PrecMax	622	120	98	59	68	64	120	97	82	86	120	257	119	(16)
(17)		PrecMin	290	4	2	1	2	4	0	0	0	0	10	5	8	(17)
(18)		PrecStd	89	31	20	15	14	18	26	27	22	20	35	51	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	10.5	15.3	21.0	25.4	29.4	32.2	31.1	27.8	20.2	12.7	8.4	(19)
(20)			MCWB	4.5	4.6	6.5	10.0	12.3	14.0	16.1	15.8	13.8	11.3	6.8	3.6	(20)
(21)		2%	DB	7.1	7.6	11.1	16.6	22.5	25.9	29.1	28.9	24.8	16.5	9.4	5.6	(21)
(22)			MCWB	3.4	2.9	5.0	7.7	11.4	13.1	15.0	15.1	13.5	9.3	5.8	2.5	(22)
(23)		5%	DB	5.4	5.7	8.8	13.5	19.6	23.2	26.7	26.5	21.6	13.9	7.4	3.8	(23)
(24)			MCWB	2.7	2.1	3.7	6.1	10.2	12.3	14.2	14.3	12.5	8.3	4.5	1.6	(24)
(25)		10%	DB	3.7	4.0	7.0	11.3	17.0	20.3	24.3	24.1	18.5	11.7	5.8	2.4	(25)
(26)			MCWB	1.8	1.2	2.7	4.9	9.1	11.5	13.5	13.5	11.2	7.1	3.5	0.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	5.4	7.6	10.7	13.5	15.6	17.7	17.8	16.0	12.0	8.1	4.7	(27)
(28)			MCDWB	8.3	8.8	13.6	19.5	22.7	24.7	27.3	26.1	23.0	18.4	10.8	7.2	(28)
(29)		2%	WB	3.9	3.7	5.5	8.6	11.8	14.0	16.0	15.7	14.2	10.3	6.1	3.1	(29)
(30)			MCDWB	6.3	6.5	10.4	15.8	21.0	23.3	26.6	26.1	23.2	15.1	8.6	4.9	(30)
(31)		5%	WB	3.0	2.4	4.2	6.8	10.7	12.9	15.0	14.8	12.8	8.9	4.9	1.9	(31)
(32)			MCDWB	5.1	5.3	8.1	12.8	18.3	21.4	24.8	24.7	20.3	13.0	7.0	3.4	(32)
(33)		10%	WB	1.9	1.3	3.1	5.3	9.7	12.0	14.0	14.0	11.7	7.5	3.7	0.8	(33)
(34)			MCDWB	3.7	3.8	6.4	10.6	15.9	19.3	23.0	22.9	17.8	11.2	5.6	2.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	11.8	11.7	13.6	15.4	15.6	17.5	18.2	16.3	12.8	9.2	8.9	(35)
(36)			MCDBR	10.1	13.0	14.1	18.9	21.5	22.4	23.4	23.9	23.1	17.2	10.6	9.5	(36)
(37)			MCWBR	7.2	8.9	8.5	10.9	11.3	10.3	10.3	11.2	12.4	10.7	7.0	7.0	(37)
(38)		5% WB	MCDWB	9.5	12.1	13.0	17.4	18.1	18.5	20.2	21.3	20.7	15.8	9.8	8.7	(38)
(39)			MCWBR	7.0	8.4	8.3	10.4	9.9	9.1	10.1	10.5	11.9	10.5	6.8	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.286	0.310	0.340	0.368	0.369	0.351	0.352	0.314	0.305	0.298	0.275	(40)	
(41)		taud	2.248	2.344	2.311	2.291	2.288	2.335	2.432	2.437	2.544	2.515	2.317	2.246	(41)	
(42)		Ebn at Noon	719	844	887	897	884	884	896	877	881	818	697	660	(42)	
(43)		Edh at Noon	67	81	101	117	124	120	107	101	81	68	62	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.84	1.72	2.70	4.19	5.34	5.38	5.78	4.99	3.42	1.94	0.94	0.67	(44)	
(45)		RadStd	0.09	0.21	0.34	0.41	0.43	0.51	0.59	0.29	0.31	0.27	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+67	N/A

Nomenclature: See separate page