

HOLMAN, NT, CanadaWMO: **710290**Lat: **70.7614N**Lon: **117.8000W**Elev: **98**StdP: **14.64**Time Zone: **-7.00 (NAM)**Period: **00-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.2	-34.6	-44.6	0.4	-37.1	-41.7	0.5	-34.4	35.9	-4.7	31.5	-7.7	6.2	40	1.061

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	65.8	55.2	61.9	53.5	58.2	51.2	56.1	64.3	53.8	61.2	51.6	57.7	14.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
51.4	56.5	59.5	49.1	51.8	57.4	47.0	47.9	55.1	23.9	64.7	22.5	61.4	21.2	57.8	63.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
34.4	29.1	25.2	DB	-40.6	70.2	4.9	5.1	-44.2	73.9	-47.1	76.9	-49.8	79.8	-53.4	83.5	
			WB	-41.0	58.8	4.9	2.9	-44.5	60.8	-47.4	62.5	-50.1	64.1	-53.6	66.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.8	-15.6	-17.6	-14.5	1.4	21.1	40.2	48.3	44.8	34.5	18.8	0.4	-10.8		
	DBStd	25.62	9.77	10.08	11.44	10.07	9.87	7.06	7.61	6.75	6.59	8.25	8.76	9.50		
	HDD50	13714	2033	1893	2000	1459	895	306	127	193	467	967	1488	1886		
	HDD65	19072	2498	2313	2465	1909	1360	744	519	627	916	1432	1938	2351		
	CDD50	117	0	0	0	0	0	12	73	31	1	0	0	0		
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	11.0	10.7	9.3	9.2	10.4	11.1	10.9	9.8	10.4	12.2	13.6	13.0	11.1		
	PrecAvg	6.8	0.4	0.3	0.3	0.2	0.3	0.4	0.9	1.3	0.9	0.7	0.5	0.4		
	PrecMax	10.7	1.1	1.6	0.9	0.7	0.8	1.2	2.8	3.9	2.2	1.8	1.3	1.7		
(15) Precipitation	PrecMin	4.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.2	0.0	0.0		
	PrecStd	1.9	0.4	0.4	0.2	0.2	0.2	0.3	0.6	0.7	0.6	0.4	0.4	0.4		
	DB	13.7	11.7	19.1	35.0	44.9	65.3	71.6	69.2	53.6	37.1	25.7	17.2			
	MCWB	13.1	10.8	18.0	31.5	39.4	54.6	57.5	57.4	48.9	35.6	24.8	16.4			
	2% DB	7.0	7.3	12.9	25.6	40.1	59.6	67.6	63.6	48.9	34.3	21.6	11.5			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	6.3	6.6	11.8	23.9	36.3	51.2	55.9	55.1	45.4	33.2	20.5	10.7			
	5% DB	2.5	1.6	6.8	20.0	36.8	55.5	64.1	58.8	46.3	32.1	16.9	6.8			
	MCWB	1.8	1.0	5.9	18.5	34.0	48.9	54.2	52.5	43.4	30.9	16.1	6.1			
	10% DB	-2.0	-2.9	1.9	15.8	34.1	51.5	60.7	54.8	43.8	30.1	12.6	3.0			
	MCWB	-2.7	-3.5	1.2	14.5	31.9	45.9	52.5	49.9	41.6	28.9	11.7	2.3			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	13.2	11.1	18.4	31.7	39.9	55.1	58.9	58.8	49.6	35.9	24.9	16.6			
	MCDB	13.8	11.7	19.2	34.8	44.4	63.9	67.7	66.9	53.3	36.8	25.7	17.1			
	2% WB	6.2	6.5	11.9	23.9	36.7	51.7	56.8	55.3	45.8	33.5	20.5	10.9			
	MCDB	6.8	7.2	12.9	25.6	39.9	58.6	65.7	62.3	48.3	34.2	21.6	11.5			
	5% WB	1.9	1.0	6.1	18.5	34.1	48.9	55.0	52.8	43.6	31.0	16.1	6.1			
(33) Mean Daily Temperature Range	MCDB	2.5	1.6	6.8	19.9	36.4	55.1	63.3	58.8	46.0	31.9	16.8	6.6			
	10% WB	-2.6	-3.4	1.3	14.6	32.0	46.0	52.9	50.3	41.7	28.9	11.8	2.3			
	MCDB	-2.0	-2.9	1.9	15.8	34.0	51.3	60.1	54.4	43.8	30.0	12.5	2.9			
	5% DB	13.5	14.5	13.1	13.5	10.5	16.1	15.6	13.4	9.6	6.3	13.2	13.9			
	MCWBR	13.2	14.3	12.7	12.2	7.8	10.6	8.7	7.8	7.0	6.3	13.1	13.9			
(40) Clear-Sky Solar Irradiance	5% WB	13.5	14.4	13.3	12.6	9.5	15.8	16.0	13.0	9.3	6.5	13.3	14.1			
	MCWBR	13.2	14.2	12.9	11.6	7.1	10.9	10.1	7.9	7.1	6.6	13.3	14.0			
	taub	N/A	0.193	0.241	0.315	0.332	0.324	0.343	0.331	0.294	0.211	N/A	N/A			
	taud	N/A	1.995	2.170	2.005	2.078	2.317	2.411	2.489	2.488	2.119	N/A	N/A			
	Ebn at Noon	0	165	244	251	264	273	263	253	230	153	0	0			
(44) All-Sky Solar Radiation	Edh at Noon	0	11	22	38	40	33	29	24	17	10	0	0			
	RadAvg	0	104	591	1405	1986	2095	1743	1045	460	121	0	0			
	RadStd	0	10	32	71	137	125	121	102	48	15	0	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page