

HOLMAN, NT, CanadaWMO: **710290**Lat: **70.7614N**Lon: **117.8000W**Elev: **30**StdP: **100.97**Time Zone: **-7.00 (NAM)**Period: **00-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-38.5	-37.0	-42.5	0.1	-38.4	-40.9	0.1	-36.9	16.0	-20.4	14.1	-22.1	2.8	40	1.061

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	18.8	12.9	16.6	11.9	14.5	10.7	13.4	18.0	12.1	16.2	10.9	14.3	6.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
10.8	8.1	15.3	9.5	7.4	14.1	8.4	6.8	12.8	37.7	18.2	34.5	16.3	31.4	14.3	17.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.0	11.3	DB	-40.3	21.2	2.7	2.8	-42.3	23.3	-43.9	25.0	-45.5	26.6	-47.5	28.6	(4)
(5)			WB	-40.6	14.9	2.7	1.6	-42.5	16.0	-44.1	17.0	-45.6	17.9	-47.6	19.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.7	-26.4	-27.6	-25.8	-17.0	-6.0	4.6	9.0	7.1	1.4	-7.3	-17.6	-23.8	(6)
(7)		DBStd	14.23	5.43	5.60	6.36	5.59	5.48	3.92	4.23	3.75	3.66	4.58	4.87	5.28	(7)
(8)		HDD10.0	7619	1129	1052	1111	811	497	170	71	107	259	537	827	1048	(8)
(9)		HDD18.3	10596	1388	1285	1369	1061	756	413	288	348	509	796	1077	1306	(9)
(10)		CDD10.0	65	0	0	0	0	0	7	41	17	1	0	0	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH23.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.9	4.8	4.2	4.1	4.6	5.0	4.9	4.4	4.7	5.5	6.1	5.8	5.0	(14)
(15)	Precipitation	PrecAvg	172	10	7	8	6	7	10	22	33	22	19	13	10	(15)
(16)		PrecMax	271	29	41	22	17	20	30	70	98	55	45	33	42	(16)
(17)		PrecMin	101	0	0	1	0	1	1	3	2	5	4	0	1	(17)
(18)		PrecStd	49	9	9	5	5	6	7	16	19	14	11	9	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.1	-11.3	-7.1	1.7	7.2	18.5	22.0	20.7	12.0	2.8	-3.5	-8.2	(19)
(20)			MCWB	-10.5	-11.8	-7.8	-0.3	4.1	12.6	14.2	14.1	9.4	2.0	-4.0	-8.7	(20)
(21)		2%	DB	-13.9	-13.7	-10.6	-3.6	4.5	15.4	19.8	17.6	9.4	1.3	-5.8	-11.4	(21)
(22)			MCWB	-14.3	-14.1	-11.2	-4.5	2.4	10.7	13.3	12.8	7.4	0.6	-6.4	-11.8	(22)
(23)		5%	DB	-16.4	-16.9	-14.0	-6.7	2.7	13.1	17.9	14.9	8.0	0.1	-8.4	-14.0	(23)
(24)			MCWB	-16.8	-17.2	-14.5	-7.5	1.1	9.4	12.3	11.4	6.3	-0.6	-8.8	-14.4	(24)
(25)		10%	DB	-18.9	-19.4	-16.7	-9.0	1.2	10.8	15.9	12.7	6.6	-1.1	-10.8	-16.1	(25)
(26)			MCWB	-19.3	-19.7	-17.1	-9.7	-0.1	7.7	11.4	9.9	5.4	-1.7	-11.3	-16.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.4	-11.6	-7.6	-0.2	4.4	12.8	15.0	14.9	9.8	2.2	-3.9	-8.5	(27)
(28)			MCDWB	-10.1	-11.3	-7.1	1.6	6.9	17.7	19.8	19.4	11.8	2.6	-3.5	-8.3	(28)
(29)		2%	WB	-14.3	-14.2	-11.1	-4.5	2.6	10.9	13.8	12.9	7.7	0.8	-6.4	-11.7	(29)
(30)			MCDWB	-14.0	-13.8	-10.6	-3.6	4.4	14.8	18.7	16.8	9.0	1.2	-5.8	-11.4	(30)
(31)		5%	WB	-16.7	-17.2	-14.4	-7.5	1.2	9.4	12.8	11.6	6.5	-0.5	-8.8	-14.4	(31)
(32)			MCDWB	-16.4	-16.9	-14.0	-6.7	2.5	12.8	17.4	14.9	7.8	-0.1	-8.4	-14.1	(32)
(33)		10%	WB	-19.2	-19.6	-17.1	-9.7	0.0	7.8	11.6	10.2	5.4	-1.7	-11.2	-16.5	(33)
(34)			MCDWB	-18.9	-19.4	-16.7	-9.0	1.1	10.7	15.6	12.4	6.5	-1.1	-10.8	-16.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	6.4	7.0	7.5	5.7	5.5	6.7	5.0	3.8	4.6	5.8	5.9	(35)
(36)			MCDBR	7.5	8.0	7.3	7.5	5.8	8.9	8.7	7.4	5.3	3.5	7.3	7.7	(36)
(37)			MCWBR	7.3	7.9	7.0	6.8	4.4	5.9	4.8	4.3	3.9	3.5	7.3	7.7	(37)
(38)		5% WB	MCDBR	7.5	8.0	7.4	7.0	5.3	8.8	8.9	7.2	5.1	3.6	7.4	7.8	(38)
(39)			MCWBR	7.3	7.9	7.2	6.4	4.0	6.0	5.6	4.4	3.9	3.7	7.4	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.193	0.241	0.315	0.332	0.324	0.343	0.331	0.294	0.211	N/A	N/A	(40)	
(41)		taud	N/A	1.995	2.170	2.005	2.078	2.317	2.411	2.489	2.488	2.119	N/A	N/A	(41)	
(42)		Ebn at Noon	0	519	769	792	832	862	830	798	724	482	0	0	(42)	
(43)		Edh at Noon	0	36	70	119	126	103	92	75	55	31	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.33	1.86	4.43	6.26	6.61	5.50	3.29	1.45	0.38	0.00	0.00	(44)	
(45)		RadStd	0.00	0.03	0.10	0.22	0.43	0.40	0.38	0.32	0.15	0.05	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page