

PRINCETON, BC, Canada

WMO: 710320

Lat: 49.4683N

Lon: 120.5143W

Elev: 698

StdP: 93.22

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-22.1	-17.8	-25.0	0.4	-21.3	-20.8	0.6	-17.3	5.3	-1.9	4.2	-2.7	0.4	0	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	33.0	16.9	30.9	16.3	28.7	15.6	18.0	29.9	17.0	28.3	16.1	27.0	3.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.9	19.0	12.8	10.0	18.8	11.7	9.3	18.7	53.4	30.1	50.2	28.5	47.4	27.1	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.0	5.7	4.8	-26.9	36.4	4.5	1.7	-30.1	37.6	-32.7	38.6	-35.2	39.5	-38.5	40.8
			-27.2	20.3	4.7	1.7	-30.6	21.5	-33.3	22.5	-35.9	23.4	-39.3	24.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-5.2	-3.0	2.1	6.6	11.4	14.7	18.6	18.1	13.5	6.4	-0.3	-5.4		
	DBStd	9.41	5.91	4.82	3.99	3.13	3.62	3.34	3.27	3.25	3.52	3.50	4.74	5.31		
	HDD10.0	2136	472	364	244	109	27	2	0	0	8	121	310	479		
	HDD18.3	4414	730	597	502	351	216	119	37	44	149	370	560	737		
	CDD10.0	860	0	0	0	8	70	142	266	252	113	9	0	0		
	CDD18.3	97	0	0	0	0	1	9	45	38	4	0	0	0		
	CDH23.3	2282	0	0	0	9	106	264	907	797	197	3	0	0		
	CDH26.7	923	0	0	0	1	28	94	398	339	62	0	0	0		
(14) Wind	WSAvg	1.2	0.5	0.7	1.2	1.7	1.7	1.8	1.8	1.5	1.2	0.9	0.7	0.5		
(15) Precipitation	PrecAvg	629	89	53	45	35	42	44	26	30	34	53	83	86		
	PrecMax	893	120	93	92	58	88	70	85	64	80	142	191	165		
	PrecMin	512	59	26	19	21	16	21	0	7	12	15	29	50		
	PrecStd	92	17	19	17	10	20	17	19	18	19	29	50	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	8.2	17.6	24.5	30.1	32.9	35.9	35.5	31.6	22.1	11.7	5.3		
		MCWB	3.1	4.1	8.6	12.3	15.3	17.0	18.0	17.3	15.8	12.8	7.5	2.6		
	2%	DB	3.2	5.9	13.2	20.1	26.3	29.5	33.3	32.7	28.4	17.6	8.6	2.8		
		MCWB	1.8	2.6	6.6	10.3	13.6	15.6	17.3	16.6	14.7	10.5	5.9	1.3		
	5%	DB	1.8	4.2	10.6	17.1	23.3	26.3	31.1	30.5	25.5	14.8	6.8	1.4		
		MCWB	0.9	1.7	5.3	8.7	12.7	14.4	16.6	16.1	14.2	9.0	4.8	0.5		
	10%	DB	0.7	2.8	8.5	14.1	20.3	23.3	28.7	28.0	22.2	12.5	5.2	0.4		
		MCWB	0.1	1.0	4.1	7.3	11.4	13.4	15.9	15.5	13.0	7.9	3.7	-0.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	4.7	9.2	13.0	16.1	18.2	19.8	18.9	17.2	13.3	8.1	3.2		
		MCDB	5.2	7.7	16.2	23.0	28.4	29.5	32.3	32.3	27.1	20.0	10.2	4.6		
	2%	WB	2.0	3.1	7.2	11.0	14.3	16.3	18.3	17.7	15.7	11.4	6.5	1.7		
		MCDB	2.8	5.1	12.5	19.5	24.1	27.2	30.2	29.7	25.8	16.5	8.2	2.5		
	5%	WB	1.1	2.1	5.7	9.3	13.1	15.1	17.3	16.7	14.7	9.7	5.2	0.7		
		MCDB	1.6	3.8	10.0	16.1	22.0	24.7	28.7	28.1	24.2	13.6	6.5	1.3		
	10%	WB	0.2	1.2	4.5	7.8	12.0	13.9	16.3	15.8	13.5	8.4	3.9	-0.1		
		MCDB	0.7	2.6	8.2	13.7	19.4	22.3	27.1	26.9	21.5	11.9	5.1	0.4		
(35) Mean Daily Temperature Range	MDBR		6.5	9.3	11.6	13.8	14.9	14.4	17.1	17.7	16.1	12.0	7.3	6.2		
	5% DB	MCDBR	6.5	10.0	14.8	19.8	21.1	20.9	22.1	22.7	22.8	16.0	9.0	6.3		
		MCWBR	5.1	7.2	8.9	10.9	9.9	9.2	9.0	9.3	10.9	9.4	6.1	5.1		
	5% WB	MCDBR	5.9	8.9	14.1	18.3	18.6	18.4	19.9	20.4	20.6	14.3	7.9	6.1		
		MCWBR	4.8	6.5	8.7	10.4	9.0	8.7	8.7	8.7	10.1	8.6	5.7	4.9		
(40) Clear-Sky Solar Irradiance	taub		0.279	0.277	0.295	0.328	0.356	0.338	0.331	0.335	0.320	0.318	0.293	0.271		
	taud		2.406	2.456	2.480	2.409	2.384	2.473	2.514	2.512	2.533	2.519	2.495	2.441		
	Ebn at Noon		783	886	925	921	902	921	922	903	886	823	766	746		
	Edh at Noon		63	76	89	106	114	105	100	95	84	72	58	53		
(44) All-Sky Solar Radiation	RadAvg		1.06	1.93	3.03	4.54	5.33	5.59	6.45	5.50	3.81	2.20	1.09	0.82		
	RadStd		0.13	0.18	0.30	0.30	0.46	0.58	0.58	0.39	0.34	0.24	0.11	0.10		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page