

CAPE SCOTT, BC, Canada

WMO: 710328

Lat: 50.7823N

Lon: 128.4270W

Elev: 235

StdP: 14.57

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	32.1	18.8	14.3	32.4	23.2	17.6	34.6	45.9	47.6	40.2	47.6	10.6	50	0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	62.5	58.7	61.2	57.9	60.2	57.4	59.7	61.3	58.9	60.4	58.1	59.7	8.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.9	75.0	60.1	58.1	72.7	59.5	57.2	70.4	59.0	26.2	61.7	25.7	60.5	25.2	59.8	63.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.8	30.5	25.9	DB	27.6	66.7	4.1	3.0	24.6	68.9	22.2	70.6	19.9	72.3	16.9	74.5	(4)
(5)			WB	24.6	61.0	3.7	1.1	21.9	61.8	19.8	62.4	17.7	63.0	15.0	63.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	41.9	42.5	43.3	46.0	49.4	52.9	56.0	57.2	55.0	50.1	45.6	42.2		
	DBStd	6.43	4.63	4.11	3.25	2.93	2.78	2.14	1.95	1.86	2.67	3.23	4.18	4.79		
	HDD50	1264	251	214	209	124	44	3	0	0	1	37	138	243		
	HDD65	6008	716	631	673	570	485	363	278	242	299	461	582	708		
	CDD50	731	0	2	1	4	24	91	187	223	152	41	6	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	10.0	12.2	11.1	9.2	9.7	8.9	7.3	7.6	7.9	8.4	11.0	12.9	13.1		
(15) Precipitation	PrecAvg	110.1	12.8	9.8	10.7	7.8	5.5	4.4	3.3	4.9	7.0	13.4	15.9	15.2		
	PrecMax	134.7	20.4	20.6	18.5	14.6	8.0	7.2	8.3	10.7	13.7	20.8	23.3	26.9		
	PrecMin	85.2	6.3	3.8	4.9	3.3	2.1	2.4	0.9	1.2	1.9	6.1	10.0	8.2		
	PrecStd	11.1	3.0	3.2	2.8	2.2	1.4	1.2	1.7	2.4	2.8	4.3	3.8	3.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	55.5	54.1	57.3	59.5	60.9	63.2	64.4	65.4	59.8	55.8	52.0		
		MCWB	46.5	50.9	46.6	49.5	55.2	56.4	59.3	60.2	58.0	54.4	51.5	49.0		
	2%	DB	49.8	51.7	50.6	53.1	56.3	59.1	61.7	62.7	61.8	57.6	53.8	50.1		
		MCWB	47.4	48.3	46.8	48.9	53.1	55.5	58.2	59.2	57.6	53.8	51.3	48.5		
	5%	DB	48.6	49.4	49.0	51.3	54.8	57.6	60.5	61.4	60.2	56.1	52.1	49.0		
		MCWB	46.6	46.4	46.4	47.9	52.0	54.1	57.4	58.6	57.2	53.2	49.6	47.3		
	10%	DB	47.5	47.9	47.7	50.1	53.6	56.4	59.5	60.4	59.0	54.7	50.9	47.8		
		MCWB	45.8	45.6	45.3	47.2	50.9	53.3	56.8	58.0	56.7	52.4	48.5	46.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	52.0	49.4	52.0	56.1	57.5	60.1	61.2	60.1	57.5	53.9	50.1		
		MCDB	50.4	54.0	51.2	54.2	57.9	59.8	62.1	62.6	62.5	58.4	54.4	50.4		
	2%	WB	48.5	49.3	48.1	50.1	54.0	56.1	58.7	60.1	59.1	55.7	52.0	49.0		
		MCDB	49.0	50.8	49.6	51.9	55.6	58.2	60.6	61.5	60.9	56.8	52.8	49.7		
	5%	WB	47.2	47.6	47.1	48.9	52.6	54.9	58.0	59.2	58.1	54.0	50.4	47.6		
		MCDB	47.9	48.8	48.4	50.7	54.4	56.7	59.9	60.6	59.7	55.0	51.5	48.7		
	10%	WB	46.0	46.0	46.0	47.7	51.3	53.9	57.1	58.4	57.0	52.7	49.0	46.4		
		MCDB	47.1	47.4	47.3	49.6	53.2	55.6	59.1	59.9	58.5	54.0	50.5	47.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.5	6.0	6.3	6.1	5.7	5.6	5.2	5.6	5.3	5.0	5.2		
		MCDBR	5.9	6.9	7.3	7.9	7.5	7.2	7.0	6.3	7.5	6.5	6.5	5.9		
	5% WB	MCWBR	5.4	5.4	5.7	5.6	5.6	5.1	4.6	4.2	5.2	5.3	6.0	5.8		
		MCWBR	5.4	6.2	5.9	6.9	7.1	6.6	6.5	5.8	6.5	5.9	6.1	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.318	0.324	0.348	0.377	0.378	0.368	0.360	0.364	0.359	0.345	0.326	0.313		
	taud		2.449	2.503	2.442	2.355	2.394	2.461	2.529	2.523	2.515	2.491	2.418	2.391		
	Ebn at Noon		226	259	271	274	279	282	283	276	265	246	219	206		
	Edh at Noon		19	23	29	36	36	34	31	30	27	23	19	17		
(44) All-Sky Solar Radiation	RadAvg		228	502	822	1283	1584	1690	1644	1432	1046	581	284	189		
	RadStd		27	76	102	82	135	163	166	142	87	69	38	25		

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page