

POINT ATKINSON, BC, Canada

WMO: 710370

Lat: 49.3304N

Lon: 123.2646W

Elev: 46

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	28.7	31.5	9.1	8.8	36.2	15.6	12.1	34.6	37.5	48.3	34.7	48.2	4.6	80	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	75.8	63.7	73.6	63.7	71.6	63.1	65.5	72.1	64.4	70.6	63.4	69.4	5.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.6	84.9	70.0	61.5	81.8	68.9	60.5	78.8	67.9	30.4	72.7	29.6	71.0	28.8	69.6	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.0	25.5	21.8	DB	26.0	83.3	4.9	4.6	22.5	86.6	19.6	89.3	16.9	91.9	13.3	95.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.3	43.1	43.7	46.4	50.9	57.1	61.5	66.3	66.6	61.1	53.1	46.9	42.4	(6)	
	DBStd	9.79	5.43	4.78	4.39	4.49	4.69	4.48	4.03	3.56	3.91	4.01	5.28	5.41	(7)	
	HDD50	942	221	178	126	41	3	0	0	0	0	16	117	240	(8)	
	HDD65	4438	680	595	577	424	247	124	30	23	128	368	542	700	(9)	
	CDD50	2150	6	3	14	66	224	344	505	514	333	113	24	4	(10)	
	CDD65	174	0	0	0	0	3	19	70	72	10	0	0	0	(11)	
	CDH74	181	0	0	0	0	4	26	98	49	4	0	0	0	(12)	
	CDH80	18	0	0	0	0	1	3	12	2	0	0	0	0	(13)	
(14) Wind	WSAvg	7.8	8.2	7.5	9.0	8.3	7.5	7.9	7.4	7.0	6.8	7.5	8.6	8.3	(14)	
(15) Precipitation	PrecAvg	76.1	10.9	7.1	6.9	5.0	3.7	3.0	2.1	2.4	3.2	8.6	11.4	11.2	(15)	
	PrecMax	91.1	17.9	13.7	12.5	9.9	5.4	5.1	3.9	10.7	7.3	14.7	19.7	13.9	(16)	
	PrecMin	63.2	6.5	1.7	2.7	1.7	1.3	1.2	0.4	0.6	1.0	2.8	6.1	7.6	(17)	
	PrecStd	7.7	2.7	2.7	1.9	2.1	1.1	1.2	0.9	2.5	1.7	3.0	3.6	1.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.0	55.4	58.4	66.3	72.7	77.2	81.0	78.1	73.8	64.5	60.0	56.6	(19)	
		MCWB	51.1	49.1	50.6	55.0	57.6	63.4	62.2	64.2	63.2	57.1	54.2	48.2	(20)	
	2%	DB	54.0	52.8	55.5	61.9	68.1	72.6	76.4	75.1	70.3	61.8	57.4	53.2	(21)	
		MCWB	50.7	49.3	49.2	52.4	57.1	62.5	64.4	63.6	61.8	58.1	53.5	48.3	(22)	
	5%	DB	51.9	51.1	53.8	59.2	65.3	69.5	73.7	73.2	68.1	60.0	55.4	51.0	(23)	
		MCWB	48.6	47.6	48.3	52.2	57.2	61.3	64.1	64.0	61.0	56.5	52.2	47.4	(24)	
	10%	DB	49.9	49.5	52.2	56.9	63.3	67.2	71.6	71.5	66.2	58.4	53.6	49.1	(25)	
		MCWB	46.9	46.2	47.5	50.8	56.6	60.1	63.5	63.2	60.2	54.9	50.9	46.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	50.4	52.5	55.7	61.2	65.7	67.0	67.1	65.5	59.4	55.4	50.2	(27)	
		MCDB	52.6	52.3	55.4	61.4	66.3	73.4	73.5	73.9	72.6	61.4	57.8	53.7	(28)	
	2%	WB	48.2	48.6	49.9	53.7	59.4	63.7	65.6	65.4	63.1	58.1	52.9	47.7	(29)	
		MCDB	49.8	50.4	53.2	58.8	64.6	70.2	72.1	71.7	68.9	60.1	55.5	50.1	(30)	
	5%	WB	46.8	46.8	48.4	51.9	58.2	61.8	64.4	64.4	61.7	56.0	51.2	46.3	(31)	
		MCDB	48.6	48.6	51.8	57.3	63.3	68.4	70.9	70.1	66.6	58.0	53.7	48.3	(32)	
	10%	WB	45.3	45.6	47.1	50.3	57.0	60.4	63.2	63.5	59.7	53.7	49.8	45.0	(33)	
		MCDB	47.3	47.5	50.3	54.4	62.1	66.7	69.5	69.2	63.9	56.3	52.0	47.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.5	7.2	8.5	8.5	8.2	8.6	8.0	7.3	6.4	6.3	5.8	(35)	
		MCDBR	7.4	7.7	8.8	11.6	11.3	11.2	11.2	9.9	9.6	7.7	7.4	7.4	(36)	
	5% WB	MCWBR	5.7	6.0	6.8	7.2	6.7	6.5	6.2	5.6	5.6	5.7	6.3	6.7	(37)	
		MCWBR	7.6	7.5	9.4	10.4	10.0	10.4	10.3	8.9	8.9	7.3	8.1	7.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.318	0.311	0.331	0.363	0.384	0.364	0.360	0.363	0.346	0.336	0.321	0.305	(40)	
		taud	2.412	2.480	2.445	2.382	2.365	2.444	2.480	2.487	2.538	2.542	2.496	2.439	(41)	
	Ebn at Noon		232	268	280	281	278	284	284	278	272	255	232	221	(42)	
		Edh at Noon	21	24	30	35	37	35	33	31	27	23	19	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		268	539	802	1254	1649	1763	1980	1682	1159	636	314	213	(44)	
	RadStd		46	84	114	139	146	219	181	136	106	91	61	34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	-3.76	N/A	N/A	N/A	N/A	+293	N/A	N/A	-67
Regional (63 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page