

DELTA BURNS BOG, BC, Canada

WMO: 710420

Lat: 49.1260N

Lon: 123.0025W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 17.8	(c) 21.3	(d) 8.4	(e) 8.4	(f) 28.5	(g) 13.4	(h) 10.9	(i) 25.2	(j) 9.8	(k) 44.0	(l) 8.7	(m) 43.5	(n) 0.8	(o) 0	(p) 0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 22.9	(c) 82.9	(d) 66.7	(e) 79.9	(f) 65.5	(g) 76.9	(h) 64.2	(i) 68.0	(j) 80.2	(k) 66.5	(l) 77.7	(m) 65.1	(n) 75.2	(o) 2.3	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 63.3	(b) 87.2	(c) 72.4	(d) 62.0	(e) 83.0	(f) 71.1	(g) 60.7	(h) 79.3	(i) 69.6	(j) 32.2	(k) 80.2	(l) 31.1	(m) 77.8	(n) 30.0	(o) 75.6	(p) 72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.8	(b) 6.7	(c) 5.4	(e) 12.5	(f) 88.4	(g) 2.3	(h) 3.1	(i) 10.8	(j) 90.6	(k) 9.4	(l) 92.4	(m) 8.1	(n) 94.1	(o) 6.4	(p) 96.3		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	38.1	38.5	43.8	48.6	55.7	59.7	63.8	64.0	58.0	49.5	42.5	37.7		
	DBStd	10.77	6.14	6.64	4.69	4.00	4.31	4.23	3.62	3.39	4.21	4.48	6.15	6.08		
	HDD50	1646	369	322	197	71	5	0	0	0	1	63	235	383		
	HDD65	5523	834	741	658	491	288	168	66	61	213	480	676	847		
	CDD50	1668	0	1	5	29	183	292	429	433	240	47	8	1		
	CDD65	72	0	0	0	0	1	10	30	28	3	0	0	0		
	CDH74	1321	0	0	0	9	68	188	476	478	102	0	0	0		
	CDH80	247	0	0	0	1	8	38	97	90	13	0	0	0		
(14) Wind	WSAvg	1.8	2.0	2.4	2.7	2.4	1.7	1.6	1.5	1.3	1.3	1.3	1.9	2.1		
(15) Precipitation	PrecAvg	47.9	6.9	4.0	4.6	3.2	2.5	2.0	1.3	1.7	2.4	5.2	7.3	6.9		
	PrecMax	58.8	11.6	8.7	9.9	6.9	4.0	4.0	3.0	6.8	6.7	11.2	13.8	10.7		
	PrecMin	35.8	3.6	0.5	1.1	0.6	0.0	0.2	0.0	0.2	0.2	0.6	2.9	3.0		
	PrecStd	6.0	2.1	1.8	1.7	1.4	1.0	1.1	0.7	1.5	1.6	2.5	2.6	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	55.3	64.7	73.6	80.1	84.8	86.6	86.7	81.6	67.5	58.5	53.7		
		MCWB	50.6	49.7	52.8	58.1	61.6	67.0	67.7	67.2	65.7	58.8	54.8	50.9		
	2%	DB	50.4	52.1	59.7	65.1	75.3	79.5	82.6	82.4	76.7	63.2	55.4	49.7		
		MCWB	48.5	48.6	50.0	53.2	60.8	64.9	66.5	67.4	63.5	56.6	52.9	48.0		
	5%	DB	48.5	50.0	56.0	60.9	71.5	74.6	79.2	79.3	72.9	60.0	53.3	47.6		
		MCWB	46.7	47.5	48.3	51.6	59.1	62.8	65.6	66.2	62.4	54.9	51.4	46.0		
	10%	DB	46.8	47.8	52.5	57.7	67.5	70.8	75.9	76.1	68.7	57.5	51.4	46.1		
		MCWB	45.2	45.3	47.4	49.9	57.5	60.5	63.9	64.9	60.3	53.6	49.5	44.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	52.2	55.1	58.9	64.4	68.5	69.4	69.7	68.1	61.9	56.2	52.0		
		MCDB	52.4	54.2	62.0	71.3	77.7	81.0	83.0	81.6	80.1	65.4	58.0	53.5		
	2%	WB	49.0	49.9	51.5	55.5	61.7	65.6	67.5	68.1	65.3	58.8	53.9	48.5		
		MCDB	49.8	50.7	56.3	63.4	73.0	77.6	80.4	79.8	74.0	61.3	55.0	49.6		
	5%	WB	47.2	47.9	49.6	53.0	59.8	63.2	65.8	66.7	63.4	56.1	52.2	46.5		
		MCDB	48.3	49.7	53.8	59.1	69.9	73.2	77.5	77.5	71.0	58.6	53.2	47.5		
	10%	WB	45.4	45.9	48.2	50.9	57.9	61.2	64.4	65.4	61.4	54.6	50.2	44.7		
		MCDB	46.5	47.4	51.8	55.8	66.2	69.6	74.8	75.1	67.5	57.0	51.5	45.8		
(35) Mean Daily Temperature Range	MDBR		11.8	13.4	16.0	17.7	20.6	20.0	22.9	23.0	20.3	15.8	13.4	10.8		
	5% DB	MCDBR	12.4	15.4	23.1	25.5	29.9	28.6	30.2	29.7	29.6	20.0	13.1	9.9		
		MCWBR	10.3	11.1	14.2	14.7	16.0	14.5	15.2	15.6	17.5	13.4	9.1	8.3		
	5% WB	MCDBR	11.3	13.1	16.8	21.3	26.8	25.9	27.8	27.1	25.1	16.7	9.9	10.0		
		MCWBR	9.8	10.0	11.6	12.9	14.9	13.8	14.6	14.8	15.2	12.2	8.2	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.316	0.332	0.366	0.392	0.365	0.363	0.367	0.350	0.338	0.323	0.311		
	taud		2.446	2.508	2.483	2.389	2.340	2.437	2.468	2.471	2.517	2.535	2.496	2.453		
	Ebn at Noon		233	267	281	280	275	284	283	277	271	255	232	221		
	Edh at Noon		20	24	29	35	38	35	33	32	27	23	19	18		
(44) All-Sky Solar Radiation	RadAvg		274	548	826	1281	1673	1799	2005	1700	1181	648	324	219		
	RadStd		44	82	112	136	143	209	173	130	105	88	59	33		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (70 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page