

OLD CROW, YT, Canada

WMO: 710440

Lat: 67.5679N

Lon: 139.8449W

Elev: 824

StdP: 14.26

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-51.9	-48.3	-60.6	0.1	-51.4	-56.2	0.2	-47.8	25.7	-6.9	23.4	-6.4	0.3	0	0.812

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	78.0	59.6	74.5	58.3	71.2	57.2	61.9	73.4	60.1	70.6	58.5	68.4	6.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	72.5	64.8	55.5	67.7	63.7	53.8	63.4	62.5	28.1	73.7	26.9	70.7	25.8	68.8	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.6	20.1	18.0	DB	-52.6	83.9	4.6	2.7	-55.9	85.9	-58.6	87.5	-61.2	89.1	-64.5	91.1	
			WB	-52.5	65.3	4.2	2.5	-55.5	67.1	-57.9	68.6	-60.3	70.0	-63.3	71.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	-19.3	-13.2	-6.3	16.0	39.8	55.9	58.9	51.5	39.5	18.6	-5.7	-14.0
	DBStd	30.90	17.78	14.78	12.41	12.89	11.54	7.44	6.22	7.12	7.58	10.96	14.40	15.06
	HDD50	12085	2150	1770	1745	1019	349	31	10	67	317	973	1670	1984
	HDD65	16941	2615	2190	2210	1469	782	282	200	422	764	1438	2120	2449
	CDD50	640	0	0	0	0	32	206	287	112	3	0	0	0
	CDD65	22	0	0	0	0	0	8	12	2	0	0	0	0
	CDH74	335	0	0	0	0	11	117	164	43	0	0	0	0
	CDH80	35	0	0	0	0	0	11	20	4	0	0	0	0
Wind	WSAvg	6.3	4.4	4.8	6.3	7.8	8.3	7.4	6.8	6.7	6.4	6.5	4.6	5.2
Precipitation	PrecAvg	10.7	0.4	0.3	0.4	0.3	0.5	1.3	2.0	2.2	1.3	0.9	0.6	0.5
	PrecMax	13.1	1.2	0.7	1.1	0.9	1.1	2.5	4.3	4.1	2.4	1.6	1.4	1.1
	PrecMin	8.0	0.0	0.0	0.0	0.0	0.1	0.4	0.8	0.8	0.7	0.4	0.1	0.1
	PrecStd	1.2	0.3	0.2	0.2	0.2	0.2	0.6	0.7	0.7	0.4	0.3	0.3	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	27.1	35.7	50.8	75.3	81.6	82.7	79.2	63.5	42.7	29.0	24.1
		MCWB	25.9	25.0	32.5	41.4	55.3	59.8	61.8	62.2	51.2	39.0	27.6	22.8
	2%	DB	18.8	19.3	25.0	46.5	69.1	77.5	78.5	73.5	59.7	37.9	23.8	16.0
		MCWB	18.0	18.2	22.7	38.6	52.7	58.1	60.9	59.1	49.4	35.4	22.6	15.3
	5%	DB	9.9	12.2	18.6	41.6	63.8	73.9	74.9	68.4	55.8	34.8	19.3	10.7
		MCWB	9.2	11.2	16.6	35.4	49.6	56.7	59.6	56.9	48.2	33.0	18.3	9.9
	10%	DB	3.4	6.4	12.8	37.0	58.9	70.5	71.6	64.2	51.7	32.0	14.5	6.2
		MCWB	2.7	5.5	11.3	32.4	47.2	55.4	58.5	54.9	46.2	30.4	13.5	5.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	25.4	32.6	42.1	56.7	63.4	64.8	63.3	53.1	39.7	27.7	22.9
		MCDB	28.4	27.5	35.6	50.1	71.8	76.4	77.0	74.8	60.5	42.2	28.9	23.9
	2%	WB	17.9	18.4	22.9	38.8	53.5	60.0	62.6	60.5	50.7	35.8	22.9	15.5
		MCDB	18.7	19.6	25.0	45.9	67.8	72.2	74.6	70.7	57.2	37.7	24.0	16.3
	5%	WB	9.1	11.5	16.7	35.6	50.4	58.1	61.1	58.2	48.7	33.3	18.5	10.1
		MCDB	9.7	12.4	18.6	41.1	62.7	70.3	71.6	66.4	54.6	34.8	19.5	10.7
	10%	WB	2.8	5.7	11.4	32.4	47.7	56.5	59.5	55.9	46.7	30.5	13.7	5.8
		MCDB	3.4	6.5	12.9	36.9	58.3	67.9	69.4	62.5	51.6	32.0	14.6	6.5
Mean Daily Temperature Range	5% DB	MDBR	13.6	15.8	22.5	21.9	19.9	20.7	19.0	17.9	15.0	11.1	12.8	13.2
		MCDBR	18.6	18.5	26.6	24.5	28.1	25.8	25.5	25.4	24.1	12.7	13.7	16.8
		MCWBR	18.1	17.6	24.6	17.9	15.4	11.7	12.0	13.2	14.9	10.5	13.3	16.0
	5% WB	MCDBR	18.2	18.1	26.9	23.6	27.0	22.7	21.8	20.9	20.9	12.2	13.4	16.3
		MCWBR	17.9	17.6	24.4	17.3	15.0	11.1	11.4	11.7	13.6	10.1	13.2	16.0
Clear-Sky Solar Irradiance	taub	0.171	0.226	0.245	0.298	0.341	0.348	0.372	0.348	0.303	0.236	0.157	N/A	
	taud	1.904	2.143	2.266	2.211	2.351	2.410	2.373	2.460	2.522	2.300	1.933	N/A	
	Ebn at Noon	50	195	262	271	271	271	259	254	241	192	53	0	
	Edh at Noon	3	15	23	33	32	31	32	26	19	12	3	0	
All-Sky Solar Radiation	RadAvg	18	201	768	1527	1872	1941	1584	1122	664	234	40	0	
	RadStd	1	12	33	55	135	176	116	97	67	29	4	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (4 neighbors)	+2.36	N/A	N/A	N/A	N/A	N/A	-812	-842	N/A	N/A
		+1.55	N/A	N/A	N/A	N/A	N/A	-689	-731	N/A	N/A

Nomenclature: See separate page