

TESLIN, YT, Canada

WMO: 710450

Lat: 60.1746N

Lon: 132.7339W

Elev: 2313

StdP: 13.51

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.5	-31.5	-42.9	0.5	-35.2	-37.2	0.7	-29.3	15.6	13.5	13.7	12.8	1.6	80	0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	77.0	57.9	73.1	56.1	69.4	54.8	59.5	72.9	57.5	69.9	55.9	66.7	6.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.2	68.0	62.0	52.3	63.4	60.3	50.6	59.6	59.1	27.0	73.3	25.7	70.0	24.6	67.0	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.2	13.1	11.4	DB	-42.7	83.5	6.1	3.7	-47.1	86.2	-50.7	88.4	-54.1	90.5	-58.6	93.3	(4)
			WB	-41.0	63.4	5.1	3.1	-44.7	65.6	-47.7	67.4	-50.6	69.2	-54.3	71.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.7	1.6	8.1	18.0	32.9	44.4	53.3	56.7	53.9	44.8	33.1	14.9	5.5
	DBStd	22.34	18.84	15.16	13.02	7.44	6.54	5.82	4.56	5.48	5.47	7.25	13.08	16.53
	HDD50	7556	1500	1174	991	514	198	29	4	19	172	523	1052	1380
	HDD65	12517	1965	1594	1456	964	638	355	259	344	607	988	1502	1845
	CDD50	521	0	0	0	0	25	127	212	142	15	0	0	0
	CDD65	7	0	0	0	0	0	3	2	2	0	0	0	0
	CDH74	264	0	0	0	0	9	87	89	79	0	0	0	0
	CDH80	40	0	0	0	0	1	17	12	10	0	0	0	0
Wind	WSAvg	4.2	3.0	3.0	4.2	4.5	4.8	4.7	4.7	4.3	4.3	4.6	4.8	3.8
Precipitation	PrecAvg	13.8	1.1	0.7	0.5	0.4	0.7	1.3	1.8	1.7	2.0	1.4	1.1	0.9
	PrecMax	20.5	2.7	1.3	1.1	1.5	1.9	2.3	5.8	3.4	4.0	2.7	2.5	2.1
	PrecMin	9.3	0.2	0.1	0.2	0.0	0.3	0.2	0.6	0.4	0.7	0.5	0.3	0.4
	PrecStd	2.4	0.6	0.4	0.2	0.3	0.4	0.6	1.0	0.7	0.8	0.5	0.6	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.0	40.0	47.3	60.8	74.3	82.3	81.2	80.9	67.1	54.3	43.0	40.2
		MCWB	34.3	34.9	37.9	46.0	53.3	59.3	59.7	60.5	53.7	46.2	38.5	36.1
	2%	DB	34.5	35.7	41.6	53.2	68.9	75.8	76.1	75.5	61.6	49.4	38.7	35.6
		MCWB	31.9	32.1	34.5	41.0	50.9	56.4	57.9	58.2	50.8	42.9	34.8	32.9
	5%	DB	30.9	32.4	38.4	48.3	63.6	71.3	72.5	70.7	58.0	46.4	35.0	32.4
		MCWB	29.1	29.6	32.7	38.2	48.2	54.1	56.6	56.3	48.7	40.7	32.2	30.2
	10%	DB	26.2	28.7	35.4	45.2	59.3	66.8	68.7	65.7	55.0	43.4	31.6	28.1
		MCWB	24.9	26.6	30.8	36.5	45.7	52.4	55.4	54.0	47.3	38.6	29.6	26.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	35.7	38.6	45.8	54.8	60.9	61.9	62.1	55.8	47.6	38.7	36.3
		MCDB	37.0	39.2	45.8	58.6	70.7	76.5	75.6	77.8	64.9	52.8	43.1	39.3
	2%	WB	32.1	32.2	35.1	41.6	51.5	57.5	59.5	59.3	52.0	43.8	35.2	33.3
		MCDB	34.3	35.2	40.7	51.1	67.0	73.5	72.0	72.7	59.0	48.2	38.1	35.5
	5%	WB	29.1	29.6	33.0	39.0	49.0	55.5	57.8	57.0	49.8	41.3	32.4	30.1
		MCDB	31.0	32.2	37.9	47.3	62.0	68.6	69.2	68.6	56.1	45.6	34.8	32.3
	10%	WB	25.0	26.7	31.0	37.0	46.5	53.4	56.2	55.1	48.0	39.0	29.6	26.4
		MCDB	26.4	28.9	35.3	44.3	57.4	64.6	66.6	64.3	53.9	43.0	31.6	28.0
Mean Daily Temperature Range	5% DB	MDBR	14.6	18.3	21.6	20.8	23.5	22.7	20.8	20.6	18.0	13.1	12.0	13.1
		MCDBR	15.5	17.6	19.8	25.0	31.4	30.8	29.0	29.6	23.0	16.8	14.2	14.7
		MCWBR	13.3	14.9	14.3	15.4	16.2	14.7	13.8	14.5	13.5	11.2	11.7	13.0
	5% WB	MCDBR	15.3	17.0	18.9	23.2	29.0	27.8	25.3	26.5	20.3	15.4	13.7	14.9
		MCWBR	13.2	14.6	14.2	14.9	15.6	13.8	12.9	13.9	12.7	10.8	11.5	13.4
Clear-Sky Solar Irradiance	taub	0.225	0.246	0.275	0.332	0.357	0.361	0.359	0.347	0.301	0.277	0.223	0.194	
	taud	2.107	2.289	2.236	2.144	2.317	2.395	2.422	2.479	2.591	2.485	2.132	1.991	
	Ebn at Noon	177	249	273	273	275	276	273	269	267	236	175	137	
	Edh at Noon	13	20	29	39	36	34	32	28	21	17	12	9	
All-Sky Solar Radiation	RadAvg	119	375	852	1420	1744	1728	1589	1257	771	384	143	67	
	RadStd	9	41	76	96	116	102	119	108	80	36	17	6	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (4 neighbors)	N/A	+2.41	+3.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page