

TESLIN, YT, Canada

WMO: 710450

Lat: 60.1746N

Lon: 132.7339W

Elev: 705

StdP: 93.14

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.2	-35.3	-41.6	0.1	-37.3	-38.4	0.1	-34.1	7.0	-10.3	6.1	-10.7	0.7	80	0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	25.0	14.4	22.8	13.4	20.8	12.7	15.3	22.7	14.2	21.0	13.3	19.3	2.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.3	9.7	16.7	11.3	9.1	15.7	10.4	8.5	15.1	45.0	22.9	41.9	21.1	39.4	19.5	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.8	5.9	5.1	-41.5	28.6	3.4	2.1	-43.9	30.1	-45.9	31.3	-47.8	32.5	-50.3	34.0		
(5)			-40.6	17.5	2.9	1.7	-42.6	18.7	-44.3	19.7	-45.9	20.7	-47.9	21.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.7	-16.9	-13.3	-7.8	0.5	6.9	11.8	13.7	12.2	7.1	0.6	-9.5	-14.7	(6)
(7)		DBStd	12.41	10.46	8.42	7.24	4.14	3.64	3.23	2.53	3.04	3.04	4.03	7.27	9.18	(7)
(8)		HDD10.0	4198	833	652	551	286	110	16	2	11	96	291	584	767	(8)
(9)		HDD18.3	6954	1092	886	809	536	354	197	144	191	337	549	834	1025	(9)
(10)		CDD10.0	289	0	0	0	0	14	71	118	79	8	0	0	0	(10)
(11)		CDD18.3	4	0	0	0	0	0	2	1	1	0	0	0	0	(11)
(12)		CDH23.3	147	0	0	0	0	5	48	49	44	0	0	0	0	(12)
(13)		CDH26.7	22	0	0	0	0	1	9	7	6	0	0	0	0	(13)
(14)	Wind	WSAvg	1.9	1.3	1.3	1.9	2.0	2.1	2.1	1.9	1.9	2.0	2.1	1.7	(14)	
(15)	Precipitation	PrecAvg	351	29	18	12	11	19	32	45	42	50	35	28	23	(15)
(16)		PrecMax	521	69	34	28	39	47	58	147	87	101	69	64	53	(16)
(17)		PrecMin	236	5	3	4	1	8	4	14	11	19	13	7	9	(17)
(18)		PrecStd	61	15	9	6	8	10	16	25	19	21	13	14	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.3	4.4	8.5	16.0	23.5	28.0	27.3	27.2	19.5	12.4	6.1	4.6	(19)
(20)			MCWB	1.3	1.6	3.3	7.8	11.8	15.1	15.4	15.8	12.1	7.9	3.6	2.3	(20)
(21)		2%	DB	1.4	2.1	5.3	11.8	20.5	24.3	24.5	24.1	16.4	9.7	3.7	2.0	(21)
(22)			MCWB	-0.1	0.0	1.4	5.0	10.5	13.6	14.4	14.6	10.4	6.0	1.5	0.5	(22)
(23)		5%	DB	-0.6	0.2	3.6	9.1	17.6	21.8	22.5	21.5	14.5	8.0	1.7	0.2	(23)
(24)			MCWB	-1.6	-1.4	0.4	3.4	9.0	12.3	13.7	13.5	9.3	4.8	0.1	-1.0	(24)
(25)		10%	DB	-3.2	-1.8	1.9	7.3	15.2	19.3	20.4	18.7	12.8	6.4	-0.2	-2.2	(25)
(26)			MCWB	-3.9	-3.0	-0.7	2.5	7.6	11.3	13.0	12.2	8.5	3.7	-1.3	-3.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	2.1	3.7	7.6	12.7	16.1	16.6	16.7	13.2	8.7	3.7	2.4	(27)
(28)			MCDWB	2.8	4.0	7.6	14.8	21.5	24.7	24.2	25.4	18.3	11.6	6.2	4.0	(28)
(29)		2%	WB	0.0	0.1	1.7	5.3	10.9	14.2	15.3	15.2	11.1	6.5	1.8	0.7	(29)
(30)			MCDWB	1.3	1.8	4.8	10.6	19.5	23.1	22.2	22.6	15.0	9.0	3.4	1.9	(30)
(31)		5%	WB	-1.6	-1.3	0.6	3.9	9.4	13.0	14.3	13.9	9.9	5.2	0.2	-1.1	(31)
(32)			MCDWB	-0.5	0.1	3.3	8.5	16.7	20.3	20.7	20.3	13.4	7.5	1.5	0.2	(32)
(33)		10%	WB	-3.9	-3.0	-0.5	2.8	8.1	11.9	13.5	12.8	8.9	3.9	-1.3	-3.1	(33)
(34)			MCDWB	-3.1	-1.7	1.8	6.9	14.1	18.1	19.2	17.9	12.2	6.1	-0.2	-2.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.1	10.2	12.0	11.6	13.1	12.6	11.6	11.4	10.0	7.3	6.7	7.3	(35)
(36)			MCDBR	8.6	9.8	11.0	13.9	17.5	17.1	16.1	16.5	12.8	9.3	7.9	8.1	(36)
(37)			MCWBR	7.4	8.3	7.9	8.6	9.0	8.1	7.7	8.1	7.5	6.2	6.5	7.2	(37)
(38)		5% WB	MCDBR	8.5	9.4	10.5	12.9	16.1	15.4	14.0	14.7	11.3	8.6	7.6	8.3	(38)
(39)			MCWBR	7.3	8.1	7.9	8.3	8.7	7.7	7.2	7.7	7.1	6.0	6.4	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.225	0.246	0.275	0.332	0.357	0.361	0.359	0.347	0.301	0.277	0.223	0.194	(40)	
(41)		taud	2.107	2.289	2.236	2.144	2.317	2.395	2.422	2.479	2.591	2.485	2.132	1.991	(41)	
(42)		Ebn at Noon	558	784	861	860	868	870	862	847	843	744	552	433	(42)	
(43)		Edh at Noon	41	63	92	124	113	107	102	89	67	53	39	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.37	1.18	2.69	4.47	5.50	5.45	5.01	3.96	2.43	1.21	0.45	0.21	(44)	
(45)		RadStd	0.03	0.13	0.24	0.30	0.37	0.32	0.37	0.34	0.25	0.11	0.05	0.02	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (4 neighbors)	N/A	+1.34	+1.78	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page