

KOMAKUK BEACH, YT, Canada

WMO: 710460

Lat: 69.595N

Lon: 140.180W

Elev: 43

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 86-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -37.5	(c) -34.4	(d) -40.8	(e) 0.5	(f) -33.9	(g) -39.6	(h) 0.6	(i) -33.4	(j) 54.5	(k) -5.1	(l) 49.5	(m) -5.7	(n) 7.3	(o) 270	(p) 1.102

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	65.5	56.7	60.4	53.9	56.4	51.5	57.4	64.9	54.5	60.1	51.8	56.1	14.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.1	60.1	60.3	50.9	55.2	58.1	48.7	50.8	55.2	24.7	65.0	22.9	60.4	21.3	56.3	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 42.1	(b) 36.5	(c) 31.6	(e) -40.8	(f) 75.8	(g) 3.6	(h) 4.2	(i) -43.4	(j) 78.8	(k) -45.5	(l) 81.2	(m) -47.5	(n) 83.6	(o) -50.1	(p) 86.6		
(4) 42.1	(5) 36.5	(6) 31.6	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	-12.1	-11.3	-10.9	4.2	24.0	40.1	47.3	44.2	34.8	17.6	-0.4	-8.1
	DBStd	24.80	13.85	14.98	12.15	12.43	9.32	6.98	6.60	7.11	6.97	9.72	12.73	12.48
	HDD50	13132	1924	1716	1887	1375	806	309	132	209	458	1005	1511	1800
	HDD65	18516	2389	2136	2352	1825	1271	746	550	646	905	1470	1961	2265
	CDD50	91	0	0	0	0	0	13	47	28	3	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	12	0	0	0	0	0	2	3	7	0	0	0	0
	CDH80	1	0	0	0	0	0	0	0	1	0	0	0	0
	WSAvg	13.8	16.7	16.2	14.8	14.2	13.8	12.3	11.2	10.7	11.6	12.9	15.4	16.2
	PrecAvg	6.6	0.2	0.2	0.1	0.2	0.2	0.6	1.2	1.5	0.8	0.8	0.4	0.2
	PrecMax	10.9	0.7	0.7	0.5	0.6	1.0	1.8	4.5	3.4	2.6	2.3	1.9	0.7
	PrecMin	2.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0
	PrecStd	2.2	0.2	0.2	0.1	0.2	0.2	0.6	0.9	0.9	0.6	0.6	0.4	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	30.8	30.2	36.0	45.5	68.3	71.8	71.9	62.5	42.6	35.6	30.5
		MCWB	32.4	30.2	29.8	33.8	42.0	57.6	58.1	59.7	52.6	39.3	34.2	30.2
	2%	DB	22.6	24.5	19.6	31.2	40.4	60.4	66.4	62.8	53.7	35.9	28.0	21.3
		MCWB	21.9	23.9	19.1	29.9	38.2	53.7	57.3	54.9	47.7	34.2	27.2	20.5
	5%	DB	13.6	17.7	11.9	26.3	37.0	54.9	61.6	58.0	47.7	32.4	22.3	15.4
		MCWB	12.8	17.1	11.2	25.5	35.3	49.9	55.3	52.6	44.2	31.5	21.6	14.5
	10%	DB	6.7	10.4	5.4	21.5	34.5	50.3	57.4	54.2	43.6	29.7	16.8	9.6
		MCWB	5.9	9.6	4.9	20.8	33.2	46.3	52.5	50.0	41.6	28.9	16.4	8.9
	0.4%	WB	29.6	29.6	35.3	34.0	40.8	58.5	61.3	61.1	53.6	39.4	30.3	28.8
		MCDB	30.4	30.0	35.6	35.7	42.8	66.9	68.7	74.8	61.3	41.5	30.5	28.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	22.7	25.2	24.9	29.8	37.2	53.6	58.3	56.1	47.8	35.3	21.9	20.1
		MCDB	23.5	25.8	25.4	30.6	38.9	59.9	65.7	62.5	54.1	36.9	22.4	20.8
	5%	WB	15.4	20.8	14.2	24.8	34.8	50.0	55.7	52.2	43.7	32.5	14.4	13.3
		MCDB	16.2	21.4	14.9	25.5	36.2	55.2	61.5	55.9	46.0	33.4	14.9	14.1
	10%	WB	7.6	13.3	6.4	20.1	32.8	46.5	53.2	50.0	40.7	29.0	9.5	7.1
		MCDB	8.3	13.9	6.9	20.8	33.7	50.1	58.2	53.4	41.9	29.9	10.2	7.8
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	12.0	10.8	11.4	8.4	11.5	13.1	11.5	9.0	9.4	10.7	10.7
		MCDBR	21.9	22.6	18.2	14.9	11.1	21.7	21.0	20.3	18.2	11.9	17.6	18.9
		MCWBR	17.0	19.0	20.0	13.7	8.1	14.6	12.4	14.8	11.9	11.0	18.8	19.9
	5% WB	MCDBR	17.4	19.8	22.0	13.2	8.9	20.1	18.8	20.4	14.7	11.5	15.5	19.4
		MCWBR	17.3	20.0	22.1	12.9	7.6	14.7	13.0	14.2	10.7	11.1	15.5	19.5
(40) Clear-Sky Solar Irradiance	taub		0.169	0.205	0.252	0.310	0.346	0.357	0.380	0.347	0.303	0.224	N/A	N/A
	taud		1.887	2.077	2.168	2.073	2.092	2.293	2.344	2.471	2.494	2.192	N/A	N/A
	Ebn at Noon		9	180	245	258	262	264	252	250	231	167	0	0
	Edh at Noon		1	12	23	36	40	34	32	25	18	11	0	0
	RadAvg		4	124	638	1367	1890	1964	1557	998	548	169	0	0
(45) All-Sky Solar Radiation	RadStd		0	12	34	71	124	171	120	91	53	23	0	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.26	+2.16	N/A	N/A	N/A	N/A	-454	-452	N/A
(47) Regional (6 neighbors)		+1.35	+1.69	N/A	N/A	N/A	N/A	-457	-493	N/A

Nomenclature: See separate page