

WAGER BAY, NU, Canada

WMO: 710490

Lat: 65.879N

Lon: 89.446W

Elev: 18

StdP: 101.11

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.5	-38.0	-44.3	0.0	-39.4	-42.4	0.1	-38.0	23.1	-23.3	18.5	-30.0	2.4	300	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	19.9	12.7	17.4	11.5	15.5	10.6	13.2	18.3	12.0	15.5	10.8	14.3	5.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	8.1	14.8	9.6	7.5	13.6	8.4	6.8	12.5	37.2	18.5	34.1	15.6	31.2	14.3	17.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	16.4	13.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.0	-28.0	-29.8	-24.9	-16.0	-5.8	4.6	11.5	9.6	2.9	-5.8	-16.3	-23.7
	DBStd	15.22	6.06	5.68	6.30	5.97	4.97	3.57	3.11	3.18	3.09	4.83	6.74	6.65
	HDD10.0	7414	1177	1116	1082	781	491	166	19	46	214	489	789	1045
	HDD18.3	10354	1435	1349	1340	1031	749	412	214	269	464	748	1039	1303
	CDD10.0	102	0	0	0	0	0	4	64	34	0	0	0	0
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH23.3	18	0	0	0	0	0	0	10	8	0	0	0	0
	CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0
Wind	WSAvg	5.4	5.0	4.4	4.4	5.0	6.0	5.8	5.1	5.4	5.7	6.6	6.5	5.1
Precipitation	PrecAvg	280	11	10	14	17	18	25	36	49	37	29	19	14
	PrecMax	415	34	21	40	45	43	61	92	98	69	55	44	26
	PrecMin	153	2	2	3	3	4	5	13	18	15	7	2	3
	PrecStd	60	8	5	9	10	9	13	19	19	14	12	11	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.1	-13.1	-8.0	-0.2	5.6	17.9	24.7	24.1	12.0	3.1	-0.6	-1.0
		MCWB	-6.6	-13.7	-8.7	-1.6	2.9	11.2	14.1	14.1	7.4	1.9	-1.1	-1.7
	2%	DB	-12.8	-15.5	-11.3	-3.1	3.6	14.2	21.0	19.5	9.8	1.8	-2.5	-8.0
		MCWB	-13.3	-16.0	-12.1	-4.1	1.5	9.1	13.7	12.0	6.6	0.9	-2.9	-8.6
	5%	DB	-16.1	-18.3	-13.6	-5.0	2.1	11.8	18.3	16.6	8.4	1.1	-4.4	-11.0
		MCWB	-16.5	-18.7	-14.1	-6.0	0.3	7.7	12.2	10.9	5.9	0.3	-4.8	-11.6
	10%	DB	-18.9	-20.8	-15.6	-7.1	0.8	9.5	16.7	14.5	7.1	0.3	-6.3	-13.5
		MCWB	-19.4	-21.1	-16.1	-8.1	-0.6	6.1	11.4	10.1	5.1	-0.5	-6.9	-14.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.3	-14.4	-8.7	-1.7	3.0	11.0	15.3	13.8	8.5	2.2	-1.2	-1.6
		MCDB	-5.9	-14.0	-8.1	-0.3	4.7	15.5	20.3	18.9	10.6	2.7	-1.0	-0.8
	2%	WB	-13.0	-17.4	-12.4	-4.1	1.5	8.9	14.0	12.3	7.2	1.1	-3.2	-8.1
		MCDB	-12.6	-17.0	-11.8	-3.1	3.1	13.3	19.7	15.7	9.2	1.7	-2.9	-7.6
	5%	WB	-16.1	-19.8	-14.2	-6.0	0.4	7.4	12.9	11.3	6.2	0.5	-5.1	-11.3
		MCDB	-15.8	-19.6	-13.7	-5.1	1.6	10.9	17.8	14.3	7.9	1.1	-4.7	-10.8
	10%	WB	-18.8	-22.1	-16.1	-8.0	-0.8	6.0	11.7	10.3	5.3	-0.4	-7.0	-13.9
		MCDB	-18.5	-21.9	-15.6	-7.0	0.6	8.9	15.5	13.4	6.9	0.3	-6.5	-13.4
Mean Daily Temperature Range	5% DB	MDBR	6.0	5.9	8.0	8.7	7.0	6.3	7.9	6.6	4.8	4.6	6.0	6.1
		MCDBR	7.5	7.4	8.8	9.5	7.4	10.2	10.9	10.8	6.9	4.1	7.6	7.4
		MCWBR	7.3	7.5	8.0	8.4	5.1	5.2	5.0	4.9	4.7	3.8	7.7	7.0
	5% WB	MCDBR	7.5	7.6	8.5	8.9	6.4	8.5	8.9	7.4	6.3	4.1	7.7	7.1
		MCWBR	7.4	7.5	8.1	8.1	5.2	5.2	5.1	4.7	4.7	4.0	7.8	6.9
Clear-Sky Solar Irradiance	taub	0.153	0.223	0.264	0.313	0.345	0.325	0.357	0.336	0.304	0.256	0.165	0.151	
	taud	1.891	2.121	2.163	2.065	2.063	2.363	2.410	2.462	2.452	2.174	1.906	1.902	
	Ebn at Noon	336	671	808	841	846	885	841	826	772	597	282	66	
	Edh at Noon	18	53	85	122	137	104	97	84	66	50	17	4	
All-Sky Solar Radiation	RadAvg	0.10	0.71	2.42	4.80	6.38	5.83	5.17	3.46	1.96	0.67	0.17	0.02	
	RadStd	0.01	0.06	0.14	0.20	0.35	0.56	0.49	0.31	0.19	0.10	0.02	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page