

STORM HILLS, NT, Canada

WMO: 710520

Lat: 68.894N

Lon: 133.940W

Elev: 261

StdP: 98.22

Time Zone: -7.00 (NAM)

Period: 99-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.1	-34.6	N/A	N/A	N/A	N/A	N/A	N/A	25.2	-21.5	22.7	-17.3	7.1	270	1.078

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	21.9	N/A	20.0	N/A	18.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.6	13.2	DB	-37.7	25.2	1.5	1.9	-38.8	26.6	-39.7	27.7	-40.5	28.8	-41.6	30.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-8.5	-23.6	-23.1	-22.7	-13.8	-2.8	7.8	10.8	8.2	2.3	-6.7	-17.5	-22.5
	DBStd	14.24	7.07	7.40	6.66	6.55	6.74	5.25	4.79	4.52	4.35	4.64	5.29	5.87
	HDD10.0	6921	1042	926	1015	713	398	103	49	89	234	518	824	1009
	HDD18.3	9814	1301	1159	1273	963	654	316	236	313	482	776	1074	1267
	CDD10.0	152	0	0	0	0	2	38	75	34	2	1	0	0
	CDD18.3	4	0	0	0	0	0	1	3	0	0	0	0	0
	CDH23.3	17	0	0	0	0	0	7	10	0	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	6.6	7.7	7.6	6.7	6.3	6.2	6.1	5.8	6.0	6.2	6.4	7.2	7.1
Precipitation	PrecAvg	239	11	10	13	10	12	25	40	40	31	23	14	12
	PrecMax	314	30	20	34	26	36	69	73	81	56	42	34	35
	PrecMin	181	1	0	0	1	0	3	10	13	8	5	1	2
	PrecStd	36	8	6	8	7	8	17	15	16	12	9	7	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.0	-2.7	-4.4	4.8	17.7	24.6	24.6	22.0	15.5	10.4	-1.8	-3.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-4.2	-5.6	-7.4	1.3	13.5	21.5	22.2	19.5	13.0	3.5	-5.0	-8.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-8.7	-8.7	-10.1	-1.5	10.4	19.4	20.4	17.2	10.8	0.7	-7.7	-11.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-14.1	-11.6	-13.0	-3.9	6.9	16.9	18.6	15.3	8.7	-0.8	-10.1	-14.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.8	5.8	6.0	6.4	9.1	7.5	6.3	4.8	3.6	4.9	5.2
		MCDBR	9.7	8.8	8.7	7.7	11.8	11.7	9.7	8.8	8.4	4.8	6.4	9.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.153	0.205	0.241	0.292	0.329	0.330	0.349	0.324	0.288	0.225	0.151	N/A	
	taud	1.909	2.116	2.243	2.192	2.308	2.464	2.459	2.542	2.560	2.216	1.919	N/A	
	Ebn at Noon	86	605	810	850	856	870	836	824	767	561	69	0	
	Edh at Noon	5	40	70	102	104	92	90	74	55	36	4	0	
All-Sky Solar Radiation	RadAvg	0.02	0.47	2.09	4.36	5.84	6.24	5.00	3.29	1.75	0.56	0.07	0.00	
	RadStd	0.00	0.03	0.10	0.19	0.41	0.49	0.43	0.32	0.16	0.06	0.01	0.00	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+1.04	+1.81	+2.05	N/A	N/A	N/A	N/A	-427	-422	N/A	N/A

Nomenclature: See separate page