

CLINTON POINT, NU, Canada

WMO: 710530

Lat: 69.580N

Lon: 120.800W

Elev: 330

StdP: 14.52

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -36.0	(c) -32.8	(d) -37.5	(e) 0.7	(f) -31.2	(g) -35.6	(h) 0.7	(i) -29.6	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) 1.095

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.7	(c) 65.8	(d) 55.5	(e) 61.6	(f) 53.4	(g) 57.1	(h) 50.9	(i) 56.4	(j) 64.2	(k) 53.7	(l) 60.9	(m) 51.1	(n) 57.0	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.0	58.3	60.2	49.1	52.3	57.0	46.8	47.9	54.7	24.2	64.3	22.5	61.1	21.0	57.0	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -37.9	(f) 72.6	(g) 4.3	(h) 5.4	(i) -41.0	(j) 76.5	(k) -43.6	(l) 79.7	(m) -46.0	(n) 82.8	(o) -49.1	(p) 86.7		
(4) N/A	(5) N/A	(6) N/A	(e) -34.5	(f) 62.2	(g) 1.9	(h) 3.9	(i) -35.9	(j) 65.1	(k) -37.0	(l) 67.4	(m) -38.1	(n) 69.6	(o) -39.5	(p) 72.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	-15.3	-15.3	-10.0	3.0	21.2	38.7	46.2	43.2	34.4	19.0	-2.9	-9.7		
	DBStd	24.91	10.76	13.02	11.41	11.92	9.85	8.17	7.76	7.40	6.65	9.56	11.12	11.25		
	HDD50	13656	2025	1830	1861	1411	894	355	172	242	468	961	1587	1850		
	HDD65	19032	2490	2250	2326	1861	1359	790	585	676	917	1426	2037	2315		
	CDD50	102	0	0	0	0	0	15	55	31	1	0	0	0		
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH74	9	0	0	0	0	0	0	7	2	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	6.3	0.2	0.1	0.1	0.2	0.3	0.6	1.3	1.5	1.1	0.6	0.3	0.2		
(15) Precipitation	PrecMax	11.5	0.5	0.5	0.7	0.9	0.9	1.9	3.3	4.2	2.1	1.2	0.8	0.5		
	PrecMin	3.7	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.1	0.2	0.1	0.0	0.0		
	PrecStd	1.8	0.1	0.1	0.2	0.2	0.3	0.5	0.9	0.9	0.5	0.3	0.2	0.1		
	PrecStd	1.8	0.1	0.1	0.2	0.2	0.3	0.5	0.9	0.9	0.5	0.3	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.6	21.3	27.4	40.0	46.9	67.2	73.3	70.4	58.1	41.9	27.0	25.4		
		MCWB	19.8	20.7	26.2	36.3	42.5	56.0	61.4	57.3	50.4	38.8	26.4	24.2		
	2%	DB	15.1	17.2	18.1	31.3	42.9	61.8	67.7	63.4	51.9	37.7	21.7	18.5		
		MCWB	14.5	16.6	17.3	29.7	39.1	52.6	56.8	55.5	46.5	35.5	20.7	17.5		
	5%	DB	4.7	12.6	12.2	25.6	38.7	55.8	63.3	59.3	47.1	34.6	18.4	13.0		
		MCWB	4.0	11.9	11.6	24.5	36.1	49.6	54.1	52.5	43.5	32.8	17.7	12.3		
	10%	DB	-0.6	5.4	6.9	19.7	34.2	50.5	58.4	54.7	43.3	30.7	13.7	7.8		
		MCWB	-1.1	4.7	6.2	18.9	32.8	45.9	52.0	50.3	40.7	29.8	13.1	7.1		
	0.4%	WB	19.9	20.7	26.8	37.3	43.2	56.4	61.9	59.5	50.8	39.6	26.3	24.3		
		MCDB	20.4	20.9	27.8	39.5	46.2	64.8	72.3	68.9	57.4	41.8	26.9	25.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	14.8	16.9	17.6	29.7	39.4	52.6	57.6	55.7	46.9	35.9	20.9	17.7		
		MCDB	15.4	17.4	18.1	31.6	42.2	61.2	65.8	62.6	51.5	37.6	21.5	18.5		
	5%	WB	5.2	12.7	11.7	24.6	36.1	49.4	54.5	52.7	44.0	32.8	17.7	12.3		
		MCDB	5.9	13.5	12.3	25.8	38.4	55.6	62.1	58.3	47.0	34.3	18.5	12.8		
	10%	WB	-1.0	5.9	6.4	18.8	32.7	45.9	52.0	50.1	40.7	30.1	13.0	7.2		
		MCDB	-0.5	6.7	7.0	19.7	34.1	50.2	58.6	55.2	42.8	30.9	13.7	7.9		
	5% DB	MDBR	8.9	9.8	9.3	9.6	7.8	8.7	9.7	8.8	6.5	6.4	6.9	8.7		
		MCDBR	16.7	16.4	14.5	14.5	13.5	17.7	16.7	17.2	13.5	8.7	8.8	13.1		
		MCWBR	16.5	16.3	14.3	13.2	11.5	12.4	10.4	10.6	10.4	7.6	8.8	12.6		
		MCWBR	17.0	16.4	14.5	14.1	12.7	16.7	16.1	16.4	12.7	8.3	8.8	12.9		
(35) Mean Daily Temperature Range	5% WB	MCWBR	16.8	16.4	14.3	13.2	11.2	12.3	11.4	11.2	10.0	7.4	8.9	12.4		
		MCWBR	16.8	16.4	14.3	13.2	11.2	12.3	11.4	11.2	10.0	7.4	8.9	12.4		
		MCWBR	16.8	16.4	14.3	13.2	11.2	12.3	11.4	11.2	10.0	7.4	8.9	12.4		
		MCWBR	16.8	16.4	14.3	13.2	11.2	12.3	11.4	11.2	10.0	7.4	8.9	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.156	0.210	0.244	0.294	0.335	0.343	0.358	0.341	0.296	0.235	N/A	N/A		
	taud		1.890	2.032	2.198	2.124	2.126	2.312	2.355	2.460	2.504	2.142	N/A	N/A		
	Ebn at Noon		12	174	250	266	266	269	260	252	235	157	0	0		
	Edh at Noon		1	13	23	34	39	34	31	25	18	11	0	0		
(44) All-Sky Solar Radiation	RadAvg		5	133	636	1424	1941	1944	1682	1044	510	138	0	0		
	RadStd		1	15	37	64	145	153	125	115	62	21	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (7 neighbors)		+1.01	+2.18	+2.88	N/A	N/A	N/A	N/A	-400	N/A	N/A		

Nomenclature: See separate page