

KEATS POINT, NT, Canada

WMO: 710580

Lat: 69.673N

Lon: 121.672W

Elev: 1083

StdP: 14.13

Time Zone: -7.00 (NAM)

Period: 98-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.1	-27.9	N/A	N/A	N/A	N/A	N/A	N/A	52.8	-1.0	48.9	-3.8	24.2	220	1.157

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	69.8	N/A	65.7	N/A	61.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.6	39.9	35.6	DB	-35.1	74.5	4.4	4.4	-38.3	77.6	-40.9	80.2	-43.4	82.7	-46.6	85.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	-10.0	-10.5	-8.3	5.5	23.8	41.7	48.3	45.4	33.6	19.5	3.1	-6.0	(6)	
	DBStd	23.89	10.90	10.82	12.07	10.21	11.32	9.95	9.41	9.04	8.12	7.27	8.95	9.36	(7)	
	HDD50	12748	1859	1695	1808	1336	814	292	152	206	494	947	1408	1737	(8)	
	HDD65	18023	2324	2115	2273	1786	1278	700	523	611	941	1412	1858	2202	(9)	
	CDD50	208	0	0	0	0	1	43	98	63	3	0	0	0	(10)	
	CDD65	8	0	0	0	0	0	1	4	3	0	0	0	0	(11)	
	CDH74	22	0	0	0	0	0	4	8	10	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	16.0	18.8	17.6	16.2	14.9	15.2	14.9	15.0	14.0	15.7	16.3	17.2	16.4	(14)	
	PrecAvg	7.9	0.4	0.3	0.4	0.3	0.4	0.7	1.3	1.5	1.0	0.7	0.5	0.4	(15)	
(16) Precipitation	PrecMax	10.3	1.1	0.9	1.2	1.0	1.1	1.5	2.2	3.0	2.1	1.5	1.1	0.9	(16)	
	PrecMin	5.6	0.1	0.0	0.1	0.0	0.1	0.2	0.6	0.7	0.4	0.2	0.2	0.1	(17)	
	PrecStd	1.3	0.2	0.2	0.2	0.2	0.2	0.3	0.4	0.6	0.4	0.4	0.3	0.2	(18)	
	PrecStd	1.3	0.2	0.2	0.2	0.2	0.2	0.3	0.4	0.6	0.4	0.4	0.3	0.2	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	21.1	26.7	34.6	55.8	73.6	74.2	75.0	58.2	47.3	28.8	23.2	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	19.6	16.2	21.9	29.8	49.0	66.3	69.7	69.4	53.1	34.9	23.6	16.7	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	12.1	10.6	14.9	25.8	45.0	61.7	66.2	64.4	49.0	31.5	19.4	11.6	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	5.7	5.7	8.5	21.0	40.4	57.4	62.7	59.2	45.2	28.7	15.7	7.3	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	10.5	10.9	10.8	11.2	9.8	11.4	11.3	9.9	7.2	6.8	8.6	9.6	(35)	
		MCDBR	18.1	15.1	16.0	15.9	13.3	17.6	15.7	15.5	13.0	9.0	12.2	14.6	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.151	0.202	0.238	0.290	0.324	0.327	0.345	0.331	0.287	0.227	N/A	N/A	(40)	
	taud		1.889	2.029	2.194	2.106	2.115	2.333	2.376	2.466	2.498	2.127	N/A	N/A	(41)	
	Ebn at Noon		12	177	252	267	270	275	264	255	238	160	0	0	(42)	
	Edh at Noon		1	13	23	35	39	33	30	25	18	11	0	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		5	131	633	1421	1944	1958	1681	1040	510	139	0	0	(44)	
	RadStd		1	14	35	64	145	155	129	116	60	19	0	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+1.01	+2.18	+2.88	N/A	N/A	N/A	N/A	-400	N/A	N/A

Nomenclature: See separate page