

KEATS POINT, NT, Canada

WMO: 710580

Lat: 69.673N

Lon: 121.672W

Elev: 330

StdP: 97.42

Time Zone: -7.00 (NAM)

Period: 98-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.1	-33.3	N/A	N/A	N/A	N/A	N/A	N/A	23.6	-18.4	21.8	-19.9	10.8	220	1.157

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	21.0	N/A	18.7	N/A	16.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	17.9	15.9	DB	-37.3	23.6	2.5	2.4	-39.1	25.4	-40.5	26.8	-41.9	28.2	-43.7	29.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.1	-23.3	-23.6	-22.4	-14.7	-4.6	5.4	9.0	7.4	0.9	-7.0	-16.1	-21.1	(6)	
	DBStd	13.27	6.06	6.01	6.71	5.67	6.29	5.53	5.23	5.02	4.51	4.04	4.97	5.20	(7)	
	HDD10.0	7082	1033	942	1004	742	452	162	84	114	274	526	782	965	(8)	
	HDD18.3	10013	1291	1175	1263	992	710	389	291	339	523	784	1032	1223	(9)	
	CDD10.0	116	0	0	0	0	1	24	54	35	2	0	0	0	(10)	
	CDD18.3	4	0	0	0	0	0	1	2	2	0	0	0	0	(11)	
	CDH23.3	12	0	0	0	0	0	2	4	6	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.2	8.4	7.9	7.2	6.7	6.8	6.6	6.7	6.3	7.0	7.3	7.7	7.3	(14)	
(15) Precipitation	PrecAvg	200	9	8	9	8	11	18	32	38	26	19	13	10	(15)	
	PrecMax	262	27	24	31	25	29	38	56	75	53	38	28	22	(16)	
	PrecMin	143	2	1	2	1	2	6	14	18	9	5	4	3	(17)	
	PrecStd	34	4	5	6	5	6	7	9	14	9	9	7	5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.3	-6.0	-2.9	1.4	13.2	23.1	23.4	23.9	14.6	8.5	-1.8	-4.9	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	-6.9	-8.8	-5.6	-1.2	9.5	19.1	21.0	20.8	11.7	1.6	-4.6	-8.5	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	-11.0	-11.9	-9.5	-3.5	7.2	16.5	19.0	18.0	9.5	-0.3	-7.0	-11.3	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	-14.6	-14.6	-13.0	-6.1	4.7	14.1	17.1	15.1	7.3	-1.8	-9.1	-13.7	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	6.1	6.0	6.2	5.5	6.4	6.3	5.5	4.0	3.8	4.8	5.3	(35)	
		MCDBR	10.0	8.4	8.9	8.8	7.4	9.8	8.7	8.6	7.2	5.0	6.8	8.1	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.151	0.202	0.238	0.290	0.324	0.327	0.345	0.331	0.287	0.227	N/A	N/A	(40)	
	taud		1.889	2.029	2.194	2.106	2.115	2.333	2.376	2.466	2.498	2.127	N/A	N/A	(41)	
	Ebn at Noon		38	558	796	841	850	866	833	805	751	503	0	0	(42)	
	Edh at Noon		3	40	71	109	124	103	96	78	56	35	0	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.01	0.41	2.00	4.48	6.13	6.17	5.30	3.28	1.61	0.44	0.00	0.00	(44)	
	RadStd		0.00	0.04	0.11	0.20	0.46	0.49	0.41	0.37	0.19	0.06	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	+0.56	+1.21	+1.60	N/A	N/A	N/A	N/A	-222	N/A	N/A

Nomenclature: See separate page