

NORDEGG, AB, Canada

WMO: 710600

Lat: 52.471N

Lon: 116.077W

Elev: 4370

StdP: 12.52

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-21.7	-14.7	-28.0	1.4	-21.5	-20.5	2.1	-13.7	17.1	38.1	14.4	37.0	2.1	280	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.1	79.8	56.6	76.2	55.9	72.8	54.7	60.3	72.4	58.5	70.5	56.7	68.7	6.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.3	79.6	63.1	54.2	73.5	61.1	52.2	68.1	59.7	28.8	72.9	27.4	70.6	26.1	68.5	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.1	10.4	DB	-31.5	85.5	4.8	3.1	-35.0	87.7	-37.8	89.5	-40.4	91.3	-43.9	93.5	(4)
(5)			WB	-32.0	63.8	4.0	2.3	-34.9	65.5	-37.3	66.8	-39.6	68.1	-42.5	69.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.6	19.8	19.5	27.0	35.0	44.4	51.2	57.1	55.2	47.3	37.4	26.6	17.7
	DBStd	17.20	15.17	13.63	12.62	8.51	7.60	5.80	5.56	5.90	7.73	8.86	12.00	13.81
	HDD50	5479	935	854	713	451	205	51	8	20	142	399	701	1000
	HDD65	10365	1400	1274	1177	899	638	414	252	306	532	857	1151	1465
	CDD50	600	0	0	0	2	32	89	227	181	61	7	1	0
	CDD65	9	0	0	0	0	0	1	6	2	0	0	0	0
	CDH74	561	0	0	0	0	11	56	271	169	54	0	0	0
	CDH80	92	0	0	0	0	0	8	52	27	5	0	0	0
Wind	WSAvg	3.9	4.1	3.9	4.5	4.2	4.0	3.7	3.7	3.3	3.4	3.7	4.1	3.8
Precipitation	PrecAvg	23.8	1.1	0.7	1.1	1.5	2.8	3.9	4.4	3.2	2.5	1.2	0.8	1.0
	PrecMax	32.0	4.1	1.9	3.1	3.1	6.2	10.4	11.5	6.8	6.2	3.0	1.7	2.6
	PrecMin	17.2	0.0	0.0	0.2	0.4	0.6	1.5	0.9	0.9	0.2	0.2	0.2	0.2
	PrecStd	4.6	1.0	0.5	0.7	0.7	1.5	1.9	2.6	1.6	1.6	0.7	0.4	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	50.2	57.4	67.4	75.5	80.5	85.0	83.8	79.9	68.5	56.6	49.5
		MCWB	38.2	36.5	40.5	46.8	50.9	55.7	58.1	57.6	54.9	49.7	42.3	38.5
	2%	DB	45.8	45.6	50.8	60.3	71.0	74.3	80.8	78.2	74.1	61.3	51.4	44.4
		MCWB	35.8	34.4	37.4	43.9	49.1	53.9	57.1	56.7	54.5	46.4	39.7	34.6
	5%	DB	42.6	41.9	47.4	55.3	66.2	69.8	76.7	74.9	68.8	56.6	46.6	40.3
		MCWB	33.7	32.4	35.9	40.9	48.1	51.8	57.4	56.0	52.5	44.2	37.0	32.0
	10%	DB	39.0	37.8	43.7	50.4	61.4	65.9	72.5	70.8	63.0	52.0	42.2	36.3
		MCWB	31.6	29.7	33.6	38.0	46.2	50.7	55.9	55.4	49.9	41.5	34.4	29.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.4	37.8	41.4	47.6	53.1	59.7	63.3	62.6	58.5	51.0	43.6	39.3
		MCDB	48.7	47.8	55.2	63.7	69.2	72.0	75.2	73.3	71.7	65.5	55.0	49.1
	2%	WB	36.6	35.1	38.6	44.6	50.9	56.4	60.9	60.1	55.8	47.7	40.5	35.1
		MCDB	45.0	44.5	48.9	58.5	66.2	68.0	73.0	71.9	69.8	59.2	50.0	43.1
	5%	WB	34.1	32.6	36.3	41.8	49.1	54.1	59.0	58.2	53.5	44.9	37.6	32.5
		MCDB	41.6	41.0	46.1	53.2	63.6	65.7	71.2	69.9	67.0	55.0	45.8	39.9
	10%	WB	31.9	30.1	34.2	39.1	47.2	52.3	57.3	56.3	51.0	42.2	34.9	29.9
		MCDB	38.8	37.1	43.1	49.1	60.6	62.9	69.2	68.0	62.6	50.7	41.7	35.8
Mean Daily Temperature Range	5% DB	MDBR	19.5	22.6	22.1	21.4	23.1	22.8	25.1	25.1	23.8	21.4	18.6	18.6
		MCDBR	20.0	23.5	25.3	30.1	33.4	31.0	33.9	34.0	34.8	28.9	21.5	20.1
		MCWBR	11.8	14.3	14.2	15.6	15.3	14.0	14.5	15.3	16.4	15.4	12.6	12.9
	5% WB	MCDBR	19.6	23.2	23.9	28.7	30.6	26.7	29.4	30.0	33.4	28.2	20.8	20.1
		MCWBR	11.8	14.5	13.9	15.3	14.7	13.2	13.9	14.9	16.6	15.5	12.8	13.4
Clear-Sky Solar Irradiance	taub		0.253	0.253	0.279	0.313	0.331	0.350	0.345	0.353	0.318	0.279	0.247	0.234
	taud		2.478	2.553	2.506	2.421	2.424	2.394	2.453	2.403	2.496	2.594	2.551	2.469
	Ebn at Noon		249	285	295	294	292	286	286	277	276	270	252	238
	Edh at Noon		16	20	26	32	34	36	33	33	27	20	15	14
All-Sky Solar Radiation	RadAvg		291	567	940	1353	1617	1672	1804	1526	1063	625	316	227
	RadStd		23	49	75	125	128	135	129	95	121	65	26	19

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page