

INDIN RIVER, NT, Canada

WMO: 710614

Lat: 64.390N

Lon: 115.020W

Elev: 305

StdP: 97.72

Time Zone: -7.00 (NAM)

Period: 91-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -46.5	(c) -44.7	(d) -48.9	(e) 0.0	(f) -46.0	(g) -46.9	(h) 0.0	(i) -44.3	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	25.9	16.4	23.9	15.5	21.9	14.7	17.6	23.5	16.5	22.1	15.5	20.7	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	11.4	19.2	14.3	10.6	18.2	13.2	9.8	17.1	50.8	23.4	47.4	22.0	44.5	21.0	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) N/A	(b) N/A	(c) N/A	(e) -48.0	(f) 29.5	(g) 1.6	(h) 1.5	(i) -49.2	(j) 30.6	(k) -50.1	(l) 31.4	(m) -51.0	(n) 32.3	(o) -52.2	(p) 33.4		
(4) N/A	(5) N/A	(6) N/A	(7) -48.0	(8) 19.4	(9) 1.6	(10) 1.4	(11) -49.2	(12) 20.4	(13) -50.1	(14) 21.2	(15) -51.0	(16) 22.0	(17) -52.2	(18) 23.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.5	-30.1	-26.7	-21.5	-11.0	1.0	10.9	14.8	11.9	5.3	-4.4	-16.1	-24.8
	DBStd	17.07	9.43	8.33	8.63	8.16	5.98	4.13	3.85	4.01	4.49	5.70	7.45	9.50
	HDD10.0	6686	1243	1027	976	629	282	37	7	26	152	445	783	1079
	HDD18.3	9426	1502	1260	1234	879	538	225	120	203	392	703	1033	1338
	CDD10.0	316	0	0	0	0	3	63	156	84	10	0	0	0
	CDD18.3	14	0	0	0	0	0	1	11	3	0	0	0	0
	CDH23.3	243	0	0	0	0	0	49	148	46	0	0	0	0
	CDH26.7	45	0	0	0	0	0	12	30	3	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	298	13	10	13	10	18	36	48	50	39	27	19	15
	PrecMax	354	25	20	27	16	35	93	95	82	79	42	37	27
	PrecMin	224	5	4	3	4	4	7	25	19	11	11	10	5
	PrecStd	35	5	4	6	4	9	18	17	17	15	8	6	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-5.4	-7.2	1.9	10.4	18.3	28.7	29.9	26.8	19.6	10.5	0.5	-3.8
		MCWB	-5.6	-7.7	0.1	5.1	11.7	17.0	18.7	16.5	13.0	7.6	0.1	-4.1
	2%	DB	-9.5	-9.4	-2.3	7.2	15.5	24.3	26.7	24.7	16.9	5.1	-1.1	-6.2
		MCWB	-9.8	-9.7	-4.0	3.2	9.3	14.9	17.4	16.1	12.0	3.5	-1.4	-6.5
	5%	DB	-12.7	-11.6	-4.6	4.5	13.0	21.7	24.7	21.9	14.6	3.3	-3.4	-8.6
		MCWB	-13.0	-12.1	-5.6	1.5	7.3	13.8	16.0	15.1	11.1	2.4	-3.8	-8.8
	10%	DB	-15.8	-13.9	-7.1	2.1	10.5	19.6	23.0	19.6	11.9	1.9	-5.3	-11.3
		MCWB	-16.2	-14.2	-7.8	0.2	6.0	12.5	15.4	13.8	9.2	1.2	-5.7	-11.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.8	-7.7	0.3	5.1	12.2	17.1	19.5	17.9	14.1	7.5	0.3	-4.0
		MCDB	-5.3	-7.3	1.7	10.0	17.6	27.5	27.2	22.7	17.2	10.0	0.4	-3.5
	2%	WB	-9.9	-9.6	-3.8	3.4	9.9	15.6	18.2	16.8	12.6	4.0	-1.5	-6.6
		MCDB	-9.6	-9.3	-2.5	6.8	14.9	22.3	24.7	22.6	15.8	4.9	-1.2	-6.3
	5%	WB	-13.0	-11.8	-5.5	1.9	7.7	14.4	17.2	15.8	11.2	2.4	-3.8	-8.8
		MCDB	-12.7	-11.4	-4.5	4.2	12.4	20.3	22.4	21.1	14.2	3.1	-3.5	-8.6
	10%	WB	-16.0	-14.1	-7.8	0.2	6.1	13.2	16.2	14.6	9.8	1.3	-5.7	-11.6
		MCDB	-15.7	-13.8	-7.0	2.1	10.4	18.6	21.3	18.5	11.5	1.9	-5.3	-11.4
Mean Daily Temperature Range	5% DB	MDBR	9.9	12.0	15.3	15.5	11.0	11.5	11.3	10.3	7.5	5.7	8.9	9.9
		MCDBR	10.4	11.2	15.3	16.7	14.9	16.1	14.9	14.3	12.5	6.3	7.7	10.2
		MCWBR	10.1	10.8	13.5	12.7	8.8	7.6	6.1	6.5	7.4	4.6	6.9	9.9
	5% WB	MCDBR	9.9	11.2	15.0	15.8	14.4	14.7	12.5	12.8	11.0	5.8	6.6	9.9
		MCWBR	9.6	10.7	13.3	12.2	8.7	7.2	5.8	6.2	6.8	4.5	6.6	9.9
Clear-Sky Solar Irradiance	taub	0.160	0.227	0.252	0.289	0.323	0.326	0.356	0.328	0.296	0.253	0.156	0.146	
	taud	1.949	2.216	2.261	2.222	2.376	2.495	2.420	2.514	2.575	2.379	1.952	1.937	
	Ebn at Noon	448	720	853	888	888	893	849	847	810	682	434	206	
	Edh at Noon	24	53	80	107	102	93	98	81	62	46	23	9	
All-Sky Solar Radiation	RadAvg	0.19	0.97	2.81	5.08	6.00	6.05	5.25	3.85	2.22	0.74	0.20	0.06	
	RadStd	0.01	0.05	0.12	0.25	0.45	0.50	0.29	0.29	0.20	0.09	0.04	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page