

CAPE PEEL WEST, NU, Canada

WMO: 710640

Lat: 69.036N

Lon: 107.823W

Elev: 165

StdP: 99.35

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-40.3	-38.7	N/A	N/A	N/A	N/A	N/A	N/A	19.4	-26.8	17.8	-27.6	5.9	340	1.160

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	19.0	N/A	16.6	N/A	14.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.3	13.4	DB	-41.9	21.4	2.1	2.5	-43.5	23.1	-44.7	24.6	-45.9	26.0	-47.4	27.7	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.7	-30.1	-30.3	-27.1	-19.7	-8.9	3.1	9.8	7.2	0.1	-10.1	-20.4	-27.1	(6)	
(7)		DBStd	15.19	5.21	4.86	6.15	5.45	5.18	4.78	3.40	3.82	3.92	5.46	5.57	5.33	(7)	
(8)		HDD10.0	8346	1244	1128	1151	891	585	215	47	104	298	622	911	1149	(8)	
(9)		HDD18.3	11324	1503	1361	1409	1141	843	458	266	344	548	881	1161	1408	(9)	
(10)		CDD10.0	64	0	0	0	0	0	7	39	18	0	0	0	0	(10)	
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
(12)		CDH23.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(12)	
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	6.6	6.8	6.8	6.8	6.9	6.7	6.2	5.9	5.7	6.9	7.0	6.6	7.0	(14)	
(15)	Precipitation	PrecAvg	179	6	5	8	8	7	18	33	35	24	18	10	7	(15)	
(16)		PrecMax	233	13	13	28	22	24	44	63	72	57	33	20	15	(16)	
(17)		PrecMin	120	1	1	2	2	1	2	9	17	10	8	4	2	(17)	
(18)		PrecStd	28	3	3	6	4	5	10	15	14	11	7	5	3	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-12.3	-14.2	-8.8	-3.9	2.6	19.2	22.5	21.6	10.8	1.2	-4.7	-8.9	(19)	
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	-17.9	-17.5	-12.4	-7.3	1.0	15.6	19.7	18.1	8.5	0.1	-7.4	-13.2	(21)	
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	-20.2	-20.2	-14.9	-9.8	-0.3	13.1	17.6	15.4	6.9	-1.1	-9.4	-16.0	(23)	
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)		10%	DB	-22.5	-23.0	-17.8	-12.0	-1.7	10.3	15.7	13.1	5.4	-2.5	-11.7	-19.2	(25)	
(26)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
(28)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)
(30)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)
(32)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)		10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)
(34)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)
(35)	Mean Daily Temperature Range		MDBR	5.5	6.0	6.2	6.9	5.6	5.6	6.9	6.0	4.2	5.3	5.9	5.6	(35)	
(36)		5% DB	MCDBR	8.1	8.9	7.5	8.0	5.4	9.6	9.8	9.3	6.5	4.7	7.1	8.5	(36)	
(37)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)
(38)		5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)
(39)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.144	0.206	0.237	0.286	0.313	0.345	0.350	0.325	0.286	0.228	0.157	N/A	(40)		
(41)		taud	1.901	2.059	2.237	2.138	2.139	2.275	2.378	2.483	2.497	2.161	1.891	N/A	(41)		
(42)		Ebn at Noon	86	584	813	853	867	847	831	817	761	535	50	0	(42)		
(43)		Edh at Noon	4	42	70	107	121	110	97	78	57	37	4	0	(43)		
(44)	All-Sky Solar Radiation	RadAvg	0.02	0.43	2.00	4.39	6.32	6.04	5.28	3.41	1.64	0.53	0.06	0.00	(44)		
(45)		RadStd	0.00	0.04	0.12	0.22	0.33	0.31	0.44	0.28	0.17	0.08	0.01	0.00	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page