

MYRNAM AGCM, AB, Canada

WMO: 710650

Lat: 53.7200N

Lon: 111.1144W

Elev: 580

StdP: 94.55

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-35.3	-31.6	-39.0	0.1	-35.3	-35.0	0.1	-31.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	28.1	17.5	26.4	16.7	24.8	16.1	19.3	25.6	18.2	24.2	17.2	22.8	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	13.0	22.6	15.8	12.1	21.2	14.8	11.3	20.1	57.5	25.7	53.9	24.2	50.5	22.8	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-40.4	31.2	2.2	1.8	-42.0	32.6	-43.2	33.6	-44.5	34.6	-46.0	36.0		
(5)			-40.5	21.9	2.2	1.3	-42.1	22.8	-43.3	23.5	-44.6	24.3	-46.1	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.8	-12.8	-13.5	-6.0	2.5	10.1	14.5	16.6	15.4	10.3	3.2	-6.5	-13.6		
	DBStd	12.73	8.67	8.21	7.55	5.28	4.36	3.11	2.58	3.14	4.20	4.58	6.83	8.25		
	HDD10.0	3635	707	658	495	228	54	4	0	2	46	214	493	732		
	HDD18.3	6067	966	892	753	474	256	118	66	101	242	468	743	990		
	CDD10.0	636	0	0	0	4	57	141	206	168	55	5	0	0		
	CDD18.3	26	0	0	0	0	1	4	12	8	1	0	0	0		
	CDH23.3	695	0	0	0	3	71	113	232	204	68	3	0	0		
	CDH26.7	123	0	0	0	1	12	18	44	37	11	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	414	19	12	16	30	44	70	76	58	34	18	19	17		
	PrecMax	562	61	23	37	104	93	139	166	118	78	46	76	32		
	PrecMin	209	4	3	5	3	5	14	25	12	1	2	2	4		
	PrecStd	80	12	6	8	20	23	29	30	23	21	10	16	8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	6.0	12.4	22.6	28.3	28.8	30.1	30.0	28.2	22.1	10.8	5.8		
		MCWB	3.3	2.7	6.2	10.3	13.7	17.0	19.5	18.5	16.0	12.3	5.1	1.8		
	2%	DB	4.7	3.7	8.7	18.3	25.4	26.4	27.8	27.4	25.4	17.0	7.0	3.1		
		MCWB	1.7	1.1	3.9	8.3	12.8	16.0	19.0	18.0	14.7	9.8	3.3	0.1		
	5%	DB	2.8	1.3	5.9	14.8	22.7	24.3	25.8	25.6	23.0	14.0	4.3	0.6		
		MCWB	0.5	-0.4	2.5	6.8	11.8	15.0	17.9	17.3	13.9	7.9	1.6	-1.4		
	10%	DB	0.3	-0.6	3.7	11.6	20.3	22.4	24.1	23.8	19.9	11.4	2.4	-1.9		
		MCWB	-1.4	-2.1	1.0	5.3	10.6	13.9	17.1	16.5	12.5	6.7	0.5	-3.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	3.1	6.7	10.7	15.0	18.7	21.5	20.6	16.9	12.8	5.5	2.6		
		MCDB	6.7	5.5	11.8	21.7	24.3	26.5	28.2	27.2	24.2	20.6	10.0	5.8		
	2%	WB	2.1	1.2	4.2	8.6	13.6	17.2	19.8	19.0	15.4	10.5	3.5	0.2		
		MCDB	4.6	2.9	8.3	17.1	22.3	23.5	26.0	25.7	23.6	15.3	6.3	2.7		
	5%	WB	0.6	-0.2	2.6	7.2	12.6	16.1	18.7	17.9	14.2	8.8	1.7	-1.3		
		MCDB	2.8	1.5	5.5	14.1	20.9	22.2	24.5	23.8	21.9	13.2	3.7	0.4		
	10%	WB	-1.4	-2.3	1.3	5.7	11.5	15.2	17.7	16.9	13.0	7.1	0.6	-3.2		
		MCDB	0.3	-0.6	3.6	10.8	19.2	20.8	23.0	22.8	19.0	11.5	2.3	-1.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.6	11.4	11.9	15.0	12.9	12.8	14.2	15.0	12.0	9.9	10.5		
		MCDBR	12.7	14.2	13.5	18.2	19.4	16.8	16.6	17.6	21.0	17.8	12.3	13.0		
		MCWBR	10.2	11.9	9.3	9.5	8.8	7.8	8.8	9.2	10.9	10.7	9.0	10.5		
		MCDBR	12.6	13.2	12.1	17.0	17.2	14.0	14.7	15.8	19.4	16.4	11.0	12.7		
	5% WB	MCWBR	10.3	11.2	8.4	9.4	8.0	7.1	8.1	8.8	10.5	10.3	8.4	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.249	0.285	0.294	0.333	0.352	0.370	0.367	0.378	0.313	0.277	0.251	0.219		
	taud		2.305	2.234	2.345	2.359	2.356	2.331	2.371	2.311	2.484	2.556	2.445	2.352		
	Ebn at Noon		742	813	895	898	894	879	874	840	868	839	749	726		
	Edh at Noon		56	85	95	108	114	119	112	112	83	61	49	43		
(44) All-Sky Solar Radiation	RadAvg		0.95	2.00	3.52	4.68	5.80	5.92	6.09	4.96	3.49	2.00	0.95	0.70		
	RadStd		0.10	0.15	0.27	0.40	0.42	0.42	0.33	0.37	0.38	0.29	0.11	0.07		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page