

NEW SAREPTA AGCM, AB, Canada

WMO: 710670

Lat: 53.2624N

Lon: 113.1651W

Elev: 2510

StdP: 13.41

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-23.3	-17.8	-29.6	1.1	-22.8	-23.9	1.6	-17.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	81.3	62.3	78.5	61.5	75.6	60.3	66.4	75.7	64.1	73.9	62.3	71.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	93.8	72.0	60.4	86.2	69.1	58.4	80.0	66.7	32.5	75.9	30.7	74.1	29.3	72.0	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-30.0	87.4	5.8	2.8	-34.2	89.5	-37.6	91.1	-40.9	92.7	-45.1	94.7		
(5)			-30.2	70.3	5.8	3.1	-34.4	72.6	-37.8	74.4	-41.0	76.1	-45.2	78.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.0	14.1	12.0	23.2	37.3	50.9	57.4	61.9	60.0	51.2	38.9	24.0	11.3		
	DBStd	21.39	15.14	14.62	13.78	9.59	7.87	5.36	4.92	5.45	8.14	8.45	12.64	14.35		
	HDD50	5910	1113	1064	830	391	86	8	0	3	80	355	781	1199		
	HDD65	10271	1578	1484	1295	830	440	234	120	169	416	810	1231	1664		
	CDD50	1161	0	0	0	10	112	230	370	312	117	10	0	0		
	CDD65	48	0	0	0	0	1	6	25	13	3	0	0	0		
	CDH74	949	0	0	0	2	94	106	334	270	143	0	0	0		
	CDH80	149	0	0	0	0	11	11	54	38	35	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	17.0	0.9	0.5	0.7	1.2	1.9	2.8	3.4	2.1	1.3	0.8	0.7	0.7		
(15) Precipitation	PrecMax	24.3	2.5	1.0	1.9	2.4	3.1	5.8	6.9	3.8	3.2	1.7	2.5	1.5		
	PrecMin	10.3	0.1	0.0	0.2	0.0	0.6	1.0	1.5	0.9	0.0	0.2	0.0	0.2		
	PrecStd	3.1	0.7	0.3	0.5	0.6	0.8	1.5	1.3	0.7	0.9	0.5	0.7	0.4		
	PrecStd	3.1	0.7	0.3	0.5	0.6	0.8	1.5	1.3	0.7	0.9	0.5	0.7	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	42.8	53.6	71.7	81.6	80.9	85.7	83.7	84.6	70.8	56.7	42.4		
		MCWB	37.0	35.6	42.3	50.7	55.4	60.1	65.5	62.0	60.0	53.1	45.5	36.2		
	2%	DB	41.6	38.5	47.6	64.5	76.5	76.9	80.8	80.2	78.0	62.2	47.8	38.5		
		MCWB	35.5	33.2	38.9	47.0	53.6	60.1	65.2	63.2	57.8	48.5	39.7	33.1		
	5%	DB	38.4	35.5	43.0	58.1	72.0	73.5	77.7	77.1	72.6	57.3	42.7	35.0		
		MCWB	33.5	31.4	36.9	43.9	52.2	57.4	63.8	62.1	56.3	46.0	36.5	30.4		
	10%	DB	34.9	32.6	39.2	53.1	67.7	70.2	74.5	73.6	67.1	52.7	39.2	30.6		
		MCWB	31.3	29.2	33.9	41.6	50.4	56.1	62.1	61.3	53.9	43.6	34.6	27.3		
	0.4%	WB	37.7	36.4	43.7	51.1	57.5	64.5	70.1	68.6	61.7	53.6	46.1	37.1		
		MCDB	43.0	41.6	51.8	69.9	73.7	75.2	79.5	77.7	77.2	67.1	55.9	42.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.9	33.9	39.7	47.6	55.4	61.7	67.2	66.2	59.5	50.2	40.7	33.5		
		MCDB	40.9	37.9	46.7	63.6	71.3	72.1	77.2	75.3	75.2	60.5	46.9	37.9		
	5%	WB	33.9	31.6	36.8	44.8	53.6	59.6	65.0	63.8	57.0	46.9	37.3	30.8		
		MCDB	38.0	35.3	42.5	56.5	68.9	69.9	74.4	73.6	70.4	55.4	41.7	34.8		
	10%	WB	31.4	29.2	34.2	42.0	51.7	58.0	63.0	61.8	55.0	44.3	34.8	27.3		
		MCDB	35.2	32.8	38.8	51.9	65.1	67.6	72.6	71.4	65.5	51.4	38.6	30.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.7	18.2	17.3	19.3	23.1	20.6	21.1	22.8	23.1	19.3	15.7	15.6		
		MCDBR	16.3	20.5	20.4	29.1	30.9	26.4	26.2	28.7	34.0	27.4	19.7	18.2		
		MCWBR	12.3	16.1	13.4	15.1	13.5	12.0	13.0	14.1	16.1	15.4	13.3	14.5		
		MCDBR	17.4	20.4	19.9	27.3	27.4	22.2	23.7	25.2	30.1	25.5	18.5	18.0		
	5% WB	MCWBR	13.9	16.1	13.5	14.6	12.4	11.3	12.9	13.6	14.8	14.9	12.9	15.0		
		MCWBR	13.9	16.1	13.5	14.6	12.4	11.3	12.9	13.6	14.8	14.9	12.9	15.0		
(40) Clear-Sky Solar Irradiance	taub		0.257	0.260	0.307	0.322	0.340	0.349	0.351	0.359	0.305	0.279	0.251	0.242		
	taud		2.313	2.383	2.331	2.394	2.393	2.388	2.421	2.356	2.498	2.546	2.460	2.306		
	Ebn at Noon		234	275	279	289	288	286	283	273	279	266	241	218		
	Edh at Noon		18	23	31	33	35	36	34	34	26	20	16	15		
(44) All-Sky Solar Radiation	RadAvg		320	651	1132	1486	1821	1918	1974	1623	1121	652	317	235		
	RadStd		34	52	86	142	128	123	97	112	117	76	36	22		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page