

NEW SAREPTA AGCM, AB, Canada

WMO: 710670

Lat: 53.2624N

Lon: 113.1651W

Elev: 765

StdP: 92.47

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-30.7	-27.7	-34.2	0.2	-30.5	-31.1	0.2	-27.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	27.4	16.8	25.8	16.4	24.2	15.7	19.1	24.3	17.9	23.3	16.8	22.2	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	13.4	22.2	15.8	12.3	20.6	14.7	11.4	19.3	57.7	24.4	53.5	23.4	50.2	22.2	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	-34.5	30.8	3.2	1.6	-36.8	31.9	-38.7	32.8	-40.5	33.7	-42.9	34.8		
			-34.6	21.3	3.2	1.7	-36.9	22.5	-38.8	23.5	-40.6	24.5	-42.9	25.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-9.9	-11.1	-4.9	3.0	10.5	14.1	16.6	15.5	10.7	3.8	-4.5	-11.5
	DBStd	11.88	8.41	8.12	7.66	5.33	4.37	2.98	2.73	3.03	4.52	4.69	7.02	7.97
	HDD10.0	3283	618	591	461	217	48	4	0	2	44	197	434	666
	HDD18.3	5706	877	824	719	461	244	130	67	94	231	450	684	924
	CDD10.0	645	0	0	0	6	62	128	206	173	65	6	0	0
	CDD18.3	27	0	0	0	0	1	3	14	7	2	0	0	0
	CDH23.3	527	0	0	0	1	52	59	186	150	79	0	0	0
	CDH26.7	83	0	0	0	0	6	6	30	21	19	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	433	23	12	19	30	48	71	87	54	34	21	19	17
	PrecMax	618	63	25	47	61	78	148	174	97	81	42	64	39
	PrecMin	262	2	1	5	1	15	25	38	22	0	4	0	5
	PrecStd	80	17	7	12	15	21	39	33	18	24	12	17	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.9	6.0	12.0	22.0	27.5	27.2	29.8	28.7	29.2	21.6	13.7	5.8
		MCWB	2.8	2.0	5.7	10.4	13.0	15.6	18.6	16.7	15.5	11.7	7.5	2.3
	2%	DB	5.3	3.6	8.7	18.0	24.7	25.0	27.1	26.8	25.5	16.8	8.8	3.6
		MCWB	1.9	0.7	3.9	8.4	12.0	15.6	18.4	17.4	14.3	9.2	4.3	0.6
	5%	DB	3.6	1.9	6.1	14.5	22.2	23.1	25.4	25.0	22.5	14.1	5.9	1.7
		MCWB	0.8	-0.3	2.7	6.6	11.2	14.1	17.6	16.7	13.5	7.8	2.5	-0.9
	10%	DB	1.6	0.3	4.0	11.7	19.8	21.2	23.6	23.1	19.5	11.5	4.0	-0.8
		MCWB	-0.4	-1.6	1.1	5.3	10.2	13.4	16.7	16.3	12.2	6.4	1.4	-2.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	2.4	6.5	10.6	14.2	18.0	21.2	20.4	16.5	12.0	7.9	2.8
		MCDB	6.1	5.3	11.0	21.1	23.2	24.0	26.4	25.4	25.1	19.5	13.3	5.8
	2%	WB	2.2	1.0	4.3	8.7	13.0	16.5	19.5	19.0	15.3	10.1	4.8	0.8
		MCDB	5.0	3.3	8.1	17.5	21.8	22.3	25.1	24.1	24.0	15.9	8.3	3.3
	5%	WB	1.1	-0.2	2.7	7.1	12.0	15.4	18.3	17.6	13.9	8.3	3.0	-0.7
		MCDB	3.3	1.8	5.8	13.6	20.5	21.1	23.5	23.1	21.3	13.0	5.4	1.5
	10%	WB	-0.4	-1.6	1.2	5.6	10.9	14.4	17.2	16.6	12.8	6.8	1.6	-2.6
		MCDB	1.8	0.4	3.8	11.0	18.4	19.8	22.6	21.9	18.6	10.8	3.7	-0.9
Mean Daily Temperature Range		MDBR	9.3	10.1	9.6	10.7	12.8	11.4	11.7	12.7	12.8	10.7	8.7	8.7
	5% DB	MCDBR	9.1	11.4	11.3	16.2	17.2	14.7	14.5	15.9	18.9	15.2	11.0	10.1
		MCWBR	6.8	8.9	7.4	8.4	7.5	6.7	7.2	7.8	9.0	8.6	7.4	8.1
	5% WB	MCDBR	9.7	11.3	11.1	15.1	15.2	12.3	13.2	14.0	16.7	14.2	10.3	10.0
		MCWBR	7.7	8.9	7.5	8.1	6.9	6.3	7.1	7.6	8.2	8.3	7.2	8.3
Clear-Sky Solar Irradiance	taub	0.257	0.260	0.307	0.322	0.340	0.349	0.351	0.359	0.305	0.279	0.251	0.242	
	taud	2.313	2.383	2.331	2.394	2.393	2.388	2.421	2.356	2.498	2.546	2.460	2.306	
	Ebn at Noon	739	867	881	912	909	901	892	861	881	840	760	687	
	Edh at Noon	57	74	97	104	110	112	107	108	82	63	49	47	
All-Sky Solar Radiation	RadAvg	1.01	2.05	3.57	4.69	5.74	6.05	6.22	5.12	3.54	2.06	1.00	0.74	
	RadStd	0.11	0.16	0.27	0.45	0.40	0.39	0.30	0.35	0.37	0.24	0.11	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page