

JENNY LIND ISLAND, NU, Canada

WMO: 710710

Lat: 68.650N

Lon: 101.730W

Elev: 60

StdP: 14.66

Time Zone: -7.00 (NAM)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.3	-42.2	-40.2	0.5	-33.5	-38.9	0.6	-32.9	N/A	N/A	N/A	N/A	N/A	N/A	1.165

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	56.4	51.0	53.1	48.7	49.7	46.1	51.6	55.8	48.8	52.7	46.4	49.7	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.6	50.8	54.2	46.0	46.0	51.1	43.6	41.9	48.0	21.2	55.9	19.6	52.8	18.4	49.8	59.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-47.1	63.2	2.8	3.1	-49.1	65.4	-50.7	67.3	-52.3	69.0	-54.3	71.3
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec				
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)				
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.2	-29.6	-27.9	-20.9	-6.3	14.7	33.8	43.5	39.8	31.5	14.0	-11.0	-21.2	(6)		
(7)		DBStd	28.06	8.97	10.41	9.80	11.59	9.93	6.57	4.58	5.64	5.78	10.79	12.31	10.86	(7)		
(8)		HDD50	16353	2468	2181	2197	1688	1093	488	208	321	554	1117	1831	2207	(8)		
(9)		HDD65	21815	2933	2601	2662	2138	1558	937	666	781	1004	1582	2281	2672	(9)		
(10)		CDD50	14	0	0	0	0	0	1	7	6	0	0	0	0	(10)		
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)		
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)		
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)		
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)		
(15)	Precipitation	PrecAvg	4.6	0.1	0.1	0.1	0.1	0.2	0.4	0.8	1.1	0.7	0.5	0.2	0.1	(15)		
(16)		PrecMax	8.1	0.7	0.4	0.7	0.4	1.0	1.8	2.8	3.8	2.1	1.5	0.6	1.1	(16)		
(17)		PrecMin	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.0	0.0	0.0	(17)		
(18)		PrecStd	1.5	0.2	0.1	0.2	0.1	0.2	0.5	0.6	0.8	0.5	0.4	0.2	0.2	(18)		
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	9.1	11.8	25.4	34.4	56.2	61.1	60.4	46.0	36.9	23.9	18.9	(19)		
(20)			MCWB	5.9	8.5	11.2	24.4	33.5	49.7	54.9	53.8	43.1	36.4	23.6	18.3	(20)		
(21)		2%	DB	-4.8	-1.8	5.3	20.7	33.0	51.6	57.2	55.7	43.6	32.6	17.1	12.3	(21)		
(22)			MCWB	-5.3	-2.7	4.6	20.0	32.5	46.6	51.9	50.5	42.0	32.2	16.2	11.6	(22)		
(23)		5%	DB	-9.9	-6.9	-0.2	16.3	31.8	46.1	54.3	51.8	41.6	31.3	12.8	3.8	(23)		
(24)			MCWB	-10.2	-7.3	-0.9	15.8	31.5	42.7	49.7	48.3	40.6	31.0	12.2	3.2	(24)		
(25)		10%	DB	-15.9	-12.7	-5.0	11.6	29.4	42.7	51.2	48.0	39.0	29.2	7.7	-6.4	(25)		
(26)			MCWB	-16.3	-13.2	-5.5	11.0	28.9	40.2	47.3	44.9	38.0	28.8	7.1	-7.0	(26)		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	9.6	11.8	24.6	33.9	50.6	55.9	54.7	44.0	36.4	23.6	18.7	(27)		
(28)			MCDWB	11.0	10.4	12.5	25.3	34.1	55.7	60.8	59.7	44.9	36.8	24.0	18.8	(28)		
(29)		2%	WB	-2.2	1.3	5.4	20.1	32.7	46.4	52.5	50.9	42.3	32.4	16.6	13.2	(29)		
(30)			MCDWB	-1.7	1.9	5.9	20.7	33.0	51.8	56.8	54.7	43.3	32.5	17.4	13.8	(30)		
(31)		5%	WB	-6.7	-4.3	0.2	15.7	31.5	43.0	49.8	48.1	40.5	31.0	12.4	4.2	(31)		
(32)			MCDWB	-6.3	-3.6	0.7	16.2	31.8	46.0	53.6	51.6	41.6	31.2	13.0	4.9	(32)		
(33)		10%	WB	-10.6	-8.3	-4.2	11.0	29.0	40.3	47.6	45.2	38.2	28.8	7.4	-5.4	(33)		
(34)			MCDWB	-10.1	-7.9	-3.7	11.6	29.5	42.7	51.2	47.6	39.0	29.1	8.0	-5.0	(34)		
(35)	Mean Daily Temperature Range			MDBR	9.1	9.9	10.4	12.4	10.0	6.4	9.1	7.3	4.6	8.1	8.7	9.5	(35)	
(36)		5% DB			MCDBR	17.9	16.2	14.8	12.9	9.0	12.3	14.6	14.0	6.7	7.4	10.1	11.3	(36)
(37)					MCWBR	15.9	15.9	14.6	12.9	8.5	9.4	11.0	10.3	5.9	7.4	10.1	11.6	(37)
(38)		5% WB			MCDBR	16.8	18.4	15.7	12.8	8.4	11.9	14.2	13.4	6.5	6.8	10.5	11.1	(38)
(39)					MCWBR	16.5	18.1	15.6	12.9	8.5	9.2	11.2	10.0	5.9	7.1	10.5	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.148	0.206	0.238	0.286	0.305	0.335	0.353	0.329	0.297	0.242	0.156	N/A	(40)		
(41)		taud		1.874	2.034	2.173	2.072	2.072	2.159	2.281	2.504	2.513	2.178	1.887	N/A	(41)		
(42)		Ebn at Noon		33	188	257	270	278	271	262	259	239	168	23	0	(42)		
(43)		Edh at Noon		2	14	24	36	41	39	34	24	18	12	2	0	(43)		
(44)	All-Sky Solar Radiation	RadAvg		7	150	657	1417	2084	2154	1824	1120	519	170	25	0	(44)		
(45)		RadStd		1	7	26	58	98	123	115	87	64	28	2	0	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	+1.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page