

JENNY LIND ISLAND, NU, Canada

WMO: 710710

Lat: 68.650N

Lon: 101.730W

Elev: 18

StdP: 101.11

Time Zone: -7.00 (NAM)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.4	-41.2	-40.1	0.1	-36.4	-39.4	0.1	-36.0	N/A	N/A	N/A	N/A	N/A	N/A	1.165

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	13.5	10.5	11.7	9.3	9.8	7.8	10.9	13.2	9.3	11.5	8.0	9.8	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	7.3	12.3	7.8	6.6	10.6	6.4	6.0	8.9	31.5	13.3	27.8	11.6	24.9	9.9	15.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-43.9	17.3	1.6	1.7	-45.0	18.6	-45.9	19.6	-46.8	20.6	-47.9	21.8
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.9	-34.2	-33.3	-29.4	-21.3	-9.6	1.0	6.4	4.3	-0.3	-10.0	-23.9	-29.6
	DBStd	15.59	4.99	5.79	5.45	6.44	5.52	3.65	2.54	3.13	3.21	6.00	6.84	6.03
	HDD10.0	9085	1371	1212	1221	938	607	271	116	178	308	621	1017	1226
	HDD18.3	12119	1629	1445	1479	1188	866	521	370	434	558	879	1267	1484
	CDD10.0	8	0	0	0	0	0	1	4	3	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	116	2	3	3	3	6	11	21	28	18	13	5	3
	PrecMax	207	18	11	17	11	26	46	71	96	53	37	16	28
	PrecMin	47	0	0	0	0	0	0	0	2	4	0	0	0
	PrecStd	39	4	3	4	3	6	12	16	20	12	10	4	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-14.1	-12.7	-11.2	-3.7	1.3	13.4	16.2	15.8	7.8	2.7	-4.5	-7.3
		MCWB	-14.5	-13.1	-11.5	-4.2	0.8	9.8	12.7	12.1	6.2	2.5	-4.7	-7.6
	2%	DB	-20.5	-18.8	-14.8	-6.3	0.6	10.9	14.0	13.2	6.4	0.3	-8.3	-11.0
		MCWB	-20.7	-19.3	-15.2	-6.6	0.3	8.1	11.0	10.3	5.6	0.1	-8.8	-11.4
	5%	DB	-23.3	-21.6	-17.9	-8.7	-0.1	7.9	12.4	11.0	5.4	-0.4	-10.7	-15.7
		MCWB	-23.5	-21.8	-18.3	-9.0	-0.3	5.9	9.8	9.1	4.8	-0.6	-11.0	-16.0
	10%	DB	-26.6	-24.8	-20.6	-11.3	-1.4	6.0	10.7	8.9	3.9	-1.6	-13.5	-21.3
		MCWB	-26.8	-25.1	-20.8	-11.7	-1.7	4.6	8.5	7.2	3.3	-1.8	-13.9	-21.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-12.0	-12.4	-11.2	-4.1	1.0	10.3	13.3	12.6	6.6	2.5	-4.7	-7.4
		MCDB	-11.7	-12.0	-10.8	-3.7	1.2	13.2	16.0	15.4	7.2	2.7	-4.5	-7.3
	2%	WB	-19.0	-17.1	-14.8	-6.6	0.4	8.0	11.4	10.5	5.7	0.2	-8.5	-10.5
		MCDB	-18.7	-16.7	-14.5	-6.3	0.5	11.0	13.8	12.6	6.3	0.3	-8.1	-10.1
	5%	WB	-21.5	-20.2	-17.7	-9.0	-0.3	6.1	9.9	8.9	4.7	-0.5	-10.9	-15.4
		MCDB	-21.3	-19.8	-17.4	-8.8	-0.1	7.8	12.0	10.9	5.3	-0.4	-10.6	-15.0
	10%	WB	-23.6	-22.4	-20.1	-11.7	-1.7	4.6	8.7	7.3	3.5	-1.8	-13.7	-20.8
		MCDB	-23.4	-22.2	-19.8	-11.3	-1.4	5.9	10.7	8.7	3.9	-1.6	-13.3	-20.6
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	5.8	6.9	5.6	3.5	5.0	4.0	2.6	4.5	4.9	5.3
		MCDBR	9.9	9.0	8.2	7.2	5.0	6.9	8.1	7.8	3.7	4.1	5.6	6.3
		MCWBR	8.9	8.9	8.1	7.2	4.7	5.2	6.1	5.7	3.3	4.1	5.6	6.4
	5% WB	MCDBR	9.3	10.2	8.7	7.1	4.7	6.6	7.9	7.4	3.6	3.8	5.8	6.2
		MCWBR	9.2	10.1	8.7	7.2	4.7	5.1	6.2	5.6	3.3	3.9	5.9	6.3
Clear-Sky Solar Irradiance	taub	0.148	0.206	0.238	0.286	0.305	0.335	0.353	0.329	0.297	0.242	0.156	N/A	
	taud	1.874	2.034	2.173	2.072	2.072	2.159	2.281	2.504	2.513	2.178	1.887	N/A	
	Ebn at Noon	103	594	809	852	875	855	826	818	752	529	73	0	
	Edh at Noon	6	45	76	115	130	124	107	77	58	39	5	0	
All-Sky Solar Radiation	RadAvg	0.02	0.47	2.07	4.47	6.57	6.79	5.75	3.53	1.64	0.54	0.08	0.00	
	RadStd	0.00	0.02	0.08	0.18	0.31	0.39	0.36	0.27	0.20	0.09	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)		N/A	+0.84	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page