

URANIUM CITY, SK, Canada

WMO: 710760

Lat: 59.562N

Lon: 108.478W

Elev: 318

StdP: 97.56

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.3	-38.0	-43.6	0.1	-39.5	-41.5	0.1	-37.5	6.7	-18.0	6.1	-18.8	1.6	70	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	26.6	16.2	24.9	15.6	23.1	14.9	17.8	23.6	16.8	22.2	15.9	21.1	2.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.7	11.6	19.3	14.7	10.9	18.6	13.7	10.1	18.0	51.6	23.7	48.5	22.1	45.8	21.2	21.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.2	5.4	-43.1	29.6	2.4	1.9	-44.8	30.9	-46.2	32.0	-47.6	33.1	-49.3	34.4		
			-42.4	19.4	2.2	0.8	-44.0	20.0	-45.3	20.5	-46.6	21.0	-48.2	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.6	-23.6	-20.4	-13.6	-3.2	6.0	13.8	16.4	14.2	8.4	0.1	-10.5	-19.5
	DBStd	15.37	8.52	7.93	8.68	7.26	5.54	4.12	3.12	3.38	4.30	4.61	6.83	8.58
	HDD10.0	5107	1042	851	733	397	147	13	1	6	81	306	616	914
	HDD18.3	7658	1301	1084	991	647	383	143	76	133	298	564	866	1173
	CDD10.0	519	0	0	0	1	23	128	198	137	32	1	0	0
	CDD18.3	29	0	0	0	0	1	8	16	5	0	0	0	0
	CDH23.3	331	0	0	0	0	9	99	167	51	4	0	0	0
	CDH26.7	41	0	0	0	0	1	12	22	6	0	0	0	0
Wind	WSAvg	2.4	1.9	2.1	2.4	2.7	2.8	2.6	2.4	2.4	2.5	2.6	2.5	1.9
Precipitation	PrecAvg	379	22	15	20	22	23	40	56	56	40	39	31	23
	PrecMax	497	39	34	36	92	56	110	110	124	90	88	67	58
	PrecMin	196	4	2	7	1	4	15	6	18	16	4	9	7
	PrecStd	66	9	8	9	19	15	21	28	28	20	20	15	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.2	-0.8	7.0	16.3	24.5	28.2	28.8	27.1	22.9	14.6	4.1	-1.3
		MCWB	-2.8	-2.0	2.4	8.0	12.8	15.8	17.6	17.3	15.1	10.0	2.4	-1.7
	2%	DB	-6.0	-3.9	4.0	12.2	21.2	26.1	26.9	24.7	19.7	10.7	1.5	-3.8
		MCWB	-6.3	-4.6	0.7	5.6	11.2	15.1	16.7	16.4	13.5	7.1	0.6	-4.2
	5%	DB	-8.9	-6.3	1.3	9.5	18.5	24.1	25.3	22.6	17.3	8.4	0.1	-5.6
		MCWB	-9.3	-6.9	-0.9	4.3	9.9	14.4	16.1	15.6	12.4	6.0	-0.5	-6.0
	10%	DB	-11.5	-8.9	-1.1	7.1	15.6	22.0	23.5	20.8	15.2	6.5	-1.4	-8.0
		MCWB	-11.9	-9.5	-2.7	3.0	8.4	13.5	15.5	14.7	11.3	4.8	-2.0	-8.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.4	-1.8	3.0	8.5	13.9	17.7	19.2	19.0	15.9	10.7	2.6	-1.6
		MCDB	-2.1	-1.3	6.6	15.5	21.8	24.3	26.0	24.7	22.1	14.2	3.7	-1.4
	2%	WB	-6.3	-4.6	1.0	6.1	11.9	16.2	18.2	17.6	14.1	7.5	0.7	-4.1
		MCDB	-6.1	-4.0	3.4	11.5	19.5	23.1	24.2	22.7	18.4	9.7	1.3	-3.8
	5%	WB	-9.2	-6.9	-0.8	4.6	10.5	15.2	17.2	16.5	12.9	6.2	-0.5	-5.9
		MCDB	-8.8	-6.3	1.3	9.2	17.4	21.8	22.7	21.0	16.5	8.3	0.1	-5.6
	10%	WB	-11.8	-9.5	-2.9	3.1	8.9	14.3	16.3	15.5	11.8	4.8	-2.0	-8.3
		MCDB	-11.5	-9.0	-1.1	6.9	14.8	20.6	21.5	19.4	14.9	6.5	-1.4	-8.0
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.7	13.0	11.9	11.5	11.3	10.7	9.6	8.8	6.0	6.4	8.2
		MCDBR	9.3	10.9	13.9	13.9	15.8	14.3	14.0	13.1	12.4	9.2	7.1	8.5
		MCWBR	9.2	10.2	11.0	8.5	8.1	6.0	5.8	6.2	7.0	6.4	6.4	8.3
	5% WB	MCDBR	9.3	10.7	13.3	13.4	14.4	12.0	11.4	11.2	11.2	8.7	6.8	8.5
		MCWBR	9.2	10.1	10.5	8.2	7.6	5.5	5.4	5.9	6.7	6.3	6.2	8.3
Clear-Sky Solar Irradiance	taub	0.211	0.257	0.262	0.317	0.331	0.356	0.385	0.347	0.305	0.276	0.244	0.175	
	taud	2.153	2.204	2.300	2.308	2.453	2.401	2.363	2.462	2.596	2.516	2.103	2.065	
	Ebn at Noon	623	765	889	887	900	876	838	850	843	760	531	534	
	Edh at Noon	41	70	88	106	99	107	109	91	68	53	44	29	
All-Sky Solar Radiation	RadAvg	0.36	1.10	2.68	4.39	5.43	6.12	5.50	4.26	2.72	1.22	0.40	0.20	
	RadStd	0.05	0.11	0.20	0.33	0.46	0.42	0.34	0.24	0.24	0.12	0.05	0.02	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page