

FORT PROVIDENCE, NT, Canada

WMO: 710870

Lat: 61.317N

Lon: 117.602W

Elev: 530

StdP: 14.42

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.8	-33.8	-46.7	0.4	-38.5	-41.4	0.5	-33.4	12.2	4.5	10.5	-0.9	1.2	80	0.660

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	83.7	62.6	80.2	61.4	76.9	60.1	65.1	78.8	63.4	76.3	61.8	73.6	6.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.2	79.4	68.9	58.4	74.2	67.5	56.6	69.6	66.1	30.3	79.2	29.1	76.4	27.9	73.9	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.7	11.6	9.8	-43.1	89.3	3.8	3.0	-45.8	91.5	-48.0	93.3	-50.1	95.0	-52.9	97.2		
(5)			-43.2	68.1	3.7	2.1	-45.9	69.6	-48.1	70.8	-50.1	72.0	-52.8	73.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	-9.3	-2.6	7.5	28.7	44.9	57.4	62.8	58.4	47.8	32.1	10.2	-4.9	(6)
(7)		DBStd	27.75	13.93	12.43	14.96	12.18	8.97	7.18	5.88	6.63	7.89	8.33	11.55	13.92	(7)
(8)		HDD50	9095	1840	1473	1317	641	206	18	1	10	133	558	1195	1703	(8)
(9)		HDD65	13622	2305	1893	1782	1090	625	243	112	222	516	1021	1645	2168	(9)
(10)		CDD50	1024	0	0	0	1	46	239	398	270	68	2	0	0	(10)
(11)		CDD65	77	0	0	0	0	1	14	44	17	1	0	0	0	(11)
(12)		CDH74	1390	0	0	0	0	57	341	662	304	26	0	0	0	(12)
(13)		CDH80	321	0	0	0	0	9	78	163	67	4	0	0	0	(13)
(14)	Wind	WSAvg	4.2	2.9	3.3	4.1	5.0	5.4	4.7	4.5	4.6	4.8	4.5	3.8	2.9	(14)
(15)	Precipitation	PrecAvg	14.0	0.7	0.6	0.6	0.6	1.1	2.0	2.4	2.0	1.4	1.0	0.9	0.8	(15)
(16)		PrecMax	17.8	1.3	1.0	1.2	0.9	1.9	3.8	4.2	3.6	2.9	1.7	1.7	1.3	(16)
(17)		PrecMin	9.6	0.2	0.2	0.1	0.2	0.2	0.3	1.1	0.4	0.4	0.3	0.3	0.4	(17)
(18)		PrecStd	1.9	0.3	0.2	0.3	0.2	0.4	0.7	0.8	0.7	0.6	0.4	0.3	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	38.2	50.6	63.7	80.6	87.0	89.2	86.5	77.6	62.1	44.0	32.9	(19)
(20)			MCWB	29.2	33.1	39.9	47.1	57.1	62.6	65.6	64.9	59.7	50.7	36.6	29.5	(20)
(21)		2%	DB	22.2	28.4	42.9	56.9	73.7	81.9	84.2	81.2	71.3	52.6	33.0	24.7	(21)
(22)			MCWB	21.0	25.9	35.4	44.0	54.2	60.5	63.6	62.5	56.2	44.2	31.3	23.9	(22)
(23)		5%	DB	14.8	20.4	36.7	52.2	67.9	77.8	80.9	77.1	66.8	47.5	29.2	19.0	(23)
(24)			MCWB	14.0	18.6	31.4	41.4	51.5	59.2	62.5	60.8	54.0	41.7	28.0	18.3	(24)
(25)		10%	DB	9.3	15.1	30.6	47.5	62.4	73.9	77.5	73.3	62.1	43.2	25.7	14.9	(25)
(26)			MCWB	8.5	13.8	27.2	38.6	48.6	57.4	61.3	59.4	52.3	39.5	24.7	14.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.2	33.5	40.1	47.6	58.3	65.2	68.4	67.1	61.7	50.9	36.4	29.6	(27)
(28)			MADB	33.3	38.1	49.6	61.9	77.2	80.7	83.3	81.6	74.4	60.6	42.5	32.5	(28)
(29)		2%	WB	21.2	25.6	35.5	44.4	55.0	62.9	65.6	64.3	58.0	44.9	31.7	23.8	(29)
(30)			MADB	22.6	28.4	42.2	56.0	72.4	77.0	79.0	77.5	68.0	50.8	32.9	24.9	(30)
(31)		5%	WB	13.9	18.8	31.7	42.0	52.1	60.9	64.2	62.3	55.4	42.2	28.0	18.4	(31)
(32)			MADB	14.6	20.4	36.6	51.5	67.0	74.1	77.3	73.6	64.4	46.8	29.2	19.0	(32)
(33)		10%	WB	8.5	13.8	27.2	39.0	49.4	58.9	62.6	60.3	53.1	39.5	24.6	14.2	(33)
(34)			MADB	9.3	15.2	30.8	47.0	61.5	71.0	74.6	71.1	61.4	43.2	25.6	14.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.7	19.7	24.9	23.4	23.5	24.9	23.3	22.1	19.9	12.9	13.0	13.5	(35)
(36)			MCDBR	20.1	25.1	28.4	28.2	33.2	32.1	29.2	29.7	28.0	21.7	15.7	17.7	(36)
(37)			MCWBR	19.0	22.4	21.3	17.2	17.2	14.8	12.7	14.2	14.9	14.1	13.7	16.9	(37)
(38)		5% WB	MADB	20.2	24.8	27.5	26.7	31.2	27.4	26.1	26.1	25.6	20.2	15.4	17.7	(38)
(39)			MCWBR	19.1	22.1	20.7	16.7	16.6	13.5	12.5	13.4	14.7	13.6	13.6	16.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.198	0.243	0.267	0.321	0.346	0.353	0.379	0.353	0.309	0.275	0.201	0.158	(40)	
(41)		taud	2.120	2.272	2.278	2.274	2.430	2.431	2.380	2.485	2.560	2.523	2.174	1.964	(41)	
(42)		Ebn at Noon	181	243	275	277	279	277	266	265	260	233	178	140	(42)	
(43)		Edh at Noon	11	19	27	34	32	32	33	28	22	16	10	7	(43)	
(44)	All-Sky Solar Radiation	RadAvg	113	394	962	1590	1810	1934	1736	1349	859	366	118	57	(44)	
(45)		RadStd	7	24	62	103	132	167	108	80	82	39	18	5	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	+32	
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page