

ROWLEY ISLAND, NU, Canada

WMO: 710880

Lat: 69.067N

Lon: 79.065W

Elev: 41

StdP: 100.83

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.3	-35.9	N/A	N/A	N/A	N/A	N/A	N/A	15.6	-22.6	14.0	-24.7	4.5	320	1.141

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	13.7	N/A	12.0	N/A	10.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.8	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.3	11.9	DB	-39.0	16.6	2.0	2.0	-40.4	18.1	-41.6	19.3	-42.7	20.4	-44.2	21.8	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.0	-27.6	-27.9	-24.3	-16.6	-6.6	1.1	7.0	5.4	0.3	-5.9	-15.4	-22.7	(6)
(7)		DBStd	13.19	5.47	5.50	5.71	5.17	4.35	2.74	2.41	2.70	2.52	4.13	6.21	6.00	(7)
(8)		HDD10.0	7664	1164	1060	1063	798	514	267	98	143	291	492	761	1013	(8)
(9)		HDD18.3	10701	1423	1293	1322	1048	772	517	352	400	541	750	1011	1272	(9)
(10)		CDD10.0	6	0	0	0	0	0	0	4	2	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.0	5.3	5.3	5.5	5.8	5.8	5.6	5.9	6.7	7.2	6.7	5.9	(14)	
(15)	Precipitation	PrecAvg	242	9	8	10	13	15	19	31	45	32	30	17	13	(15)
(16)		PrecMax	432	30	25	29	59	34	40	98	69	79	67	64	30	(16)
(17)		PrecMin	125	1	1	1	2	3	7	10	11	6	7	2	4	(17)
(18)		PrecStd	74	7	6	8	12	8	9	17	15	16	15	13	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.4	-8.3	-6.5	-0.4	2.6	12.0	16.4	15.6	8.2	1.5	-1.3	-3.8	(19)
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	-12.7	-13.7	-10.9	-3.8	0.9	8.7	14.4	13.1	6.0	0.6	-2.7	-7.7	(21)
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	-16.1	-17.1	-13.1	-6.4	0.2	6.7	12.9	11.4	4.7	0.0	-4.5	-11.1	(23)
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)		10%	DB	-19.5	-19.8	-15.6	-8.8	-0.6	4.9	11.5	9.8	3.7	-0.7	-6.5	-13.9	(25)
(26)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)
(28)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)
(30)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)
(32)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)		10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)
(34)			MCDWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)
(35)	Mean Daily Temperature Range		MDBR	5.5	5.5	6.5	7.1	4.9	3.6	6.2	5.3	3.0	3.7	5.6	5.9	(35)
(36)		5% DB	MCDBR	8.6	8.3	8.6	7.5	4.9	6.7	8.6	8.0	4.7	2.9	6.2	8.3	(36)
(37)				MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)
(38)			5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(39)				MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.162	0.198	0.244	0.315	0.322	0.320	0.342	0.324	0.292	0.235	0.157	N/A	(40)	
(41)		taud	1.844	2.031	2.142	1.965	2.089	2.243	2.357	2.506	2.520	2.201	1.923	N/A	(41)	
(42)		Ebn at Noon	53	594	791	805	855	872	839	820	755	530	53	0	(42)	
(43)		Edh at Noon	5	43	77	128	128	113	99	76	56	36	4	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.02	0.46	2.12	4.47	6.12	6.64	5.56	3.66	1.81	0.50	0.06	0.00	(44)	
(45)		RadStd	0.00	0.04	0.07	0.15	0.28	0.38	0.43	0.24	0.19	0.06	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page