

CAPE HOOPER, NU, Canada

WMO: 710930

Lat: 68.472N

Lon: 66.798W

Elev: 1280

StdP: 14.03

Time Zone: -5.00 (NAE)

Period: 82-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.8	-28.8	-38.1	0.7	-31.5	-36.3	0.7	-30.1	52.3	-13.9	48.0	-16.4	17.1	260	1.157

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	57.2	49.4	53.8	45.9	50.8	44.4	48.6	55.4	46.0	51.9	43.7	49.0	11.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
43.5	43.7	50.4	41.4	40.2	48.3	39.4	37.2	46.5	19.9	55.6	18.5	52.1	17.3	48.9	62.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.3	42.7	36.7	-32.8	60.8	5.0	3.5	-36.3	63.3	-39.2	65.4	-42.0	67.3	-45.6	69.8
			-33.9	52.5	1.6	5.2	-35.0	56.2	-35.9	59.3	-36.8	62.2	-37.9	65.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-12.9	-15.3	-10.6	1.7	17.6	33.0	41.5	38.9	30.2	20.2	6.8	-5.4
	DBStd	21.57	9.01	9.02	10.36	9.58	7.92	6.61	7.77	6.41	5.14	6.47	9.32	9.76
	HDD50	13792	1951	1828	1879	1449	1003	511	284	351	595	925	1297	1719
	HDD65	19242	2416	2248	2344	1899	1468	961	730	810	1045	1390	1747	2184
	CDD50	24	0	0	0	0	0	0	19	5	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.3	15.7	14.9	14.5	13.7	12.9	10.9	10.5	11.9	15.3	17.8	17.6	16.2
Precipitation	PrecAvg	10.4	0.3	0.4	0.3	0.6	0.9	0.8	1.1	1.4	1.5	1.4	1.1	0.4
	PrecMax	19.7	0.9	2.1	0.9	2.4	3.2	3.1	3.3	3.7	4.2	3.1	3.6	1.3
	PrecMin	4.5	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.2	0.5	0.1	0.0
	PrecStd	3.4	0.3	0.6	0.3	0.5	0.7	0.7	0.8	0.9	0.9	0.6	0.8	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	15.6	22.6	28.8	41.4	53.0	62.8	59.3	46.9	38.9	28.7	27.2
		MCWB	17.1	15.5	22.1	27.4	38.4	44.7	54.4	48.0	42.9	38.8	28.0	24.6
	2%	DB	8.8	5.9	14.2	23.7	36.1	49.5	59.1	54.5	43.3	32.7	25.2	17.9
		MCWB	8.3	5.0	13.1	22.8	34.7	42.9	50.3	47.1	40.2	32.4	24.6	17.0
	5%	DB	3.5	0.8	8.3	19.4	31.2	46.5	56.3	51.6	40.6	29.6	22.6	12.4
		MCWB	2.9	0.1	7.5	18.6	30.2	40.3	48.3	45.6	37.7	29.0	21.9	11.5
	10%	DB	-0.7	-3.1	3.8	15.1	27.9	43.2	53.3	48.9	37.8	27.8	19.5	7.6
		MCWB	-1.2	-3.8	3.1	14.2	27.3	38.8	45.5	43.9	35.0	27.3	18.8	6.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	22.4	15.7	25.4	37.7	46.2	56.1	48.5	44.2	40.0	25.0	18.9
		MCDB	11.1	23.1	16.7	25.8	39.1	49.9	58.6	52.0	47.2	41.8	25.3	19.9
	2%	WB	4.1	3.8	11.0	20.5	34.7	43.3	50.5	45.7	40.9	30.3	22.1	12.4
		MCDB	4.6	4.5	12.1	21.2	36.5	48.2	58.7	50.9	43.4	30.6	22.5	13.1
	5%	WB	-0.7	-1.5	4.5	16.4	31.0	41.6	48.0	43.6	38.0	27.7	19.1	6.7
		MCDB	-0.2	-0.9	5.0	17.3	31.9	46.6	55.3	47.4	40.4	28.1	19.7	7.3
	10%	WB	-4.8	-5.2	-2.3	12.6	27.2	39.5	45.8	41.8	34.9	25.4	15.4	2.9
		MCDB	-4.3	-4.5	-1.8	13.4	27.7	43.6	52.2	45.3	36.6	25.7	16.0	3.6
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.7	7.6	7.2	6.3	6.9	8.9	7.1	4.4	4.9	6.4	6.9
		MCDBR	10.2	11.3	12.2	11.5	9.6	11.1	11.0	10.3	8.7	6.7	8.6	11.5
		MCWBR	11.5	12.2	12.7	11.1	8.3	7.4	8.3	7.3	6.2	6.6	8.7	13.0
	5% WB	MCDBR	10.5	11.0	12.3	10.4	9.4	9.2	10.2	8.5	7.8	6.3	8.8	10.0
		MCWBR	10.2	10.8	12.1	10.3	8.6	7.6	8.4	7.3	6.5	6.2	8.9	10.0
Clear-Sky Solar Irradiance	taub		0.145	0.188	0.234	0.281	0.305	0.313	0.321	0.316	0.283	0.226	N/A	N/A
	taud		1.866	2.079	2.175	2.070	2.096	2.207	2.362	2.478	2.475	2.210	N/A	N/A
	Ebn at Noon		38	206	260	272	278	280	274	264	244	181	N/A	0
	Edh at Noon		2	14	24	36	40	37	31	25	19	12	N/A	0
All-Sky Solar Radiation	RadAvg		9	166	693	1466	2068	2085	1715	1144	642	223	26	0
	RadStd		1	7	30	50	78	159	115	57	41	13	2	0

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.49	+2.57	N/A	N/A	N/A	N/A	-529	-529	N/A	N/A
(47)	Regional (3 neighbors)	+1.28	+2.52	N/A	N/A	N/A	N/A	-459	-472	N/A	N/A

Nomenclature: See separate page