

CAPE DYER, NU, Canada

WMO: 710940

Lat: 66.665N

Lon: 61.358W

Elev: 725

StdP: 92.91

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-33.5	-31.5	N/A	N/A	N/A	N/A	N/A	N/A	24.6	-16.9	21.9	-18.8	3.9	0	1.138

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	12.3	N/A	10.6	N/A	9.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.4	14.8	DB	-35.0	14.7	1.5	2.3	-36.1	16.4	-37.0	17.7	-37.8	19.0	-39.0	20.7	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.8	-22.2	-22.4	-20.4	-14.7	-6.7	0.0	4.8	3.5	-2.2	-7.2	-12.5	-18.1
	DBStd	10.58	5.31	6.09	6.31	5.62	4.58	3.68	3.49	3.35	2.80	3.11	4.24	5.41
	HDD10.0	7220	999	907	943	741	517	301	164	202	367	533	676	871
	HDD18.3	10256	1257	1140	1202	991	775	551	418	459	617	792	926	1129
	CDD10.0	6	0	0	0	0	0	1	4	1	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	5.9	6.5	6.2	6.1	6.0	5.3	5.6	4.9	5.3	6.2	6.2	6.9	6.3
(15) Precipitation	PrecAvg	575	46	31	25	27	36	36	41	63	77	76	59	58
	PrecMax	791	105	80	60	49	57	69	99	94	205	126	158	140
	PrecMin	346	18	10	3	10	17	16	5	28	30	44	28	20
	PrecStd	106	25	16	14	11	10	12	19	16	37	21	26	31
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.5	-3.9	-2.5	1.5	7.9	12.1	15.6	13.2	7.2	2.9	-0.6	-2.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-7.8	-6.8	-5.1	-1.9	3.9	9.1	13.2	11.4	5.0	-0.3	-3.9	-4.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-11.1	-10.9	-8.8	-4.7	1.5	7.0	11.6	9.7	3.2	-1.3	-5.4	-8.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-14.1	-14.2	-11.8	-7.0	-0.5	5.1	10.0	8.4	1.5	-2.7	-6.8	-10.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.0	4.9	4.7	4.2	3.9	4.3	4.1	2.9	2.9	3.3	4.3
		MCDBR	7.2	6.9	7.1	6.3	5.9	6.1	5.5	5.5	5.4	4.5	4.7	6.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.137	0.186	0.221	0.264	0.287	0.293	0.302	0.303	0.265	0.222	N/A	N/A
	taud		1.873	2.148	2.204	2.115	2.123	2.248	2.424	2.485	2.490	2.300	N/A	N/A
	Ebn at Noon		305	729	870	898	909	913	897	860	819	661	N/A	0
	Edh at Noon		14	47	78	114	126	115	94	80	61	40	N/A	0
(44) All-Sky Solar Radiation	RadAvg		0.07	0.71	2.47	4.75	6.38	6.65	5.33	3.54	2.05	0.79	0.13	0.00
	RadStd		0.01	0.04	0.11	0.26	0.22	0.61	0.50	0.29	0.21	0.07	0.01	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.61	+1.23	N/A	N/A	N/A	N/A	-230	-238	N/A	N/A

Nomenclature: See separate page