

POND INLET, NU, Canada

WMO: 710950

Lat: 72.693N

Lon: 77.957W

Elev: 62

StdP: 100.59

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-42.0	-40.5	-45.1	0.0	-41.2	-44.6	0.0	-40.5	12.2	-23.0	8.4	-21.1	2.1	180	1.025

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	13.9	9.6	12.1	8.6	10.6	7.6	10.2	13.0	9.0	11.6	7.8	10.3	2.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	6.9	11.0	7.1	6.3	10.1	5.9	5.8	9.0	30.0	13.2	27.1	11.7	24.6	10.3	15.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.1	7.4	DB	-43.3	16.9	1.7	2.2	-44.6	18.5	-45.6	19.8	-46.6	21.1	-47.8	22.7	(4)
(5)			WB	-43.3	11.9	1.6	1.5	-44.4	13.0	-45.4	13.8	-46.2	14.7	-47.4	15.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-13.4	-31.7	-32.8	-29.3	-20.5	-7.8	2.9	7.1	5.7	-0.8	-8.5	-19.5	-27.1	(6)
(7)		DBStd	15.30	5.96	5.53	6.28	5.75	5.42	2.95	2.57	2.82	3.34	4.71	6.95	6.75	(7)
(8)		HDD10.0	8555	1291	1198	1217	914	552	212	98	137	325	574	886	1150	(8)
(9)		HDD18.3	11587	1549	1431	1476	1164	810	462	350	393	575	833	1136	1408	(9)
(10)		CDD10.0	10	0	0	0	0	0	1	6	3	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	2.7	2.0	2.0	2.2	2.2	2.5	2.9	2.7	2.8	3.4	4.1	3.0	2.2	(14)
(15)	Precipitation	PrecAvg	193	4	3	6	12	11	16	31	38	19	22	11	8	(15)
(16)		PrecMax	384	15	14	28	53	39	76	77	94	44	67	37	31	(16)
(17)		PrecMin	103	0	0	0	0	1	0	1	0	2	1	1	0	(17)
(18)		PrecStd	67	4	3	7	12	9	17	21	26	10	16	10	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.9	-12.7	-6.3	-3.1	3.2	13.0	17.4	15.2	7.3	2.5	-1.9	-6.9	(19)
(20)			MCWB	-11.9	-13.4	-7.3	-3.7	1.2	7.9	12.1	10.8	4.6	0.7	-3.3	-7.8	(20)
(21)		2%	DB	-15.6	-18.3	-13.5	-7.1	1.5	10.3	15.0	12.9	5.7	0.3	-4.0	-10.3	(21)
(22)			MCWB	-16.1	-18.8	-13.9	-7.8	-0.1	6.6	10.2	9.4	3.7	-0.8	-5.2	-10.9	(22)
(23)		5%	DB	-19.1	-21.3	-17.7	-9.4	0.4	8.5	13.2	11.3	4.7	-0.9	-6.6	-13.4	(23)
(24)			MCWB	-19.5	-21.6	-18.1	-10.1	-0.9	5.4	9.1	8.4	3.0	-1.9	-7.5	-13.9	(24)
(25)		10%	DB	-22.9	-24.4	-20.4	-11.8	-0.8	7.0	11.6	9.9	3.7	-2.1	-9.6	-16.3	(25)
(26)			MCWB	-23.2	-24.7	-20.8	-12.4	-2.0	4.4	8.2	7.4	2.2	-3.1	-10.3	-16.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.7	-13.4	-7.1	-3.7	1.6	8.2	12.6	11.6	5.1	0.9	-3.1	-7.7	(27)
(28)			MCDWB	-11.0	-12.8	-6.1	-3.1	3.0	11.9	16.0	14.3	6.6	1.9	-2.1	-7.1	(28)
(29)		2%	WB	-16.1	-18.6	-13.8	-7.8	0.1	6.8	10.6	10.0	4.1	-0.6	-5.2	-10.9	(29)
(30)			MCDWB	-15.6	-18.3	-13.4	-7.1	1.3	9.7	13.9	12.1	5.5	0.2	-4.1	-10.4	(30)
(31)		5%	WB	-19.5	-21.6	-18.1	-10.0	-0.9	5.7	9.6	8.7	3.2	-1.8	-7.5	-13.9	(31)
(32)			MCDWB	-19.1	-21.3	-17.7	-9.4	0.3	8.2	12.6	10.9	4.5	-0.9	-6.6	-13.5	(32)
(33)		10%	WB	-23.2	-24.7	-20.7	-12.4	-1.9	4.6	8.5	7.6	2.3	-3.0	-10.3	-16.7	(33)
(34)			MCDWB	-22.9	-24.4	-20.3	-11.8	-0.8	6.8	11.2	9.6	3.4	-2.3	-9.7	-16.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.5	6.3	6.9	5.9	4.7	6.5	5.1	4.3	4.9	6.1	6.0	(35)
(36)			MCDBR	8.8	8.5	9.1	8.1	5.4	7.0	8.8	7.0	5.0	5.1	9.0	8.7	(36)
(37)			MCWBR	8.5	8.3	8.9	7.6	4.4	4.5	5.3	4.5	3.8	4.6	8.2	8.4	(37)
(38)		5% WB	MCDBR	8.8	8.6	9.2	8.0	5.3	6.7	8.2	6.4	4.6	4.9	9.0	8.7	(38)
(39)			MCWBR	8.4	8.4	8.9	7.6	4.4	4.6	5.5	4.4	3.6	4.5	8.2	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.168	0.244	0.302	0.315	0.313	0.330	0.310	0.269	0.181	N/A	N/A	(40)	
(41)		taud	N/A	1.916	2.109	2.009	2.095	2.266	2.343	2.403	2.330	1.931	N/A	N/A	(41)	
(42)		Ebn at Noon	0	452	718	788	839	863	830	800	705	384	0	0	(42)	
(43)		Edh at Noon	0	28	68	113	120	106	95	77	56	26	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.21	1.64	4.31	6.55	6.79	5.25	3.42	1.59	0.39	0.00	0.00	(44)	
(45)		RadStd	0.00	0.02	0.08	0.13	0.22	0.58	0.32	0.29	0.12	0.04	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page