

BREVOORT ISLAND, NU, CanadaWMO: **710970**Lat: **63.340N**Lon: **64.157W**Elev: **376**StdP: **96.89**Time Zone: **-5.00 (NAE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.2	-29.6	N/A	N/A	N/A	N/A	N/A	N/A	26.1	-20.1	24.3	-18.7	4.9	270	1.121

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	14.8	N/A	12.8	N/A	10.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.8	16.2	DB	-32.2	17.1	2.3	2.3	-33.9	18.7	-35.2	20.0	-36.5	21.3	-38.2	22.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.7	-20.9	-21.9	-18.5	-12.0	-4.5	1.1	5.4	5.3	0.7	-4.1	-8.9	-14.9	(6)	
	DBStd	10.40	5.39	5.41	5.70	4.98	3.36	3.08	4.03	3.04	2.44	2.88	4.15	5.79	(7)	
	HDD10.0	6472	958	893	883	662	450	268	154	152	278	436	566	773	(8)	
	HDD18.3	9496	1216	1127	1141	912	708	518	400	405	528	694	816	1031	(9)	
	CDD10.0	17	0	0	0	0	0	0	12	5	0	0	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	6.5	6.6	6.5	6.8	7.0	5.8	5.8	5.3	5.6	6.4	7.1	7.6	7.3	(14)	
(15) Precipitation	PrecAvg	603	35	24	23	27	33	43	59	78	82	82	64	53	(15)	
	PrecMax	804	85	92	60	58	65	87	131	123	133	130	162	119	(16)	
	PrecMin	332	10	7	6	5	10	20	20	33	20	46	22	16	(17)	
	PrecStd	116	20	19	14	13	13	16	24	23	26	19	31	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.8	-3.1	-1.6	-0.5	9.0	12.1	18.5	16.3	9.1	3.1	0.0	-0.8	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	-7.3	-7.3	-4.7	-1.9	2.8	9.5	16.0	13.8	6.7	1.7	-1.0	-1.9	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	-10.5	-12.3	-7.9	-3.5	0.4	7.3	14.1	12.0	5.1	0.6	-2.3	-4.6	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	-13.2	-14.9	-10.5	-5.2	-0.5	5.6	12.0	10.1	4.0	-0.2	-3.5	-6.8	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
(31) Mean Daily Temperature Range	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
	5% DB	MDBR	4.3	4.5	4.7	4.6	3.6	3.7	4.7	4.2	2.9	2.9	3.7	4.1	(35)	
		MCDBR	6.6	7.1	7.2	5.3	4.6	6.3	6.4	6.6	4.8	3.5	4.2	4.5	(36)	
(40) Clear-Sky Solar Irradiance	taub	taud	1.949	2.184	2.167	2.045	2.049	2.207	2.385	2.436	2.479	2.381	2.045	1.895	(41)	
		Ebn at Noon	507	775	868	879	892	898	883	850	818	703	476	275	(42)	
	Edh at Noon		30	58	90	129	142	124	102	89	69	49	26	14	(43)	
															(44)	
(44) All-Sky Solar Radiation	RadAvg	0.22	1.08	2.87	5.10	6.55	6.36	5.35	3.88	2.36	1.04	0.29	0.09		(44)	
	RadStd	0.02	0.06	0.12	0.18	0.30	0.45	0.50	0.38	0.20	0.10	0.02	0.01		(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	+2.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page