

TRIPLE ISLAND, BC, Canada

WMO: 711000

Lat: 54.295N

Lon: 130.881W

Elev: 68

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	25.6	10.5	9.4	24.6	15.5	12.1	27.7	49.6	45.5	46.7	44.6	22.7	50	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.2	60.8	57.7	59.4	56.9	58.5	56.3	58.4	59.8	57.6	58.9	56.8	58.1	11.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.7	71.2	59.1	56.8	68.9	58.3	56.0	67.0	57.6	25.4	60.1	24.8	59.1	24.3	58.3	63.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(p)
(4) 41.7	36.2	31.0		21.3	63.7	4.7	2.8	17.9	65.7	15.1	67.3	12.5	68.8	9.0	70.9	
(5)			DB	18.4	59.6	4.9	1.5	14.9	60.7	12.0	61.5	9.3	62.4	5.7	63.5	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	39.4	40.6	41.8	45.0	48.4	52.1	55.2	56.1	53.8	48.8	44.0	40.7		
	DBStd	6.97	6.24	4.89	3.61	2.68	2.89	2.14	1.89	1.80	2.32	3.02	4.76	6.03		
	HDD50	1599	329	263	255	152	66	5	0	0	3	56	181	289		
	HDD65	6499	794	682	720	600	513	386	305	277	336	501	631	754		
	CDD50	574	0	0	0	1	18	70	160	188	117	19	1	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	14.9	19.3	18.4	16.0	13.9	12.9	10.6	10.7	10.5	11.9	16.1	18.9	20.2		
	PrecAvg	93.1	9.6	7.1	7.5	6.2	4.0	3.9	4.1	6.1	8.5	12.2	11.5	10.6		
(15) Precipitation	PrecMax	120.0	20.0	12.3	15.8	12.2	11.1	6.8	7.4	11.7	18.5	18.3	20.7	22.6		
	PrecMin	64.6	3.5	3.8	2.5	3.4	0.4	1.2	2.0	2.5	3.7	4.3	5.6	4.3		
	PrecStd	15.0	3.3	2.5	2.8	2.2	2.5	1.4	1.5	2.8	3.7	3.9	3.4	3.9		
	PrecStd	15.0	3.3	2.5	2.8	2.2	2.5	1.4	1.5	2.8	3.7	3.9	3.4	3.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	51.4	52.1	56.1	60.1	59.0	63.0	62.8	60.2	57.5	52.5	50.8		
		MCWB	45.5	47.2	47.0	48.4	52.7	55.4	58.5	58.7	56.5	52.6	48.9	46.1		
	2%	DB	48.2	49.1	48.3	52.1	55.6	57.4	59.9	61.1	58.8	54.9	51.0	49.2		
		MCWB	45.9	45.6	44.8	47.1	52.3	54.7	57.2	58.3	55.9	52.2	48.0	46.0		
	5%	DB	47.2	47.7	47.1	49.7	53.6	56.2	58.6	60.1	57.7	53.8	50.0	47.8		
		MCWB	44.8	44.6	44.2	46.1	51.4	53.9	56.4	57.8	55.4	51.3	47.1	45.4		
	10%	DB	46.2	46.4	46.1	48.3	52.2	55.2	57.7	59.1	56.9	52.8	48.9	46.7		
		MCWB	43.9	43.9	43.5	45.4	50.1	53.1	55.7	57.2	54.9	50.4	46.3	44.4		
	0.4%	WB	47.7	48.6	47.7	49.3	54.5	56.7	59.2	60.1	57.9	55.2	50.6	48.2		
		MCDB	48.2	50.7	50.5	53.5	57.2	57.9	61.4	61.2	59.1	56.3	51.6	49.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.4	46.8	46.2	48.1	52.9	55.3	57.7	59.1	56.8	52.9	48.9	46.9		
		MCDB	47.5	48.3	47.5	50.9	54.5	56.6	59.2	60.3	57.8	53.9	50.3	48.2		
	5%	WB	45.1	45.3	45.1	47.0	51.7	54.3	56.9	58.2	56.1	51.8	47.9	45.8		
		MCDB	46.7	47.1	46.6	49.2	53.1	55.5	58.2	59.5	57.2	53.3	49.4	47.4		
	10%	WB	44.1	44.0	44.1	46.0	50.5	53.5	56.1	57.4	55.2	50.8	46.8	44.7		
		MCDB	46.0	45.9	45.8	47.9	51.8	54.7	57.4	58.8	56.4	52.5	48.4	46.5		
	5% DB	MDBR	4.1	4.0	4.2	3.9	3.5	3.2	3.0	3.2	3.4	3.6	3.9	4.5		
		MCDBR	4.7	4.3	5.2	6.0	5.6	4.8	4.2	4.4	4.6	4.2	4.5	4.8		
		MCWBR	4.2	3.1	3.7	3.8	3.7	3.4	3.2	2.9	3.5	3.7	4.2	4.4		
		MCWBR	4.6	4.2	4.3	5.2	4.8	4.2	3.9	4.2	4.2	3.5	4.4	4.5		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.6	4.1	3.5	3.9	3.7	3.4	3.2	2.9	3.7	3.8	4.5	4.5		
		MCWBR	4.6	4.1	3.5	3.9	3.7	3.4	3.2	2.9	3.7	3.8	4.5	4.5		
		MCWBR	4.6	4.1	3.5	3.9	3.7	3.4	3.2	2.9	3.7	3.8	4.5	4.5		
		MCWBR	4.6	4.1	3.5	3.9	3.7	3.4	3.2	2.9	3.7	3.8	4.5	4.5		
(40) Clear-Sky Solar Irradiance	taub		0.306	0.313	0.337	0.371	0.367	0.373	0.369	0.363	0.356	0.337	0.313	0.296		
	taud		2.398	2.504	2.455	2.356	2.434	2.438	2.495	2.532	2.522	2.482	2.368	2.323		
	Ebn at Noon		208	252	268	272	279	278	277	272	259	237	200	182		
	Edh at Noon		17	21	27	34	34	34	31	29	26	21	17	15		
(44) All-Sky Solar Radiation	RadAvg		163	421	759	1213	1556	1639	1484	1280	845	465	216	131		
	RadStd		21	73	93	74	142	123	167	114	95	67	29	23		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page