

PORT HARDY, BC, Canada

WMO: 711090

Lat: 50.680N

Lon: 127.370W

Elev: 71

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	24.6	27.5	14.1	11.3	29.2	19.8	14.9	29.5	32.2	40.3	29.9	41.3	5.7	210	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	69.0	60.0	66.2	58.9	64.0	57.7	61.3	66.8	59.9	64.5	58.7	62.7	9.5	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.8	74.2	63.4	57.6	71.1	61.7	56.7	68.6	60.6	27.3	67.1	26.3	64.8	25.5	62.8	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.4	22.0	18.8	DB	19.5	76.6	4.0	3.4	16.6	79.0	14.3	81.0	12.0	82.8	9.1	85.3	(4)
(5)			WB	18.4	64.6	4.0	1.2	15.5	65.4	13.2	66.1	10.9	66.7	8.1	67.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	39.7	39.4	41.5	45.1	49.9	54.2	57.7	58.2	54.2	47.8	42.1	38.8	(6)
(7)		DBStd	8.06	5.25	4.56	4.16	3.63	3.70	3.20	2.76	2.60	3.41	3.91	4.99	4.81	(7)
(8)		HDD50	1768	321	296	266	153	47	3	0	0	6	90	238	348	(8)
(9)		HDD65	6416	785	716	730	597	467	323	228	212	325	534	686	813	(9)
(10)		CDD50	827	0	0	1	7	45	130	238	253	130	21	2	0	(10)
(11)		CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH74	19	0	0	0	0	0	8	5	5	1	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.9	8.9	7.9	7.7	6.9	6.4	5.9	5.6	4.8	4.6	6.6	8.3	9.3	(14)
(15)	Precipitation	PrecAvg	75.4	9.7	6.6	6.4	4.8	3.1	3.1	2.1	2.8	5.1	10.2	11.4	10.2	(15)
(16)		PrecMax	99.4	18.1	14.4	12.6	9.8	7.5	6.9	6.1	8.5	11.1	19.7	23.3	19.8	(16)
(17)		PrecMin	50.9	2.6	1.6	1.4	1.3	0.7	0.6	0.2	0.3	0.4	3.1	4.2	3.4	(17)
(18)		PrecStd	10.3	4.1	2.7	2.4	1.8	1.5	1.5	1.4	1.7	2.7	4.0	4.6	3.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	52.2	56.8	62.9	67.3	73.6	73.0	72.7	68.7	60.8	54.7	50.3	(19)
(20)		MCWB	48.7	47.3	49.2	52.2	55.6	60.0	62.6	62.1	60.4	55.8	51.3	47.5	(20)	
(21)		2%	DB	49.5	49.5	52.5	56.9	62.2	65.6	68.3	68.3	64.2	57.5	52.5	48.1	(21)
(22)		MCWB	47.0	45.8	47.5	49.8	53.7	57.5	60.0	60.4	57.7	53.6	50.1	45.6	(22)	
(23)		5%	DB	47.9	48.0	50.2	54.0	59.1	62.1	65.5	65.8	61.7	55.4	50.9	46.7	(23)
(24)		MCWB	45.7	44.8	46.0	48.1	52.7	55.5	58.7	59.3	56.5	52.1	48.6	44.3	(24)	
(25)		10%	DB	46.6	46.3	48.3	51.8	56.7	60.0	63.4	63.7	59.8	53.6	49.2	45.4	(25)
(26)		MCWB	44.5	43.5	45.0	46.9	51.5	54.4	57.5	58.1	55.7	50.7	47.0	43.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	49.1	51.2	53.8	57.3	60.9	63.4	63.3	61.6	57.2	52.2	48.6	(27)
(28)		MDCB	50.9	50.9	54.6	60.5	64.1	70.2	71.1	70.0	66.5	59.2	53.5	49.6	(28)	
(29)		2%	WB	47.7	46.7	48.5	50.8	55.1	58.3	61.1	61.4	59.1	54.5	50.4	46.2	(29)
(30)		MDCB	48.9	48.7	51.2	55.1	60.4	64.2	66.8	66.4	62.4	56.6	51.9	47.3	(30)	
(31)		5%	WB	46.1	45.1	46.8	49.0	53.5	56.6	59.5	60.1	57.6	52.5	49.0	44.7	(31)
(32)		MDCB	47.5	47.2	49.5	52.8	57.9	61.1	64.1	64.4	60.4	54.4	50.6	46.0	(32)	
(33)		10%	WB	44.7	43.8	45.3	47.6	52.0	55.2	58.3	58.9	56.4	51.1	47.5	43.5	(33)
(34)		MDCB	46.3	45.9	47.9	51.0	56.0	59.0	62.3	62.8	59.0	53.0	49.0	45.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	7.6	9.7	10.9	12.6	13.0	11.7	11.8	12.0	11.5	9.6	8.6	7.3	(35)	
(36)		5% DB	MCDBR	7.4	11.0	13.7	17.3	17.6	15.9	15.8	15.7	14.6	11.6	8.8	7.2	(36)
(37)		MCWBR	5.6	8.0	9.5	11.0	11.0	9.6	9.3	9.3	9.2	8.4	6.9	5.9	(37)	
(38)		5% WB	MCDBR	6.6	9.8	12.1	14.9	15.9	14.5	14.5	14.2	12.7	10.2	8.0	6.8	(38)
(39)		MCWBR	5.3	7.6	8.8	9.9	10.4	9.2	9.1	8.9	8.7	7.8	6.7	5.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.322	0.326	0.351	0.368	0.379	0.370	0.371	0.362	0.359	0.351	0.328	0.315	(40)	
(41)		taud	2.409	2.480	2.413	2.378	2.382	2.443	2.476	2.518	2.508	2.459	2.415	2.377	(41)	
(42)		Ebn at Noon	224	258	270	277	279	281	279	277	265	243	218	205	(42)	
(43)		Edh at Noon	20	24	30	35	36	34	33	30	27	24	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	235	512	773	1194	1548	1618	1718	1497	1040	555	273	188	(44)	
(45)		RadStd	32	86	110	99	175	176	216	128	98	94	49	30	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	-1.62	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page