

PORT HARDY, BC, Canada

WMO: 711090

Lat: 50.680N

Lon: 127.370W

Elev: 22

StdP: 101.07

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.1	-2.5	-9.9	1.6	-1.6	-6.8	2.1	-1.4	14.4	4.6	13.4	5.1	2.5	210	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	20.6	15.6	19.0	14.9	17.8	14.3	16.3	19.3	15.5	18.1	14.8	17.0	4.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	10.6	17.4	14.2	10.2	16.5	13.7	9.8	15.9	45.6	19.5	43.3	18.2	41.5	17.1	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.8	8.4	DB	-7.0	24.8	2.2	1.9	-8.6	26.1	-9.9	27.2	-11.1	28.2	-12.7	29.6	(4)
(5)			WB	-7.6	18.1	2.2	0.6	-9.2	18.6	-10.5	18.9	-11.7	19.3	-13.3	19.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	4.3	4.1	5.3	7.3	10.0	12.4	14.3	14.5	12.3	8.8	5.6	3.8
	DBStd	4.48	2.91	2.53	2.31	2.01	2.06	1.78	1.54	1.45	1.89	2.17	2.77	2.67
	HDD10.0	982	178	164	148	85	26	2	0	0	3	50	132	193
	HDD18.3	3564	436	398	406	332	259	179	127	118	181	297	381	452
	CDD10.0	459	0	0	1	4	25	72	132	141	72	12	1	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	11	0	0	0	0	0	4	3	3	1	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	3.1	4.0	3.5	3.5	3.1	2.8	2.6	2.5	2.2	2.1	3.0	3.7	4.1
(15) Precipitation	PrecAvg	1915	246	167	163	123	80	78	54	71	129	258	290	259
	PrecMax	2524	461	365	319	250	190	174	154	217	282	500	592	504
	PrecMin	1293	66	41	36	32	18	16	6	7	9	78	107	86
	PrecStd	262	103	69	61	45	38	37	36	42	68	101	117	92
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	11.2	13.8	17.2	19.6	23.1	22.8	22.6	20.4	16.0	12.6	10.2
		MCWB	9.3	8.5	9.6	11.2	13.1	15.5	17.0	16.7	15.8	13.2	10.7	8.6
	2%	DB	9.7	9.7	11.4	13.8	16.8	18.7	20.2	20.2	17.9	14.2	11.4	9.0
		MCWB	8.3	7.7	8.6	9.9	12.1	14.1	15.5	15.8	14.3	12.0	10.0	7.5
	5%	DB	8.8	8.9	10.1	12.2	15.1	16.7	18.6	18.8	16.5	13.0	10.5	8.1
		MCWB	7.6	7.1	7.8	8.9	11.5	13.1	14.8	15.2	13.6	11.2	9.2	6.8
	10%	DB	8.1	8.0	9.1	11.0	13.7	15.5	17.5	17.6	15.4	12.0	9.6	7.4
		MCWB	7.0	6.4	7.2	8.3	10.8	12.4	14.2	14.5	13.1	10.4	8.4	6.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	9.5	10.7	12.1	14.0	16.0	17.5	17.4	16.4	14.0	11.2	9.2
		MCDB	10.5	10.5	12.6	15.9	17.8	21.2	21.7	21.1	19.2	15.1	12.0	9.8
	2%	WB	8.7	8.2	9.2	10.5	12.8	14.6	16.2	16.3	15.1	12.5	10.2	7.9
		MCDB	9.4	9.3	10.7	12.8	15.8	17.9	19.4	19.1	16.9	13.7	11.1	8.5
	5%	WB	7.8	7.3	8.2	9.5	11.9	13.7	15.3	15.6	14.2	11.4	9.5	7.1
		MCDB	8.6	8.4	9.7	11.6	14.4	16.2	17.8	18.0	15.8	12.5	10.3	7.8
	10%	WB	7.1	6.6	7.4	8.7	11.1	12.9	14.6	15.0	13.5	10.6	8.6	6.4
		MCDB	8.0	7.7	8.8	10.5	13.3	15.0	16.8	17.1	15.0	11.7	9.4	7.2
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	5.4	6.0	7.0	7.2	6.5	6.6	6.7	6.4	5.3	4.8	4.1
		MCDBR	4.1	6.1	7.6	9.6	9.8	8.8	8.8	8.7	8.1	6.5	4.9	4.0
	5% WB	MCWBR	3.1	4.5	5.3	6.1	6.1	5.3	5.2	5.2	5.1	4.6	3.8	3.3
		MCWBR	3.6	5.4	6.7	8.3	8.8	8.1	8.0	7.9	7.1	5.7	4.4	3.8
(40) Clear-Sky Solar Irradiance	taub	taub	0.322	0.326	0.351	0.368	0.379	0.370	0.371	0.362	0.359	0.351	0.328	0.315
		taud	2.409	2.480	2.413	2.378	2.382	2.443	2.476	2.518	2.508	2.459	2.415	2.377
	Edn at Noon	Edn at Noon	705	814	852	874	878	887	879	873	835	767	687	647
		Edh at Noon	62	75	95	109	114	108	103	94	86	75	61	56
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.74	1.61	2.44	3.77	4.88	5.10	5.42	4.72	3.28	1.75	0.86	0.59
	RadStd	RadStd	0.10	0.27	0.35	0.31	0.55	0.56	0.68	0.40	0.31	0.30	0.15	0.09

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	-0.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page