

SANDSPIT, BC, Canada

WMO: 711110

Lat: 53.2494N

Lon: 131.8133W

Elev: 21

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.1	28.9	13.0	10.7	28.2	17.5	13.3	30.7	48.6	44.0	43.0	43.7	13.3	330	0.696

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	68.7	61.0	66.0	59.7	64.0	58.5	61.9	66.9	60.5	64.6	59.3	62.9	8.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.5	75.8	63.9	58.4	73.1	62.7	57.5	70.5	61.5	27.6	67.3	26.7	64.9	25.9	63.1	68.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.7	33.9	28.3	DB	22.6	73.9	4.1	3.2	19.6	76.2	17.3	78.1	15.0	79.9	12.0	82.3	(4)
(5)			WB	20.2	64.5	4.1	1.6	17.2	65.7	14.9	66.6	12.6	67.5	9.6	68.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	40.0	39.4	40.3	44.1	49.3	53.9	58.3	59.6	55.8	49.4	43.1	39.8		
	DBStd	8.31	5.19	4.26	4.34	3.14	3.53	3.33	3.19	2.93	3.14	3.67	4.58	4.86		
	HDD50	1727	311	296	301	179	56	4	0	0	1	55	209	315		
	HDD65	6281	776	716	766	628	487	333	209	170	275	484	657	780		
	CDD50	927	0	0	0	1	34	121	259	298	176	36	2	0		
	CDD65	5	0	0	0	0	0	0	3	2	0	0	0	0		
	CDH74	7	0	0	0	0	0	1	4	2	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	11.2	12.9	12.2	11.9	11.5	10.9	10.3	9.3	9.1	9.9	11.4	12.0	12.9		
	PrecAvg	50.1	6.2	4.7	4.1	3.5	2.2	2.1	1.6	2.1	3.3	6.9	7.0	6.5		
(15) Precipitation	PrecMax	79.4	12.6	10.6	8.9	8.3	5.3	5.5	5.7	5.8	7.7	12.2	11.9	13.8		
	PrecMin	13.8	1.4	0.0	0.0	1.0	0.5	0.6	0.5	0.0	0.7	1.6	1.7	0.0		
	PrecStd	10.4	2.6	2.4	1.9	1.8	1.1	1.1	1.0	1.2	1.7	2.6	2.5	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.7	50.2	51.7	55.4	62.1	69.3	73.2	72.3	66.3	60.3	54.6	51.1		
		MCWB	48.7	47.6	48.3	49.1	54.0	59.2	62.3	62.3	60.1	56.4	51.6	48.9		
	2%	DB	49.0	48.3	49.3	52.4	59.1	64.2	68.6	69.0	63.8	57.7	52.1	49.4		
		MCWB	47.2	46.3	46.4	47.7	52.5	57.3	61.1	61.4	58.5	54.1	49.9	47.8		
	5%	DB	47.8	46.8	47.7	50.6	56.6	61.2	65.4	66.5	62.0	56.2	50.8	48.2		
		MCWB	46.3	44.8	45.1	46.7	51.4	55.4	59.2	60.3	57.4	52.9	48.9	46.6		
	10%	DB	46.6	45.5	46.5	49.3	54.8	59.0	63.3	64.4	60.6	54.7	49.6	46.9		
		MCWB	45.2	43.7	44.1	45.9	50.5	54.2	58.0	59.2	56.5	51.8	47.9	45.5		
	0.4%	WB	49.4	48.6	49.1	50.4	55.4	60.2	63.6	63.9	61.6	57.5	52.3	49.9		
		MCDB	50.2	49.3	50.6	52.8	60.2	67.2	70.8	69.4	64.5	59.6	53.6	50.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.8	46.7	47.2	48.9	53.5	57.8	61.5	62.2	59.8	55.4	50.6	48.2		
		MCDB	48.5	47.8	48.6	51.1	57.1	63.0	67.2	67.1	62.3	56.9	51.6	49.0		
	5%	WB	46.6	45.2	45.8	47.7	52.2	56.2	59.9	61.0	58.5	53.9	49.3	46.9		
		MCDB	47.6	46.4	47.3	49.9	55.5	60.2	64.4	65.1	60.8	55.4	50.5	47.9		
	10%	WB	45.5	44.0	44.6	46.6	51.1	54.8	58.7	59.9	57.4	52.4	48.1	45.6		
		MCDB	46.5	45.3	46.1	48.7	54.2	58.2	62.4	63.6	59.8	54.0	49.5	46.8		
	5% DB	MDBR	6.7	7.4	8.5	8.9	8.5	8.1	8.3	8.5	8.4	8.3	7.6	7.1		
		MCDBR	7.2	7.9	9.2	9.6	10.5	11.3	11.2	11.4	9.3	9.3	8.0	7.2		
		MCWBR	6.8	6.9	7.4	7.5	7.4	7.0	6.6	7.0	7.0	7.3	7.1	7.0		
		MCWBR	7.0	7.3	8.7	8.7	9.3	9.8	10.0	10.1	8.6	8.4	7.6	7.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.8	6.8	7.5	7.3	7.0	6.5	6.3	7.0	7.2	7.5	7.2	7.1		
	taub		0.318	0.325	0.350	0.385	0.385	0.373	0.375	0.373	0.365	0.351	0.327	0.309		
		taud	2.369	2.462	2.402	2.296	2.359	2.442	2.479	2.497	2.486	2.412	2.323	2.316		
(40) Clear-Sky Solar Irradiance	Ebn at Noon		208	250	265	268	274	279	276	270	258	233	199	185		
		Edh at Noon	18	23	29	37	36	34	32	30	27	23	19	16		
	RadAvg		182	448	799	1252	1562	1632	1541	1307	909	509	243	149		
(44) All-Sky Solar Radiation	RadStd		21	70	89	62	121	120	148	104	89	59	26	21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page