

AMPHITRITE POINT, BC, Canada

WMO: 711122

Lat: 48.9216N

Lon: 125.5410W

Elev: 87

StdP: 14.65

Time Zone: -8.00 (NAP)

Period: 90-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	29.2	31.9	15.2	11.9	33.6	20.9	15.8	33.5	42.8	46.3	37.0	45.0	5.2	90	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	66.3	60.3	64.1	59.3	62.4	58.4	61.0	64.8	59.9	63.1	58.9	61.7	6.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.1	75.1	62.5	58.2	72.7	61.4	57.4	70.6	60.5	27.1	64.8	26.3	63.6	25.7	62.0	65.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
31.3	26.9	22.7	DB	26.3	72.4	3.6	2.4	23.7	74.1	21.6	75.5	19.5	76.8	16.9	78.5
			WB	23.2	63.6	4.4	0.9	20.0	64.2	17.5	64.8	15.0	65.3	11.8	65.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	42.4	43.3	44.2	47.3	51.6	54.5	57.3	58.1	56.5	50.6	45.7	42.0
	DBStd	6.81	4.37	4.16	3.57	2.92	3.11	2.63	2.39	2.35	3.04	3.33	4.19	4.96
	HDD50	1130	237	189	181	89	17	1	0	0	0	32	135	249
	HDD65	5662	702	608	644	531	416	315	239	214	256	446	578	713
	CDD50	946	0	1	2	8	66	136	227	252	195	51	7	1
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	9.1	10.5	9.8	9.1	9.8	8.9	8.8	7.8	6.9	6.1	8.8	10.9	11.6
(15) Precipitation	PrecAvg	126.5	16.2	14.1	13.7	8.3	5.7	3.9	3.1	4.7	6.2	14.9	16.2	18.3
	PrecMax	153.2	25.7	35.7	27.3	17.8	10.3	7.7	12.5	11.7	12.2	35.1	29.4	29.9
	PrecMin	91.5	1.6	5.0	3.3	2.6	2.3	0.9	0.4	0.4	0.7	3.2	4.9	10.5
	PrecStd	17.3	6.6	6.5	5.4	3.3	2.4	1.9	2.9	3.3	3.0	7.8	5.3	5.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	53.7	55.3	58.1	63.9	68.1	69.4	70.4	68.3	60.8	55.3	53.6
		MCWB	47.1	47.6	49.2	50.0	56.0	57.7	61.2	60.8	60.9	55.8	51.7	44.7
	2%	DB	50.1	51.4	52.7	55.3	60.3	61.8	65.1	65.6	65.6	58.3	53.8	50.4
		MCWB	47.9	47.4	48.4	50.1	54.5	57.0	60.3	60.5	59.9	54.3	51.3	48.0
	5%	DB	48.9	50.0	51.0	53.4	58.0	60.1	62.9	63.8	63.0	56.5	52.7	49.4
		MCWB	47.3	47.0	47.3	49.3	53.8	56.0	58.8	59.7	58.8	53.3	50.6	47.6
	10%	DB	47.9	48.6	49.5	52.0	56.4	58.7	61.4	62.2	61.1	55.1	51.6	48.2
		MCWB	46.6	46.5	46.8	48.6	52.9	55.2	57.8	58.7	57.7	52.8	49.7	46.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	50.4	51.0	52.9	57.7	59.3	62.2	62.4	62.3	57.3	53.7	50.3
		MCDB	50.8	51.4	52.9	54.9	61.4	63.3	67.4	67.2	66.7	59.2	54.2	50.5
	2%	WB	48.9	49.1	49.5	51.4	56.0	57.7	60.3	60.9	60.8	55.4	52.3	49.1
		MCDB	49.5	50.0	51.3	53.5	58.9	60.6	64.3	64.6	64.1	56.6	53.0	49.6
	5%	WB	47.9	48.0	48.5	50.2	54.7	56.6	59.2	59.9	59.2	54.3	51.3	47.9
		MCDB	48.4	48.8	50.1	52.3	57.4	59.2	62.3	63.0	62.2	55.5	52.1	48.7
	10%	WB	46.8	47.0	47.6	49.2	53.2	55.6	58.2	59.0	58.1	53.4	50.1	46.8
		MCDB	47.5	48.1	49.2	51.3	55.8	58.0	60.9	61.7	60.7	54.7	51.3	47.8
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	7.5	7.9	7.9	7.6	6.8	7.0	6.9	7.2	6.8	6.6	6.1
		MCDBR	5.8	8.1	9.6	10.2	9.5	9.0	9.3	9.6	10.3	8.4	6.5	5.5
	5% WB	MCWBR	5.1	5.7	7.1	7.4	6.4	6.1	5.7	6.1	6.8	6.2	5.9	5.2
		MCWBR	5.0	6.4	7.4	7.9	8.4	7.7	8.8	8.7	9.2	6.5	5.6	5.2
(40) Clear-Sky Solar Irradiance	taub		0.327	0.326	0.345	0.367	0.388	0.368	0.356	0.358	0.348	0.351	0.334	0.321
		taud	2.441	2.515	2.472	2.400	2.361	2.447	2.520	2.526	2.539	2.476	2.437	2.417
	Ebn at Noon		232	264	276	280	277	283	285	280	272	249	226	216
		Edh at Noon	21	24	29	34	37	34	31	30	27	24	20	19
(44) All-Sky Solar Radiation	RadAvg		278	562	845	1306	1658	1803	1905	1611	1191	660	334	223
	RadStd		39	83	105	121	149	175	149	133	96	93	57	32

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page