

AMPHITRITE POINT, BC, Canada

WMO: 711122

Lat: 48.9216N

Lon: 125.5410W

Elev: 27

StdP: 101.01

Time Zone: -8.00 (NAP)

Period: 90-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.6	-0.1	-9.3	1.7	0.9	-6.1	2.3	0.8	19.1	7.9	16.6	7.2	2.3	90	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	19.0	15.7	17.8	15.2	16.9	14.7	16.1	18.2	15.5	17.3	15.0	16.5	2.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	10.7	17.0	14.6	10.4	16.3	14.1	10.1	15.8	45.1	18.2	43.3	17.5	41.8	16.6	18.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	12.0	10.2	DB	-3.2	22.4	2.0	1.3	-4.6	23.4	-5.8	24.2	-6.9	24.9	-8.4	25.9	(4)
(5)			WB	-4.9	17.6	2.5	0.5	-6.6	17.9	-8.1	18.2	-9.5	18.5	-11.2	18.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	5.8	6.3	6.8	8.5	10.9	12.5	14.1	14.5	13.6	10.3	7.6	5.5	(6)
(7)		DBStd	3.78	2.43	2.31	1.98	1.62	1.73	1.46	1.33	1.30	1.69	1.85	2.33	2.76	(7)
(8)		HDD10.0	628	132	105	101	49	9	1	0	0	0	18	75	138	(8)
(9)		HDD18.3	3146	390	338	358	295	231	175	133	119	142	248	321	396	(9)
(10)		CDD10.0	526	0	1	1	4	37	76	126	140	108	28	4	1	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.1	4.7	4.4	4.0	4.4	4.0	3.9	3.5	3.1	2.7	3.9	4.9	5.2	(14)
(15)	Precipitation	PrecAvg	3212	412	357	349	212	144	98	79	120	157	378	412	466	(15)
(16)		PrecMax	3892	654	908	694	452	261	195	318	296	311	891	746	759	(16)
(17)		PrecMin	2324	41	126	84	66	58	24	10	10	19	81	124	267	(17)
(18)		PrecStd	439	168	164	137	85	60	47	74	84	77	199	134	132	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	12.1	12.9	14.5	17.7	20.0	20.8	21.4	20.2	16.0	12.9	12.0	(19)
(20)			MCWB	8.4	8.7	9.5	10.0	13.4	14.3	16.2	16.0	16.1	13.2	11.0	7.1	(20)
(21)		2%	DB	10.0	10.8	11.5	12.9	15.7	16.5	18.4	18.7	18.7	14.6	12.1	10.2	(21)
(22)			MCWB	8.8	8.5	9.1	10.0	12.5	13.9	15.7	15.8	15.5	12.4	10.7	8.9	(22)
(23)		5%	DB	9.4	10.0	10.5	11.9	14.4	15.6	17.1	17.7	17.2	13.6	11.5	9.7	(23)
(24)			MCWB	8.5	8.4	8.5	9.6	12.1	13.3	14.9	15.4	14.9	11.8	10.3	8.7	(24)
(25)		10%	DB	8.8	9.2	9.7	11.1	13.6	14.8	16.3	16.8	16.2	12.9	10.9	9.0	(25)
(26)			MCWB	8.1	8.0	8.2	9.2	11.6	12.9	14.3	14.8	14.3	11.5	9.8	8.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	10.2	10.6	11.6	14.3	15.2	16.8	16.9	16.8	14.1	12.0	10.2	(27)
(28)			MCDWB	10.4	10.8	11.6	12.7	16.3	17.4	19.7	19.5	19.3	15.1	12.3	10.3	(28)
(29)		2%	WB	9.4	9.5	9.7	10.8	13.3	14.3	15.7	16.1	16.0	13.0	11.3	9.5	(29)
(30)			MCDWB	9.7	10.0	10.7	11.9	15.0	15.9	17.9	18.1	17.8	13.7	11.7	9.8	(30)
(31)		5%	WB	8.8	8.9	9.2	10.1	12.6	13.7	15.1	15.5	15.1	12.4	10.7	8.9	(31)
(32)			MCDWB	9.1	9.4	10.0	11.3	14.1	15.1	16.9	17.2	16.8	13.1	11.2	9.3	(32)
(33)		10%	WB	8.2	8.4	8.7	9.6	11.8	13.1	14.5	15.0	14.5	11.9	10.1	8.2	(33)
(34)			MCDWB	8.6	8.9	9.5	10.7	13.2	14.4	16.0	16.5	15.9	12.6	10.7	8.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.4	4.2	4.4	4.4	4.2	3.8	3.9	4.0	3.8	3.7	3.4	(35)	
(36)			MCDBR	3.2	4.5	5.4	5.7	5.3	5.0	5.2	5.3	5.7	4.7	3.6	3.1	(36)
(37)			MCWBR	2.8	3.2	3.9	4.1	3.5	3.4	3.2	3.4	3.8	3.5	3.3	2.9	(37)
(38)		5% WB	MCDBR	2.8	3.5	4.1	4.4	4.7	4.3	4.9	4.8	5.1	3.6	3.1	2.9	(38)
(39)			MCWBR	2.8	3.0	3.3	3.4	3.3	3.1	3.1	3.2	3.6	3.0	3.3	3.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.326	0.345	0.367	0.388	0.368	0.356	0.358	0.348	0.351	0.334	0.321	(40)	
(41)		taud	2.441	2.515	2.472	2.400	2.361	2.447	2.520	2.526	2.539	2.476	2.437	2.417	(41)	
(42)		Ebn at Noon	731	833	870	882	873	893	899	883	858	786	712	681	(42)	
(43)		Edh at Noon	65	75	91	108	117	108	99	95	85	77	64	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.88	1.77	2.66	4.12	5.23	5.68	6.01	5.08	3.75	2.08	1.05	0.70	(44)	
(45)		RadStd	0.12	0.26	0.33	0.38	0.47	0.55	0.47	0.42	0.30	0.29	0.18	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page