

BURGEO, NL, CanadaWMO: **711520**Lat: **47.613N**Lon: **57.610W**Elev: **11**StdP: **101.20**Time Zone: **-3.50 (NAF)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.2	-12.2	-18.7	0.7	-13.5	-16.8	0.9	-11.7	21.3	-1.4	19.1	-2.5	6.0	300	0.764

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	21.2	17.4	20.1	17.0	19.0	16.5	18.8	20.0	17.9	19.2	17.1	18.4	4.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.2	19.5	17.4	12.5	18.7	16.6	11.8	17.9	53.4	20.1	50.8	19.2	48.3	18.4	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	15.1	13.0	DB	-16.8	24.7	2.8	1.5	-18.8	25.8	-20.4	26.6	-22.0	27.5	-24.0	28.5	(4)
(5)			WB	-17.2	20.5	2.6	1.6	-19.1	21.7	-20.7	22.6	-22.1	23.6	-24.0	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.3	-3.9	-4.6	-2.2	1.9	6.4	10.3	14.6	16.5	13.0	8.1	3.6	-0.7	(6)
(7)		DBStd	7.69	3.93	4.35	3.88	2.61	2.32	2.40	1.97	1.88	2.71	2.84	3.40	3.83	(7)
(8)		HDD10.0	2204	432	408	379	244	115	24	0	0	6	72	192	332	(8)
(9)		HDD18.3	4763	690	641	638	494	371	242	116	62	162	317	442	591	(9)
(10)		CDD10.0	491	0	0	0	0	2	33	144	202	95	14	1	0	(10)
(11)		CDD18.3	6	0	0	0	0	0	0	1	4	1	0	0	0	(11)
(12)		CDH23.3	5	0	0	0	0	0	0	2	3	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.7	7.2	7.1	6.7	6.2	5.0	4.3	3.8	4.0	4.8	5.6	6.5	7.1	(14)
(15)	Precipitation	PrecAvg	1818	167	139	138	140	129	153	144	142	137	161	182	186	(15)
(16)		PrecMax	2240	293	268	248	266	223	295	258	339	218	265	267	305	(16)
(17)		PrecMin	1500	89	40	56	49	26	30	39	65	67	63	98	77	(17)
(18)		PrecStd	190	59	57	57	66	46	77	52	66	42	55	52	63	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	6.4	6.8	10.5	15.7	19.9	22.2	23.2	21.4	16.6	12.4	9.0	(19)
(20)			MCWB	6.0	5.8	4.6	6.5	10.2	13.7	16.9	18.1	17.7	13.8	11.6	8.1	(20)
(21)		2%	DB	4.7	4.1	4.9	7.9	13.1	17.0	20.2	21.7	19.3	15.0	11.1	7.3	(21)
(22)			MCWB	4.1	3.2	3.1	5.4	9.1	12.6	16.2	18.0	16.4	13.3	10.5	6.5	(22)
(23)		5%	DB	3.2	2.6	3.6	6.6	11.5	15.4	18.9	20.6	18.2	13.7	10.0	6.1	(23)
(24)			MCWB	2.5	1.6	2.2	4.4	8.2	11.7	15.8	17.7	15.7	12.1	9.4	5.4	(24)
(25)		10%	DB	1.8	1.4	2.6	5.4	10.1	14.0	17.8	19.7	17.1	12.6	8.8	4.8	(25)
(26)			MCWB	1.1	0.6	1.3	3.7	7.5	11.3	15.4	17.3	15.2	11.1	8.1	3.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.7	5.2	7.2	11.3	15.2	18.7	20.4	18.7	15.1	11.9	8.3	(27)
(28)			MCDWB	6.4	6.1	6.5	9.0	14.2	18.3	20.2	21.7	19.9	15.8	12.3	8.9	(28)
(29)		2%	WB	4.2	3.3	3.6	5.8	9.9	13.7	17.5	19.4	17.4	13.7	10.6	6.7	(29)
(30)			MCDWB	4.6	3.8	4.5	7.3	12.4	15.7	18.9	20.6	18.4	14.6	11.0	7.2	(30)
(31)		5%	WB	2.6	1.6	2.5	4.8	8.8	12.7	16.7	18.6	16.5	12.6	9.6	5.5	(31)
(32)			MCDWB	3.0	2.2	3.4	6.0	10.9	14.5	18.0	19.8	17.4	13.5	10.0	6.1	(32)
(33)		10%	WB	1.3	0.6	1.5	4.0	7.8	11.7	16.0	17.9	15.5	11.5	8.2	4.0	(33)
(34)			MCDWB	1.7	1.2	2.4	5.1	9.6	13.6	17.1	19.1	16.5	12.4	8.8	4.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.1	6.2	6.0	5.5	6.1	5.5	4.9	5.5	6.4	6.1	5.4	5.3	(35)
(36)			MCDBR	7.3	6.6	6.1	7.0	8.7	8.4	7.3	7.1	7.2	6.8	5.7	5.8	(36)
(37)			MCWBR	7.6	6.6	5.3	5.3	5.8	5.3	4.9	5.0	5.4	5.7	5.9	6.1	(37)
(38)		5% WB	MCDWB	7.4	6.9	5.7	6.0	7.4	7.0	5.6	5.9	5.9	6.1	5.5	6.1	(38)
(39)			MCWBR	7.7	7.1	5.3	5.0	5.3	4.9	4.3	4.7	5.0	5.7	6.0	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.308	0.334	0.361	0.367	0.389	0.422	0.401	0.368	0.344	0.318	0.307	(40)	
(41)		taud	2.331	2.355	2.340	2.357	2.424	2.388	2.340	2.391	2.477	2.491	2.484	2.346	(41)	
(42)		Ebn at Noon	769	855	884	891	896	875	839	842	841	806	756	712	(42)	
(43)		Edh at Noon	73	88	105	114	111	116	120	109	92	78	64	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.01	1.49	2.78	4.13	5.07	5.12	4.81	4.39	3.54	2.23	1.19	0.80	(44)	
(45)		RadStd	0.08	0.18	0.25	0.38	0.43	0.56	0.40	0.27	0.21	0.15	0.13	0.09	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A	

Nomenclature: See separate page