

ESKASONI FIRST NATION, NS, Canada

WMO: 711750

Lat: 45.921N

Lon: 60.647W

Elev: 92

StdP: 14.65

Time Zone: -4.00 (NAA)

Period: 12-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.3	8.9	-3.0	4.7	7.8	0.3	5.6	10.7	42.2	45.1	35.9	31.7	8.4	290	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.3	78.2	68.1	76.0	66.9	73.8	66.0	70.8	75.6	69.3	73.5	68.1	71.6	8.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	107.9	73.0	67.9	102.9	71.6	66.7	98.5	70.6	34.7	75.4	33.5	73.7	32.5	71.6	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.9	23.4	19.5	DB	0.1	84.5	3.7	2.3	-2.5	86.2	-4.7	87.5	-6.7	88.8	-9.4	90.5	(4)
(5)			WB	-0.8	72.8	3.6	1.4	-3.3	73.9	-5.4	74.7	-7.4	75.5	-10.0	76.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	26.0	24.7	28.9	38.1	48.0	55.9	65.8	67.3	59.9	50.4	40.6	31.3
	DBStd	16.07	7.99	8.40	7.57	6.30	5.55	5.45	4.37	3.84	5.76	6.08	7.15	7.60
	HDD50	3531	745	709	655	359	106	11	0	0	4	70	293	579
	HDD65	7528	1210	1129	1119	806	526	275	41	22	170	453	733	1044
	CDD50	1659	0	0	1	3	45	188	491	538	301	82	10	0
	CDD65	182	0	0	0	0	0	3	67	95	17	0	0	0
	CDH74	449	0	0	0	0	7	15	213	195	19	0	0	0
	CDH80	39	0	0	0	0	1	1	27	10	0	0	0	0
Wind	WSAvg	8.9	10.3	9.9	9.5	9.1	8.1	7.5	7.7	8.0	8.6	8.6	9.8	9.4
Precipitation	PrecAvg	59.1	5.8	5.2	4.6	4.4	4.0	4.1	3.5	3.9	4.7	6.0	6.0	6.8
	PrecMax	72.9	8.9	7.2	8.7	7.4	7.0	6.8	6.7	9.0	12.1	10.5	9.5	14.0
	PrecMin	45.3	2.8	1.9	1.9	2.3	1.9	2.0	1.5	1.7	1.7	2.4	3.8	3.8
	PrecStd	6.0	1.5	1.5	1.7	1.3	1.4	1.5	1.2	1.3	2.4	2.2	1.6	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	47.6	53.6	58.0	71.0	76.1	83.6	81.5	76.5	67.7	60.6	52.3
		MCWB	47.3	46.5	47.6	52.4	60.4	63.6	70.4	70.8	67.7	62.9	58.1	50.5
	2%	DB	44.7	44.0	44.7	54.2	65.5	71.1	78.3	78.4	72.9	64.8	58.2	49.5
		MCWB	44.3	43.0	41.1	48.8	55.0	61.0	67.9	68.8	66.0	60.5	56.3	48.5
	5%	DB	41.3	40.2	41.5	51.1	61.1	68.4	76.2	76.0	70.7	62.5	55.3	46.6
		MCWB	40.4	38.8	39.2	47.8	52.4	59.7	66.6	67.6	65.6	58.8	53.6	45.4
	10%	DB	37.7	36.9	38.5	47.9	57.5	65.4	73.7	74.2	68.9	60.3	51.8	42.6
		MCWB	36.2	35.6	35.5	44.1	50.9	58.1	65.5	66.7	64.7	56.7	49.5	41.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.4	47.2	48.6	54.7	62.2	66.2	72.8	72.6	70.0	64.3	59.1	51.4
		MCDB	47.9	47.4	52.5	56.5	69.8	72.5	79.5	77.4	73.1	65.6	60.2	51.7
	2%	WB	44.2	43.3	42.8	51.5	57.7	63.4	70.6	71.2	68.4	61.9	56.7	48.8
		MCDB	44.5	43.9	43.7	53.1	62.2	67.7	76.3	75.4	70.8	64.0	57.8	49.5
	5%	WB	40.7	39.2	39.4	48.1	54.7	61.7	69.0	70.0	67.4	59.6	53.6	45.5
		MCDB	41.2	39.9	41.3	50.0	58.0	66.0	73.4	74.3	69.8	61.8	55.1	46.4
	10%	WB	36.7	35.5	36.1	45.4	52.2	59.8	67.6	68.6	65.8	57.4	49.9	41.6
		MCDB	37.6	36.7	37.8	47.4	55.8	64.5	71.5	72.5	68.6	59.8	51.4	42.8
Mean Daily Temperature Range	5% DB	MDBR	12.9	14.0	13.2	13.2	15.5	14.6	14.3	13.3	14.4	13.0	11.5	10.3
		MCDBR	16.5	17.9	16.5	16.8	21.7	19.3	17.8	15.3	15.2	13.9	15.6	14.8
		MCWBR	17.5	17.5	14.6	11.9	12.9	11.4	9.6	8.5	10.4	10.6	15.9	15.6
	5% WB	MCDBR	16.8	18.6	16.0	13.5	17.3	16.0	14.2	12.7	12.9	12.9	14.9	15.0
		MCWBR	17.9	19.0	15.6	11.3	12.3	10.6	8.5	8.0	9.9	11.9	15.6	16.2
Clear-Sky Solar Irradiance	taub	0.303	0.295	0.325	0.357	0.370	0.394	0.421	0.397	0.364	0.340	0.323	0.301	
	taud	2.355	2.408	2.401	2.402	2.425	2.383	2.344	2.411	2.480	2.522	2.502	2.434	
	Ebn at Noon	252	282	287	286	285	277	267	270	271	262	246	241	
	Edh at Noon	24	27	32	35	36	37	38	35	30	25	21	20	
All-Sky Solar Radiation	RadAvg	352	618	1015	1323	1590	1707	1710	1534	1198	747	403	265	
	RadStd	25	69	82	107	150	151	114	102	89	68	48	20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.79	N/A	N/A	N/A	N/A

Nomenclature: See separate page