

CAPE KAKKIVIAK, NL, Canada

WMO: 711760

Lat: 59.985N

Lon: 64.165W

Elev: 1808

StdP: 13.76

Time Zone: -4.00 (NAA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-26.5	-23.3	N/A	N/A	N/A	N/A	N/A	N/A	61.2	-16.2	57.6	-15.2	34.3	280	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.0	64.8	N/A	60.3	N/A	56.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 54.0	47.9	42.2	DB	-29.8	69.7	3.8	3.4	-32.6	72.2	-34.8	74.2	-37.0	76.1	-39.8	78.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	-5.9	-6.1	1.6	14.0	25.8	35.3	43.5	43.8	34.3	26.3	18.0	6.9	(6)	
	DBStd	19.42	10.95	11.95	12.61	9.41	8.47	7.64	7.97	7.69	6.28	5.70	6.57	11.55	(7)	
	HDD50	11057	1734	1571	1499	1081	752	450	238	228	473	736	959	1336	(8)	
	HDD65	16452	2199	1991	1964	1531	1217	892	668	658	921	1201	1409	1801	(9)	
	CDD50	83	0	0	0	0	1	8	36	36	2	0	0	0	(10)	
	CDD65	2	0	0	0	0	0	0	1	1	0	0	0	0	(11)	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	17.3	24.2	18.9	19.6	18.1	14.8	14.5	12.3	14.4	16.8	14.6	17.2	21.9	(14)	
	PrecAvg	28.7	2.0	1.6	1.7	1.7	1.5	2.5	3.8	2.8	3.6	3.1	2.4	2.1	(15)	
(16) Precipitation	PrecMax	36.3	4.0	3.6	4.3	3.9	3.3	4.8	5.8	4.0	7.0	6.2	4.4	5.1	(16)	
	PrecMin	22.1	0.3	0.1	0.2	0.6	0.3	1.2	2.3	1.4	1.5	1.7	0.9	0.4	(17)	
	PrecStd	3.1	0.9	0.9	1.0	0.8	0.7	0.7	0.9	0.7	1.3	1.0	0.8	1.1	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	32.8	30.4	39.1	54.4	64.6	70.1	69.1	57.3	48.2	36.6	36.0	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	22.8	29.7	27.4	32.9	49.7	58.4	65.1	65.1	52.2	41.8	32.0	30.1	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	16.8	18.8	24.6	30.7	44.7	51.9	60.3	60.8	48.0	35.9	29.5	26.0	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	10.4	11.6	19.9	27.7	39.7	47.4	56.0	56.3	43.7	32.8	26.7	21.7	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.1	9.9	9.7	8.7	9.4	10.1	10.0	7.4	5.8	6.3	7.3	(35)	
		MCDBR	14.5	13.1	13.8	13.5	14.6	17.1	15.5	15.3	14.2	11.2	9.9	8.9	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.199	0.236	0.265	0.326	0.343	0.345	0.337	0.325	0.322	0.273	0.221	0.184	(40)	
	taud		2.109	2.198	2.183	2.034	2.114	2.311	2.464	2.533	2.474	2.480	2.210	2.027	(41)	
	Ebn at Noon		197	251	277	274	278	280	281	277	257	239	185	152	(42)	
	Edh at Noon		13	22	31	44	44	37	31	27	24	17	12	9	(43)	
(44) All-Sky Solar Radiation	RadAvg		113	388	880	1401	1775	1691	1515	1169	692	316	101	51	(44)	
	RadStd		15	38	76	135	184	137	148	123	59	34	12	6	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page