

CAPE KAKKIVIAK, NL, Canada

WMO: 711760

Lat: 59.985N

Lon: 64.165W

Elev: 551

StdP: 94.88

Time Zone: -4.00 (NAA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-32.5	-30.7	N/A	N/A	N/A	N/A	N/A	N/A	27.4	-26.8	25.8	-26.2	15.3	280	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	18.2	N/A	15.7	N/A	13.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.2	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	21.4	18.9	DB	-34.3	21.0	2.1	1.9	-35.9	22.3	-37.1	23.4	-38.3	24.5	-39.9	25.9	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.7	-21.1	-21.2	-16.9	-10.0	-3.5	1.8	6.4	6.6	1.3	-3.2	-7.8	-14.0
	DBStd	10.79	6.08	6.64	7.01	5.23	4.71	4.25	4.43	4.27	3.49	3.17	3.65	6.42
	HDD10.0	6143	963	873	833	601	418	250	132	127	263	409	533	742
	HDD18.3	9140	1222	1106	1091	851	676	496	371	366	512	667	783	1001
	CDD10.0	46	0	0	0	0	1	4	20	20	1	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.7	10.8	8.4	8.7	8.1	6.6	6.5	5.5	6.4	7.5	6.5	7.7	9.8
Precipitation	PrecAvg	729	51	41	42	43	38	63	97	70	91	78	61	53
	PrecMax	923	101	92	110	99	84	122	147	101	177	158	113	129
	PrecMin	562	7	3	6	14	7	31	58	35	38	44	24	10
	PrecStd	79	23	23	25	21	17	18	23	17	32	25	21	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.8	0.4	-0.9	4.0	12.5	18.1	21.2	20.6	14.0	9.0	2.6	2.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-5.1	-1.3	-2.6	0.5	9.8	14.7	18.4	18.4	11.2	5.5	0.0	-1.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-8.4	-7.3	-4.1	-0.7	7.0	11.0	15.7	16.0	8.9	2.2	-1.4	-3.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-12.0	-11.3	-6.7	-2.4	4.3	8.6	13.3	13.5	6.5	0.5	-3.0	-5.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.0	5.5	5.4	4.8	5.2	5.6	5.6	4.1	3.2	3.5	4.1
		MCDBR	8.0	7.3	7.7	7.5	8.1	9.5	8.6	8.5	7.9	6.2	5.5	4.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.199	0.236	0.265	0.326	0.343	0.345	0.337	0.325	0.322	0.273	0.221	0.184	
	taud	2.109	2.198	2.183	2.034	2.114	2.311	2.464	2.533	2.474	2.480	2.210	2.027	
	Ebn at Noon	621	792	873	863	877	884	887	874	811	753	583	478	
	Edh at Noon	41	69	97	138	138	116	97	84	75	53	37	28	
All-Sky Solar Radiation	RadAvg	0.36	1.22	2.77	4.42	5.59	5.33	4.78	3.68	2.18	1.00	0.32	0.16	
	RadStd	0.05	0.12	0.24	0.42	0.58	0.43	0.47	0.39	0.18	0.11	0.04	0.02	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page