

CAPE KIGLAPAIT, NL, Canada

WMO: 711770

Lat: 57.136N

Lon: 61.476W

Elev: 2737

StdP: 13.30

Time Zone: -4.00 (NAA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-24.2	-20.1	N/A	N/A	N/A	N/A	N/A	N/A	75.3	-7.6	72.9	-7.7	21.9	320	1.196

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	64.9	N/A	60.8	N/A	57.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	13.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 60.9	52.8	45.9	DB	-28.8	71.8	4.2	3.1	-31.8	74.1	-34.3	75.9	-36.7	77.7	-39.8	79.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	-0.6	-2.7	2.3	14.4	26.8	37.8	45.2	45.9	35.7	26.1	16.3	7.2		
	DBStd	19.17	11.38	11.07	11.18	9.21	8.69	8.99	7.81	7.60	7.21	7.01	7.46	11.07		
	HDD50	10576	1569	1477	1480	1068	722	383	192	174	432	742	1010	1327		
	HDD65	15938	2034	1897	1945	1518	1185	816	613	592	879	1207	1460	1792		
	CDD50	113	0	0	0	0	2	17	44	47	3	0	0	0		
	CDD65	2	0	0	0	0	0	1	1	0	0	0	0	0		
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	19.1	22.0	22.4	20.7	21.3	18.8	17.3	16.0	15.5	17.5	19.2	18.7	20.7		
(15) Precipitation	PrecAvg	38.0	3.4	3.0	2.6	2.4	2.1	2.8	4.4	3.5	3.5	3.7	3.3	3.2		
	PrecMax	48.4	7.2	6.0	5.8	5.2	5.2	4.9	7.7	6.9	7.4	7.8	7.9	7.0		
	PrecMin	28.4	0.3	0.4	0.4	0.8	0.2	1.1	2.0	1.8	1.3	1.9	0.9	0.9		
	PrecStd	4.5	1.4	1.5	1.4	1.1	1.1	0.9	1.4	1.1	1.4	1.2	1.3	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.5	31.5	33.3	41.5	58.8	69.5	70.0	69.0	59.3	49.5	38.5	33.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	24.3	28.0	25.7	36.6	50.7	62.1	64.0	64.6	54.5	45.1	33.4	29.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	21.1	18.9	22.0	31.8	45.5	56.2	59.8	61.0	50.9	40.3	29.8	26.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	16.5	11.7	18.1	28.2	40.5	51.1	56.7	57.4	47.1	35.7	26.6	22.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	9.5	10.1	9.8	10.0	9.8	9.9	9.7	8.9	7.1	7.3	9.0		
		MCDBR	11.7	9.5	14.8	13.0	16.2	16.3	12.7	14.3	14.6	13.1	11.3	9.5		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.203	0.221	0.246	0.285	0.317	0.317	0.327	0.314	0.291	0.263	0.221	0.203		
	taud		2.252	2.291	2.236	2.157	2.230	2.456	2.514	2.560	2.593	2.580	2.360	2.160		
	Ebn at Noon		234	277	294	295	291	293	288	285	278	260	224	193		
	Edh at Noon		15	22	31	40	40	32	30	27	22	17	13	12		
(44) All-Sky Solar Radiation	RadAvg		180	495	976	1492	1813	1682	1455	1256	894	454	199	109		
	RadStd		29	61	101	113	178	176	134	122	64	36	17	11		

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page